




OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
M13
 Machine Id
71-GG-3300A MAIN POWER GAS GENERATOR A (71-T-3390A) (S/N Maint Plan 22480)
 Component
Jet Turbine
 Fluid
MOBIL JET OIL II (924 LTR)

DIAGNOSIS

Recommendation

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates (2 to 100 microns in size) present in the oil. The water content is negligible.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

| method | limit/base | current | history1 | history2 |
|---------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | PP | PP | PP |
| Sample Date | Client Info | 28 Nov 2023 | 16 Oct 2023 | 11 Sep 2023 |
| Machine Age | hrs | 0 | 0 | 0 |
| Oil Age | hrs | 0 | 0 | 0 |
| Oil Changed | Client Info | N/A | N/A | N/A |
| Sample Status | | ABNORMAL | NORMAL | ABNORMAL |

WEAR METALS

| method | limit/base | current | history1 | history2 | |
|-----------|------------|------------------|--------------|----------|----|
| Iron | ppm | ASTM D5185(m) >8 | 0 | 0 | <1 |
| Chromium | ppm | ASTM D5185(m) >2 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185(m) >2 | <1 | <1 | <1 |
| Titanium | ppm | ASTM D5185(m) >2 | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185(m) >2 | <1 | <1 | <1 |
| Aluminum | ppm | ASTM D5185(m) >2 | <1 | 0 | 0 |
| Lead | ppm | ASTM D5185(m) >3 | 0 | 0 | <1 |
| Copper | ppm | ASTM D5185(m) >3 | <1 | <1 | <1 |
| Tin | ppm | ASTM D5185(m) >2 | 0 | 0 | 0 |
| Antimony | ppm | ASTM D5185(m) | 0 | 0 | 0 |
| Vanadium | ppm | ASTM D5185(m) | 0 | 0 | 0 |
| Beryllium | ppm | ASTM D5185(m) | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185(m) | 0 | 0 | 0 |

ADDITIVES

| method | limit/base | current | history1 | history2 | |
|------------|------------|---------------|--------------|----------|------|
| Boron | ppm | ASTM D5185(m) | <1 | <1 | <1 |
| Barium | ppm | ASTM D5185(m) | 0 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185(m) | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185(m) | 0 | 0 | 0 |
| Magnesium | ppm | ASTM D5185(m) | <1 | 0 | 0 |
| Calcium | ppm | ASTM D5185(m) | <1 | <1 | 0 |
| Phosphorus | ppm | ASTM D5185(m) | 2844 | 2893 | 2971 |
| Zinc | ppm | ASTM D5185(m) | <1 | <1 | <1 |
| Sulfur | ppm | ASTM D5185(m) | 0 | 1 | 0 |
| Lithium | ppm | ASTM D5185(m) | <1 | <1 | <1 |

CONTAMINANTS

| method | limit/base | current | history1 | history2 | |
|-----------|------------|-------------------|--------------|----------|-------|
| Silicon | ppm | ASTM D5185(m) >8 | 1 | 0 | 0 |
| Sodium | ppm | ASTM D5185(m) | <1 | 0 | <1 |
| Potassium | ppm | ASTM D5185(m) >20 | 2 | 0 | 0 |
| Water | % | ASTM D6304* >.1 | 0.053 | --- | 0.097 |
| ppm Water | ppm | ASTM D6304* >1000 | 533 | --- | 976.0 |


FLUID CLEANLINESS

| method | limit/base | current | history1 | history2 |
|-----------------|------------------------|-------------------|----------|------------|
| Particles >4µm | ASTM D7647 >2500 | ▲ 7402 | 1526 | ▲ 7893 |
| Particles >6µm | ASTM D7647 >640 | ▲ 1690 | 503 | ▲ 2415 |
| Particles >14µm | ASTM D7647 >80 | ▲ 163 | 40 | ▲ 142 |
| Particles >21µm | ASTM D7647 >20 | ▲ 53 | 12 | 25 |
| Particles >38µm | ASTM D7647 >4 | ▲ 7 | 2 | 2 |
| Particles >71µm | ASTM D7647 >3 | 3 | 0 | 1 |
| Oil Cleanliness | ISO 4406 (c) >18/16/13 | ▲ 20/18/15 | 18/16/12 | ▲ 20/18/14 |




OIL ANALYSIS REPORT


Particle Trend




Water (KF)




Acid Number



Water (KF)



Viscosity @ 40°C




| FLUID DEGRADATION | method | limit/base | current | history1 | history2 | |
|-------------------|----------|------------|---------|-------------|----------|------|
| Acid Number (AN) | mg KOH/g | ASTM D974* | 0.03 | 0.11 | 0.13 | 0.09 |

| VISUAL | method | limit/base | current | history1 | history2 | |
|------------------|--------|------------|---------|--------------|----------|-------|
| White Metal | scalar | Visual* | NONE | NONE | NONE | NONE |
| Yellow Metal | scalar | Visual* | NONE | NONE | NONE | NONE |
| Precipitate | scalar | Visual* | NONE | NONE | NONE | NONE |
| Silt | scalar | Visual* | NONE | NONE | NONE | NONE |
| Debris | scalar | Visual* | NONE | NONE | NONE | NONE |
| Sand/Dirt | scalar | Visual* | NONE | NONE | NONE | NONE |
| Appearance | scalar | Visual* | NORML | NORML | NORML | NORML |
| Odor | scalar | Visual* | NORML | NORML | NORML | NORML |
| Emulsified Water | scalar | Visual* | >.1 | NEG | NEG | NEG |
| Free Water | scalar | Visual* | | NEG | NEG | NEG |


| FLUID PROPERTIES | method | limit/base | current | history1 | history2 | |
|------------------|--------|---------------|---------|-------------|----------|------|
| Visc @ 40°C | cSt | ASTM D7279(m) | 27.6 | 25.4 | 25.5 | 25.8 |

SAMPLE IMAGES




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



Particle Count



Acid Number



ISO 17025:2017
Accredited
Laboratory

Laboratory Sample No. :
Lab Number :
Unique Number :
Test Package :

WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 HUSKY SEA ROSE /AKER SOLUTIONS
PP
: 02605890
: 5706976
: IND 2

Received : 02 Jan 2024
Diagnosed : 03 Jan 2024
Diagnostician : Kevin Marson

PO BOX 20
ST. JOHN'S, NL
CA A1C 6C9
Contact: Nick Fewer
nick.fewer@akersolutions.com
T: (709)757-4582
F: (709)722-8730

To discuss this sample report, contact Customer Service at 1-800-268-2131.
Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
Validity of results and interpretation are based on the sample and information as supplied.