




# PROBLEM SUMMARY

Sample Rating Trend




ISO




Area  
**COR**  
 Machine Id  
**LONGTUR1RUNHUB**  
 Component  
**Turbine**  
 Fluid  
**SHELL TURBO T ISO 68 (200 LTR)**

## COMPONENT CONDITION SUMMARY

Particle Trend



Non-ferrous Metals



## RECOMMENDATION

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

## PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	SEVERE	SEVERE	
Lead	ppm	ASTM D5185(m)	>3	▲ 4	3	▲ 6
Particles >4µm		ASTM D7647	>2500	● 41148	28503	● 26689
Particles >6µm		ASTM D7647	>640	● 9501	5574	● 6392
Particles >14µm		ASTM D7647	>80	▲ 403	257	▲ 350
Particles >21µm		ASTM D7647	>20	▲ 89	67	▲ 77
Oil Cleanliness		ISO 4406 (c)	>18/16/13	● 23/20/16	22/20/15	● 22/20/16

Customer Id: ALGMIS  
 Sample No.: WC0790717  
 Lab Number: 02605898  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
 Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

**RECOMMENDED ACTIONS**

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Dirt Access	---	---	?	We advise that you check all areas where contaminants can enter the system.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

**HISTORICAL DIAGNOSIS**

**14 Nov 2023 Diag: Kevin Marson**

ISO



We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. All component wear rates are normal. There is a high amount of particulates (2 to 100 microns in size) present in the oil. The water content is negligible. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



**27 Aug 2016 Diag: Kevin Marson**

ISO



We advise that you check all areas where contaminants can enter the system. The oil change at the time of sampling has been noted. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. Lead ppm levels are abnormal. Particles >6µm are severely high. Particles >4µm are severely high. Oil Cleanliness is severe. Particles >14µm are abnormally high. Particles >21µm are abnormally high. The water content is negligible. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



**30 Sep 2010 Diag: Kevin Marson**

WATER



We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. The iron level is abnormal. There is a high concentration of water present in the oil. There is a high amount of particulates (5 to >100 microns in size) present in the oil. A light concentration of dirt & debris was filtered from the sample. The oil viscosity is lower than normal.


view report





# OIL ANALYSIS REPORT

## Sample Rating Trend



ISO



Area  
**COR**  
Machine Id  
**LONGTUR1RUNHUB**  
Component  
**Turbine**  
Fluid  
**SHELL TURBO T ISO 68 (200 LTR)**

### DIAGNOSIS

#### Recommendation

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

#### Wear

Lead ppm levels are abnormal.

#### Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the oil. The water content is negligible.

#### Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0790717</b>	WC0790716	WC965004
Sample Date	Client Info		<b>17 Nov 2023</b>	14 Nov 2023	27 Aug 2016
Machine Age	mths	Client Info	<b>311</b>	311	223
Oil Age	mths	Client Info	<b>128</b>	128	39
Oil Changed	Client Info		<b>Not Chngd</b>	Not Chngd	Changed
Sample Status			<b>SEVERE</b>	SEVERE	SEVERE

### WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m) >10	<1	<1	3
Chromium	ppm	ASTM D5185(m) >3	0	0	0
Nickel	ppm	ASTM D5185(m) >3	<1	<1	0
Titanium	ppm	ASTM D5185(m)	0	0	0
Silver	ppm	ASTM D5185(m)	0	0	0
Aluminum	ppm	ASTM D5185(m) >3	<1	<1	<1
Lead	ppm	ASTM D5185(m) >3	▲ 4	3	▲ 6
Copper	ppm	ASTM D5185(m) >4	3	2	<1
Tin	ppm	ASTM D5185(m) >3	0	0	0
Antimony	ppm	ASTM D5185(m)	0	0	0
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0

### ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	0	<1
Barium	ppm	ASTM D5185(m)	0	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0
Manganese	ppm	ASTM D5185(m)	0	0	<1
Magnesium	ppm	ASTM D5185(m)	0	<1	0
Calcium	ppm	ASTM D5185(m)	1	1	<1
Phosphorus	ppm	ASTM D5185(m)	5	2	1
Zinc	ppm	ASTM D5185(m)	3	1	2
Sulfur	ppm	ASTM D5185(m)	62	57	113
Lithium	ppm	ASTM D5185(m)	<1	<1	<1

### CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >10	0	0	<1
Sodium	ppm	ASTM D5185(m)	4	4	5
Potassium	ppm	ASTM D5185(m) >20	3	2	0
Water	%	ASTM D6304* >0.03	0.00	0.00	0.00
ppm Water	ppm	ASTM D6304* >300	0	0	0.00

### FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	● 41148	● 28503	● 26689
Particles >6µm	ASTM D7647	>640	● 9501	● 5574	● 6392
Particles >14µm	ASTM D7647	>80	▲ 403	▲ 257	▲ 350
Particles >21µm	ASTM D7647	>20	▲ 89	▲ 67	▲ 77
Particles >38µm	ASTM D7647	>4	6	▲ 8	3
Particles >71µm	ASTM D7647	>3	1	2	0
Oil Cleanliness	ISO 4406 (c)	>18/16/13	● 23/20/16	● 22/20/15	● 22/20/16









# OIL ANALYSIS REPORT



FLUID DEGRADATION	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974*	.05	<b>0.04</b>	0.04	0.064

VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	Visual*	>0.03	<b>NEG</b>	NEG	NEG
Free Water	scalar	Visual*		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	68	<b>66.3</b>	67.3	66.8

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					
PrtFilter			no image	no image	no image



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **ALGONQUIN POWER SYSTEMS INC.**  
**Sample No.** : WC0790717 **Recieved** : 02 Jan 2024 354 DAVIS ROAD  
**Lab Number** : **02605898** **Diagnosed** : 03 Jan 2024 OAKVILLE, ON  
**Unique Number** : 5706984 **Diagnostician** : Kevin Marson CA L6J 2X1  
**Test Package** : IND 2

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

Contact: Antonino Champ Fernando  
 antoninoChamp.fernando@algonquinpower.com  
 T: (905)465-7065  
 F: x: