

OIL ANALYSIS REPORT

Sample Rating Trend







Machine Id **Z-3300 F-3305** Component Hydraulic System Fluid IRVING HYDRAULIC OIL LP 32 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.

Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PP		
Sample Date		Client Info		14 Dec 2023		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.05	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>20	0		
Chromium	ppm	ASTM D5185(m)	>10	0		
Nickel	ppm	ASTM D5185(m)	>10	<1		
Titanium	ppm	ASTM D5185(m)		0		
Silver	ppm	ASTM D5185(m)		0		
Aluminum	ppm	ASTM D5185(m)	>10	<1		
Lead	ppm	ASTM D5185(m)	>20	0		
Copper	ppm	ASTM D5185(m)	>20	<1		
Tin	ppm	ASTM D5185(m)	>10	0		
Antimony	ppm	ASTM D5185(m)		0		
Vanadium	ppm	ASTM D5185(m)		0		
Beryllium	ppm	ASTM D5185(m)		0		
Cadmium	ppm	ASTM D5185(m)		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		0		
Barium	ppm	ASTM D5185(m)		0		
Molybdenum	ppm	ASTM D5185(m)		0		
Manganese	ppm	ASTM D5185(m)		0		
Magnesium	ppm	ASTM D5185(m)		<1		
Calcium	ppm	ASTM D5185(m)		53		
Phosphorus	ppm	ASTM D5185(m)		335		
Zinc	ppm	ASTM D5185(m)	400	416		
Sulfur	ppm	ASTM D5185(m)		1126		
Lithium	ppm	ASTM D5185(m)		<1		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>15	0		
Sodium	ppm	ASTM D5185(m)		0		
Potassium	ppm	ASTM D5185(m)	>20	3		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	3052		
Particles >6µm		ASTM D7647	>1300	1001		
Particles >14µm		ASTM D7647	>160	92		
Particles >21µm		ASTM D7647	>40	18		
Particles >38µm		ASTM D7647	>10	1		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>19/17/14	19/17/14		
:52:48) Rev: 1				Contac	t/Location: Sam	Nash - HIBSTJ



OIL ANALYSIS REPORT







	FLUID DEGRADA	TION	method	limit/base	current	history1	history2
	Acid Number (AN)	mg KOH/g	ASTM D974*		0.48		
	VISUAL		method	limit/base	current	history1	history2
	White Metal	scalar	Visual*	NONE	NONE		
	Yellow Metal	scalar	Visual*	NONE	NONE		
	Precipitate	scalar	Visual*	NONE	NONE		
	Silt	scalar	Visual*	NONE	NONE		
Dec14/23	Debris	scalar	Visual*	NONE	NONE		
	Sand/Dirt	scalar	Visual*	NONE	NONE		
	Appearance	scalar	Visual*	NORML	NORML		
	Odor	scalar	Visual*	NORML	NORML		
	Emulsified Water Free Water	scalar scalar	Visual* Visual*	>0.05	NEG NEG		
	FLUID PROPERT	IES	method	limit/base	current	history1	history2
	Visc @ 40°C	cSt	ASTM D7279(m)	31.9	30.2		
Dec14/23 -	SAMPLE IMAGES	6	method	limit/base	current	history1	history2
Dec	Color					no image	no image
	Bottom					no image	no image
	GRAPHS						
£.4	Ferrous Alloys			491,520	Particle Count		T 26
	iron						
	툴. 5- mickel			122,880	Severe		-24
				30,720			-22
	23 L			€ ^{7,680}	Abnormal		-20 8
	Dec14/23			Dec14/23 Dec14/23 1,020 120 120 120 120 120		•	-20 (100 4406:1999) Cleanliness Co -18 6 (1999) Cleanliness Co -14 9 (1997) -14 (1997) -14 (1997) -14 (1997)
	Non-ferrous Metal	s		Saporte 480	1		-16 0
				jo 120			14 eanline
	nananananan lead			admur 30			ess Co
	E 5-			= 30			-12 8
	0			8			-10
	Dec14/23			Dec14/23			-8
				ag 0.	и 6µ	14µ 21µ	38µ 71µ
	Viscosity @ 40°C				Acid Number	6. A	<i>.</i>
-	Ab			HOX 0.60			
	Co 35 - Abnormal Base 30 - Abnormal			ළි 0.40 ක			
ć	3 30 - Abnormal			(b) 0.60 HOX but) but)			
	25			-00.0 gei			
	Dec14/23			Dec14/23	Dec14/23		Dec14/25
Laboratory Sample No. Lab Number Unique Number Test Package	: 02605934	Recieved Diagnos Diagnost	ed : 02 . ed : 03 . ician : We	Jan 2024 Jan 2024 s Davis	SUITE 10	000,, 100 NEW G	OWER STREET ST.JOHNS, NL CA A1C 6K3 tact: Sam Nash

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

T: F: (709)722-3766

CALA

ISO 17025:2017 Accredited Laboratory