



OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Area

M11

Machine Id


44-P-2530B-NDE WATER INJ. BOOSTER PUMP NON-DRIVE END

Component

Bearing

Fluid

MOBIL DTE OIL LIGHT (--- LTR)



DIAGNOSIS

Recommendation

Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

Sample Number	Client Info	method	limit/base	current	history1	history2
Sample Date	Client Info			01 Jan 2024	18 Sep 2023	23 Apr 2019
Machine Age	days	Client Info		0	0	0
Oil Age	days	Client Info		0	0	0
Oil Changed	Client Info			N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	ATTENTION

CONTAMINATION

Water	WC Method	limit/base	current	history1	history2
		>0.1	NEG	NEG	NEG

WEAR METALS

PQ	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m) >20	0	<1	6
Chromium	ppm	ASTM D5185(m) >2	0	0	0
Nickel	ppm	ASTM D5185(m) >2	<1	0	<1
Titanium	ppm	ASTM D5185(m)	0	0	0
Silver	ppm	ASTM D5185(m)	0	<1	0
Aluminum	ppm	ASTM D5185(m) >5	<1	<1	<1
Lead	ppm	ASTM D5185(m) >25	0	0	0
Copper	ppm	ASTM D5185(m) >5	<1	1	<1
Tin	ppm	ASTM D5185(m) >15	0	0	0
Antimony	ppm	ASTM D5185(m)	0	0	0
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	<1

ADDITIVES

Boron	ppm	method	limit/base	current	history1	history2
Barium	ppm	ASTM D5185(m)		0	<1	0
Molybdenum	ppm	ASTM D5185(m)		0	0	0
Manganese	ppm	ASTM D5185(m)		0	0	<1
Magnesium	ppm	ASTM D5185(m)		0	0	3
Calcium	ppm	ASTM D5185(m)		<1	<1	1
Phosphorus	ppm	ASTM D5185(m)		1160	1176	▲ 1045
Zinc	ppm	ASTM D5185(m)		2	7	▲ 6
Sulfur	ppm	ASTM D5185(m)		4	22	▲ 91
Lithium	ppm	ASTM D5185(m)		<1	<1	0

CONTAMINANTS





Silicon	ppm	method	limit/base	current	history1	history2
Sodium	ppm	ASTM D5185(m)		0	<1	1
Potassium	ppm	ASTM D5185(m)	>20	2	0	0

FLUID DEGRADATION

Acid Number (AN)	mg KOH/g	method	limit/base	current	history1	history2
		ASTM D974*		0.47	---	---




OIL ANALYSIS REPORT








PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.1	NEG	.2%
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	31	31.2	31.1

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 HUSKY SEA ROSE /AKER SOLUTIONS
Sample No. : PP **Received** : 02 Jan 2024
Lab Number : 02605958 **Diagnosed** : 03 Jan 2024
Unique Number : 5707044 **Diagnostician** : Kevin Marson
Test Package : IND 2 (Additional Tests: TAN Man)
 To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

PO BOX 20
 ST. JOHN'S, NL
 CA A1C 6C9
 Contact: Nick Fewer
 nick.fewer@akersolutions.com
 T: (709)757-4582
 F: (709)722-8730