

FUEL REPORT

Sample Rating Trend

OFF SPEC

Area
[R1-23486]
 Machine Id
JOHN DEERE PE4045D963656

Component
Diesel Fuel
 Fluid
No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)



DIAGNOSIS

Recommendation
 We advise that you filter this fluid before use. We recommend an early resample to monitor this condition.

Corrosion
 {not applicable}

Contaminants
 There is a moderate amount of particulates (2 to 100 microns in size) present in the fuel. The water content is negligible.

Fuel Condition
 10% Distill Point results are abnormally high. 20% Distill Point results are abnormally high. 50% Distill Point results are abnormally high. Final Boiling Point results are abnormally high. Laboratory tests indicate that this sample does NOT meet specifications for No.2 ultra-low-sulfur diesel fuel (US EPA/CGSB-3.517-3 type B).

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			VPA055845	---	---
Sample Date	Client Info			13 Dec 2023	---	---
Machine Age	hrs	Client Info		0	---	---
Sample Status				ABNORMAL	---	---

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
Specific Gravity		ASTM D1298*	0.839	0.823	---	---
Fuel Color	text	Visual Screen*	Yellow	Red	---	---
Visc @ 40°C	cSt	ASTM D7279(m)	3.0	3.1	---	---
Pensky-Martens Flash Point	°C	ASTM D7215*	52	70.6	---	---

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185(m)	10	7	---	---






DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D2887*	165	182	---	---
5% Distillation Point	°C	ASTM D2887*		213	---	---
10% Distill Point	°C	ASTM D2887*	201	227	---	---
15% Distillation Point	°C	ASTM D2887*		238	---	---
20% Distill Point	°C	ASTM D2887*	216	249	---	---
30% Distill Point	°C	ASTM D2887*	230	266	---	---
40% Distill Point	°C	ASTM D2887*	243	277	---	---
50% Distill Point	°C	ASTM D2887*	255	288	---	---
60% Distill Point	°C	ASTM D2887*	267	294	---	---
70% Distill Point	°C	ASTM D2887*	280	300	---	---
80% Distill Point	°C	ASTM D2887*	295	310	---	---
85% Distillation Point	°C	ASTM D2887*		320	---	---
90% Distill Point	°C	ASTM D2887*	310	330	---	---
95% Distillation Point	°C	ASTM D2887*		346	---	---
Final Boiling Point	°C	ASTM D2887*	341	380	---	---

IGNITION QUALITY		method	limit/base	current	history1	history2
API Gravity		ASTM D1298*	37.7	40	---	---
Cetane Index		ASTM D4737*	<40.0	63	---	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	<1.0	0	---	---
Sodium	ppm	ASTM D5185(m)	<0.1	<1	---	---
Potassium	ppm	ASTM D5185(m)	<0.1	0	---	---
Water	%	ASTM D6304*	<0.05	0.003	---	---
ppm Water	ppm	ASTM D6304*	<500	35	---	---

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	4736	---	---
Particles >6µm		ASTM D7647	>640	1358	---	---
Particles >14µm		ASTM D7647	>80	174	---	---
Particles >21µm		ASTM D7647	>20	64	---	---
Particles >38µm		ASTM D7647	>4	5	---	---
Particles >71µm		ASTM D7647	>3	0	---	---
Oil Cleanliness		ISO 4406 (c)	>18/16/13	19/18/15	---	---




FUEL REPORT



HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185(m)	<0.1	0	---
Nickel	ppm	ASTM D5185(m)	<0.1	0	---
Lead	ppm	ASTM D5185(m)	<0.1	0	---
Vanadium	ppm	ASTM D5185(m)	<0.1	0	---
Iron	ppm	ASTM D5185(m)	<0.1	0	---
Calcium	ppm	ASTM D5185(m)	<0.1	<1	---
Magnesium	ppm	ASTM D5185(m)	<0.1	0	---
Phosphorus	ppm	ASTM D5185(m)	<0.1	0	---
Zinc	ppm	ASTM D5185(m)	<0.1	<1	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : VPA055845
Lab Number : 02606130
Unique Number : 5707216
Test Package : FUEL (Additional Tests: CC Flash, GC-PercFuel, PrtCount)
Received : 02 Jan 2024
Diagnosed : 16 Jan 2024
Diagnostician : Kevin Marson
 To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

CULLEN DIESEL POWER - 695335
 9300 192 ST
 SURREY, BC
 CA V4N 3R8
 Contact: Michelle Sayers
 mns@cullendiesel.com
 T: (604)888-1211
 F: