

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



KDT Ch#2 Comp 2 MCQUAY STNU12600083(2,2) Component Chiller

ANDEROL EVEREST 46 (--- GAL)

DIAGNOSIS	SAMPLE INFORM	MATION	method				history2
Recommendation	Sample Number		Client Info		GTT0001507		
Resample at the next service interval to monitor.	Sample Date		Client Info		20 Nov 2023		
Wear	Machine Age	hrs	Client Info		0		
All component wear rates are normal.	Oil Age	hrs	Client Info		0		
Contamination	Oil Changed		Client Info		N/A		
The water content is negligible. There is no	Sample Status				NORMAL		
indication of any contamination in the oil.	WEAR METALS		method	limit/base	current	history1	history2
Fluid Condition						TIIStOLA	TIIStOLYZ
The AN level is acceptable for this fluid. The	Iron	ppm	ASTM D5185(m)	>100	1		
condition of the oil is suitable for further service.	Chromium	ppm	ASTM D5185(m)	>2	0		
	Nickel	ppm	ASTM D5185(m)		0		
	Titanium	ppm	ASTM D5185(m)		0		
	Silver	ppm	ASTM D5185(m)		0		
	Aluminum	ppm	ASTM D5185(m)		<1		
	Lead	ppm	ASTM D5185(m)	>2	<1		
	Copper	ppm	ASTM D5185(m)		15		
	Tin	ppm	ASTM D5185(m)	>4	0		
	Antimony	ppm	ASTM D5185(m)		0		
	Vanadium	ppm	ASTM D5185(m)		0		
	Beryllium	ppm	ASTM D5185(m)		0		
	Cadmium	ppm	ASTM D5185(m)		0		
	ADDITIVES		method	limit/base	current	history1	history2
	Boron	ppm	ASTM D5185(m)		<1		
	Barium	ppm	ASTM D5185(m)		0		
	Molybdenum	ppm	ASTM D5185(m)		0		
	Manganese	ppm	ASTM D5185(m)		0		
	Magnesium	ppm	ASTM D5185(m)		0		
	Calcium	ppm	ASTM D5185(m)		<1		
	Phosphorus	ppm	ASTM D5185(m)		1380		
	Zinc	ppm	ASTM D5185(m)		11		
	Sulfur	ppm	ASTM D5185(m)		23		
	Lithium	ppm	ASTM D5185(m)		<1		
	CONTAMINANTS	5	method	limit/base	current	history1	history2
	Silicon	ppm	ASTM D5185(m)	>50	12		
	Sodium	ppm	ASTM D5185(m)		<1		
	Potassium	ppm	ASTM D5185(m)	>20	1		
	ppm Water	ppm	ASTM D6304*	>400	157		
	FLUID DEGRAD		method	limit/base		history1	history2
	Acid Number (AN)	mg KOH/g	ASTM D974*	0.05	0.04		



OIL ANALYSIS REPORT

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE		
Yellow Metal	scalar	Visual*	NONE	NONE		
Precipitate	scalar	Visual*	NONE	NONE		
Silt	scalar	Visual*	NONE	NONE		
Debris	scalar	Visual*	NONE	NONE		
Sand/Dirt	scalar	Visual*	NONE	NONE		
Appearance	scalar	Visual*	NORML	NORML		
Odor	scalar	Visual*	NORML	NORML		
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	46.2	44.4		
SAMPLE IMAGES	;	method	limit/base	current	history1	history2
Color					no image	no image
Bottom					no image	no image
GRAPHS						



 Sample No.
 : GTT0001507
 Recieved
 : 03 Jan 2024
 75 C

 Lab Number
 : 02606359
 Diagnosed
 : 09 Jan 2024
 75 C

 Unique Number
 : 5707445
 Diagnostician
 : Bill Quesnel
 75 C

 Test Package
 : IND 2 (Additional Tests: KV40)
 : Bill Quesnel
 75 C

 To discuss this sample report, contact Customer Service at 1-905-847-9300 Ext 26.
 75 C
 75 C

 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 75 C

 Damages: Seller shall in no event be liable for special, incidental, or consequential damages, of a commercial nature, resulting from any cause.

Black & McDonald - Scar 75 Commerce Valley Drive East Markham, ON CA L3T 7N9 Contact: Service Manager

Contact/Location: Service Manager - GTT0000033

T:

F: