


OIL ANALYSIS REPORT

KDT Krembil Ch#1 Comp 1 [411831130P] Machine Id MCQUAY STNU120600110(1,1) Component Chiller



ANDEROL EVEREST 46 (--- GAL)

DIAGNOSIS

Recommendation

We recommend an early resample to monitor this condition. No other corrective action is recommended at this time.

Wear

Iron ppm levels are noted. The increased iron reading indicates possible moderate oil pump wear. All other component wear rates are normal.

Contamination

The water content is negligible. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	1ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		GTT0001506	GTT75248	GTT75249
Sample Date		Client Info		20 Nov 2023	21 Mar 2023	12 Jan 2022
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ATTENTION	ATTENTION	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>100	1 3	5	<u> </u>
Chromium	ppm	ASTM D5185(m)	>2	0	<1	<1
Nickel	ppm	ASTM D5185(m)		<1		
Titanium	ppm	ASTM D5185(m)		0		
Silver	ppm	ASTM D5185(m)	>2	0		
Aluminum	ppm	ASTM D5185(m)	>50	<1	<1	<1
Lead	ppm	ASTM D5185(m)	>2	1	<1	<1
Copper	ppm	ASTM D5185(m)	>100	4	2	4
Tin	ppm	ASTM D5185(m)	>4	<1	<1	<1
Antimony	ppm	ASTM D5185(m)		0		
Vanadium	ppm	ASTM D5185(m)		0		
Beryllium	ppm	ASTM D5185(m)		0		
Cadmium	ppm	ASTM D5185(m)		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		<1		
Barium	ppm	ASTM D5185(m)		0		
Molybdenum	ppm	ASTM D5185(m)		0		
Manganese	ppm	ASTM D5185(m)		0		
Magnesium	ppm	ASTM D5185(m)		0		
Calcium	ppm	ASTM D5185(m)		<1		
Phosphorus	ppm	ASTM D5185(m)		8		
Zinc	ppm	ASTM D5185(m)		11	4	6
Sulfur	ppm	ASTM D5185(m)		25		
Lithium	ppm	ASTM D5185(m)		<1		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>50	20		
Sodium	ppm	ASTM D5185(m)		1		
Potassium	ppm	ASTM D5185(m)	>20	4		
ppm Water	ppm	ASTM D6304*	>400	182	4 98	298
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.05	0.08	0.068	0.047



OIL ANALYSIS REPORT

VISUAL		method	limit/base	current	history1	history2		
White Metal	scalar	Visual*	NONE	NONE				
Yellow Metal	scalar	Visual*	NONE	NONE				
Precipitate	scalar	Visual*	NONE	NONE				
Silt	scalar	Visual*	NONE	NONE				
Debris	scalar	Visual*	NONE	NONE				
Sand/Dirt	scalar	Visual*	NONE	NONE				
Appearance	scalar	Visual*	NORML	NORML				
Odor	scalar	Visual*	NORML	NORML				
FLUID PROPERTIES		method	limit/base	current	history1	history2		
Visc @ 40°C	cSt	ASTM D7279(m)	46.2	33.0				
SAMPLE IMAGES		method	limit/base	current	history1	history2		
Color					no image	no image		
Bottom					no image	no image		
GRAPHS								



 Sample No.
 : GTT0001506
 Recieved
 : 03 Jan 2024
 75 C

 Lab Number
 : 02606360
 Diagnosed
 : 09 Jan 2024
 75 C

 Unique Number
 : 5707446
 Diagnostician
 : Bill Quesnel
 75 C

 Test Package
 : IND 2 (Additional Tests: KV40)
 : Bill Quesnel
 75 C

 To discuss this sample report, contact Customer Service at 1-905-847-9300 Ext 26.
 75 C
 75 C

 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 75 C

 Damages: Seller shall in no event be liable for special, incidental, or consequential damages, of a commercial nature, resulting from any cause.

Black & McDonald - Scar 75 Commerce Valley Drive East Markham, ON CA L3T 7N9 Contact: Service Manager

Report Id: GTT0000033 [WCAMIS] 02606360 (Generated: 01/09/2024 16:42:11) Rev: 1

Contact/Location: Service Manager - GTT0000033

T:

F: