




# PROBLEM SUMMARY


Area  
**54 LIME KILN**  
 Machine Id  
**542508 - Kiln ID Fan DE - Inboard Bearing**  
 Component  
**Inboard Bearing**  
 Fluid  
**ESSO NUTO H ISO 68 (--- GAL)**

Sample Rating Trend




## COMPONENT CONDITION SUMMARY

Particle Trend



Aluminum (ppm)



## RECOMMENDATION

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

## PROBLEMATIC TEST RESULTS

Sample Status	ASTM D7647	SEVERE	SEVERE	SEVERE
Particles >4µm	>640	258867	153175	329496
Particles >6µm	>160	139272	85831	221086
Particles >14µm	>20	2211	1776	8410
Particles >21µm	>4	112	181	499
Oil Cleanliness	ISO 4406 (c) >16/14/11	25/24/18	24/24/18	26/25/20

Customer Id: STANAC  
 Sample No.: WC  
 Lab Number: 02607521  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
 Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Information Required	---	---	?	NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Dirt Access	---	---	?	We advise that you check all areas where contaminants can enter the system.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

HISTORICAL DIAGNOSIS

ISO



05 Jul 2023 Diag: Kevin Marson

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Aluminum ppm levels are noted. All other component wear rates are normal. There is a high amount of particulates (2 to 100 microns in size) present in the oil. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



WEAR



28 Dec 2022 Diag: Kevin Marson

We advise that you check all areas where contaminants can enter the system. We recommend either performing an oil change or oil filtration. We cannot recommend specific action as we have limited information with regards to reservoir capacity and/or lubricant type. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Aluminum ppm levels are severe. Iron ppm levels are abnormal. The low ferrous density (PQ) index indicates the wear metal levels are due to corrosion. Particles >14µm are severely high. Particles >21µm are severely high. Particles >6µm are severely high. Particles >4µm are severely high. Oil Cleanliness are severely high. Silicon ppm levels are abnormally high. Elemental level of silicon (Si) above normal indicating ingress of seal material. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

view report



ISO



22 Aug 2018 Diag: Kevin Marson

Check seals and/or filters for points of contaminant entry. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Copper ppm levels are noted. All other component wear rates are normal. Particles >14µm are severely high. Particles >21µm are severely high. Particles >6µm are severely high. Particles >4µm are severely high. Silicon ppm levels are abnormally high. Elemental level of silicon (Si) above normal indicating ingress of seal material. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area  
**54 LIME KILN**  
 Machine Id  
**542508 - Kiln ID Fan DE - Inboard Bearing**  
 Component  
**Inboard Bearing**  
 Fluid  
**ESSO NUTO H ISO 68 (--- GAL)**

## DIAGNOSIS

### Recommendation

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

### Wear

Aluminum ppm levels are noted. All other component wear rates are normal.

### Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the oil. The water content is negligible. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code.

### Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC	WC	WC
Sample Date	Client Info	<b>03 Jan 2024</b>	05 Jul 2023	28 Dec 2022
Machine Age	days	0	0	0
Oil Age	days	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		<b>SEVERE</b>	SEVERE	SEVERE

## WEAR METALS

method	limit/base	current	history1	history2
PQ	ASTM D8184*	<b>24</b>	17	51
Iron	ppm ASTM D5185(m) >84	<b>64</b>	44	▲ 99
Chromium	ppm ASTM D5185(m) >20	<b>0</b>	0	0
Nickel	ppm ASTM D5185(m) >3	<b>0</b>	0	<1
Titanium	ppm ASTM D5185(m)	<b>0</b>	0	<1
Silver	ppm ASTM D5185(m)	<b>0</b>	<1	0
Aluminum	ppm ASTM D5185(m) >3	▲ <b>4</b>	▲ 4	● 11
Lead	ppm ASTM D5185(m) >143	< <b>1</b>	<1	<1
Copper	ppm ASTM D5185(m) >13	<b>4</b>	6	21
Tin	ppm ASTM D5185(m) >41	<b>10</b>	10	30
Antimony	ppm ASTM D5185(m)	< <b>1</b>	<1	3
Vanadium	ppm ASTM D5185(m)	<b>0</b>	0	0
Beryllium	ppm ASTM D5185(m)	<b>0</b>	0	0
Cadmium	ppm ASTM D5185(m)	<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185(m) 0	<b>0</b>	<1	2
Barium	ppm ASTM D5185(m) 0	<b>0</b>	0	0
Molybdenum	ppm ASTM D5185(m) 0	<b>0</b>	0	0
Manganese	ppm ASTM D5185(m)	<b>0</b>	<1	1
Magnesium	ppm ASTM D5185(m) 5	< <b>1</b>	<1	<1
Calcium	ppm ASTM D5185(m) 50	<b>79</b>	55	86
Phosphorus	ppm ASTM D5185(m) 330	<b>314</b>	372	367
Zinc	ppm ASTM D5185(m) 420	<b>399</b>	439	398
Sulfur	ppm ASTM D5185(m) 3100	<b>7154</b>	5997	7405
Lithium	ppm ASTM D5185(m)	< <b>1</b>	<1	<1

## CONTAMINANTS






method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185(m) >15	<b>7</b>	9	▲ 36
Sodium	ppm ASTM D5185(m)	<b>2</b>	<1	3
Potassium	ppm ASTM D5185(m) >20	< <b>1</b>	<1	0
Water	% ASTM D6304* >2	<b>0.014</b>	---	---
ppm Water	ppm ASTM D6304*	<b>141</b>	---	---

## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >640	● <b>258867</b>	● 153175	● 329496
Particles >6µm	ASTM D7647 >160	● <b>139272</b>	● 85831	● 221086
Particles >14µm	ASTM D7647 >20	● <b>2211</b>	● 1776	● 8410
Particles >21µm	ASTM D7647 >4	● <b>112</b>	● 181	● 499
Particles >38µm	ASTM D7647 >3	<b>1</b>	1	5
Particles >71µm	ASTM D7647 >3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c) >16/14/11	● <b>25/24/18</b>	● 24/24/18	● 26/25/20



# OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	.40	<b>0.46</b>	0.51	0.59






VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	NONE	<b>VLITE</b>	NONE	NONE
Silt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	Visual*	NONE	<b>VLITE</b>	VLITE	NONE
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	NONE	VLITE
Appearance	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	Visual*	>2	<b>.2%</b>	NEG	NEG
Free Water	scalar	Visual*		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	68.8	<b>64.6</b>	65.4	68.5

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC  
**Lab Number** : 02607521  
**Unique Number** : 5708607  
**Test Package** : IND 2 ( Additional Tests: KF, PQ, PrtCount )

**AV GROUP NB INC.**  
 103 PINDER ROAD,, NACKAWIC MILL  
 NACKAWIC, NB  
 CA E6G 1W4  
 Contact: Basil Fadulalla  
 basil.fadulalla@adityabirla.com

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.