




# OIL ANALYSIS REPORT

Sample Rating Trend

**NORMAL**



Machine Id  
**TURRET A**

Component  
**Gearbox**

Fluid  
**{not provided} (--- GAL)**

## DIAGNOSIS

### Recommendation

Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please specify the brand, type, and viscosity of the oil on your next sample.

### Wear

All component wear rates are normal.

### Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>WC0782486</b>	WC	WC0782507
Sample Date	Client Info			<b>07 Nov 2023</b>	04 Oct 2023	15 Aug 2023
Machine Age	hrs	Client Info		<b>0</b>	0	0
Oil Age	hrs	Client Info		<b>0</b>	0	0
Oil Changed	Client Info			<b>N/A</b>	N/A	N/A
Sample Status				<b>NORMAL</b>	NORMAL	NORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Water	WC Method		>0.2	<b>NEG</b>	NEG	NEG






WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184*	>DFLT	<b>25</b>	24	18
Iron	ppm	ASTM D5185(m)	>200	<b>126</b>	116	109
Chromium	ppm	ASTM D5185(m)	>15	<b>&lt;1</b>	<1	<1
Nickel	ppm	ASTM D5185(m)	>15	<b>&lt;1</b>	<1	<1
Titanium	ppm	ASTM D5185(m)		<b>0</b>	0	<1
Silver	ppm	ASTM D5185(m)		<b>0</b>	<1	0
Aluminum	ppm	ASTM D5185(m)	>25	<b>1</b>	<1	<1
Lead	ppm	ASTM D5185(m)	>100	<b>2</b>	1	1
Copper	ppm	ASTM D5185(m)	>200	<b>4</b>	4	4
Tin	ppm	ASTM D5185(m)	>25	<b>0</b>	0	0
Antimony	ppm	ASTM D5185(m)	>5	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		<b>&lt;1</b>	2	1
Barium	ppm	ASTM D5185(m)		<b>&lt;1</b>	1	<1
Molybdenum	ppm	ASTM D5185(m)		<b>0</b>	0	0
Manganese	ppm	ASTM D5185(m)		<b>1</b>	1	1
Magnesium	ppm	ASTM D5185(m)		<b>2</b>	6	1
Calcium	ppm	ASTM D5185(m)		<b>7</b>	19	6
Phosphorus	ppm	ASTM D5185(m)		<b>263</b>	271	286
Zinc	ppm	ASTM D5185(m)		<b>5</b>	7	6
Sulfur	ppm	ASTM D5185(m)		<b>10035</b>	10414	9969
Lithium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	<1

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>50	<b>8</b>	9	8
Sodium	ppm	ASTM D5185(m)		<b>&lt;1</b>	2	<1
Potassium	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	<1	<1



# OIL ANALYSIS REPORT



FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		<b>146988</b>	---	---
Particles >6µm	ASTM D7647	>10240000	<b>69916</b>	---	---
Particles >14µm	ASTM D7647	>10240000	<b>1682</b>	---	---
Particles >21µm	ASTM D7647	>2560000	<b>319</b>	---	---
Particles >38µm	ASTM D7647	>640000	<b>42</b>	---	---
Particles >71µm	ASTM D7647	>160000	<b>14</b>	---	---
Oil Cleanliness	ISO 4406 (c)	>--/30/30	<b>24/23/18</b>	---	---

FLUID DEGRADATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	<b>0.42</b>	0.55	0.45

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	VLITE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	VLITE	LIGHT
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	VLITE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	<b>231</b>	231	230

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color



Bottom



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **STELCO - BOSC - Basic Oxygen Slab Caster**  
 Sample No. : WC0782486 **Received** : 09 Jan 2024 2330 Regional Road #3, Door: BOSC8  
 Lab Number : **02607591** **Diagnosed** : 11 Jan 2024 NANTICOKE, ON  
 Unique Number : 5708677 **Diagnostician** : Wes Davis CA N0A 1L0  
 Test Package : IND 2 ( Additional Tests: PQ, PrtCount ) Contact: Kevin Beeton

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

Kevin.Beeton@stelco.com  
 T:  
 F: (519)587-7702