




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area
DEMO/53 RECAUSTICIZING
 Machine Id
532857 #2 LIME MUD STOR AGIT (S/N 465467)
 Component
Drive Reducer
 Fluid
MOBIL SHC 629 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.
 NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please specify the component make and model with your next sample.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC	WC	WC
Sample Date	Client Info	03 Jan 2024	05 Jul 2023	28 Dec 2022
Machine Age	mls	Client Info	0	0
Oil Age	mls	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		NORMAL	ABNORMAL	NORMAL

CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method >0.2	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2
PQ	ASTM D8184*	0	53	0
Iron	ppm	ASTM D5185(m) >200	4	66
Chromium	ppm	ASTM D5185(m) >10	0	1
Nickel	ppm	ASTM D5185(m) >10	0	<1
Titanium	ppm	ASTM D5185(m)	0	0
Silver	ppm	ASTM D5185(m)	0	0
Aluminum	ppm	ASTM D5185(m)	<1	<1
Lead	ppm	ASTM D5185(m)	0	1
Copper	ppm	ASTM D5185(m)	<1	2
Tin	ppm	ASTM D5185(m)	0	0
Antimony	ppm	ASTM D5185(m) >5	0	2
Vanadium	ppm	ASTM D5185(m)	0	0
Beryllium	ppm	ASTM D5185(m)	0	0
Cadmium	ppm	ASTM D5185(m)	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	<1	<1
Barium	ppm	ASTM D5185(m)	<1	12
Molybdenum	ppm	ASTM D5185(m)	0	<1
Manganese	ppm	ASTM D5185(m)	0	2
Magnesium	ppm	ASTM D5185(m)	<1	<1
Calcium	ppm	ASTM D5185(m)	<1	15
Phosphorus	ppm	ASTM D5185(m)	443	579
Zinc	ppm	ASTM D5185(m)	3	24
Sulfur	ppm	ASTM D5185(m)	156	99
Lithium	ppm	ASTM D5185(m)	2	53

CONTAMINANTS




method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	22	27
Sodium	ppm	ASTM D5185(m)	<1	27
Potassium	ppm	ASTM D5185(m) >20	<1	<1

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.60	1.02




OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	LIGHT
Appearance	scalar	Visual*	NORML	▲ WGOIL	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	142.8	149	▲ 451

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC
Lab Number : 02607605
Unique Number : 5708691
Test Package : IND 2 (Additional Tests: TAN Man)
Received : 09 Jan 2024
Diagnosed : 10 Jan 2024
Diagnostician : Wes Davis

AV GROUP NB INC.
 103 PINDER ROAD,, NACKAWIC MILL
 NACKAWIC, NB
 CA E6G 1W4
 Contact: Alan Vanwagener
 alan.vanwagener@adityabirla.com
 T:
 F:

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.