

FUEL REPORT


CHELL

[99923] Machine Id PENTHOUSE

Component

Auxiliary Diesel Fuel

No.2 DIESEL FUEL (LOW-SULPHUR) (--- GAL)





DIAGNOSIS

Recommendation

We advise that you filter this fluid before use. We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

Corrosion

Lead ppm levels are abnormal. The high metal levels indicate corrosion in the system.

Contaminants

There is a moderate amount of silt (particulates < 14 microns in size) present in the fuel. The water content is negligible.


Fuel Condition

All laboratory tests indicate that this sample meets specifications for No.2 diesel fuel, low sulfur (US EPA/CGSB-3.517-3 type B). The fuel is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

AL)				Dec2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		CU0019836		
Sample Date		Client Info		16 Dec 2023		
Machine Age	hrs	Client Info		170		
Sample Status				ABNORMAL		
PHYSICAL PROP	FRTIES	method	limit/base	current	history1	history2
Specific Gravity		ASTM D1298*	0.839	0.826		
Fuel Color	text	Visual Screen*	Yllow	DkGry		
Visc @ 40°C	cSt	ASTM D7279(m)	3.0	2		
Pensky-Martens Flash Point		ASTM D7215*	52	54.9		
SULFUR CONTE		method	limit/base	current	history1	history2
Sulfur		ASTM D5185(m)	250	48		
	ppm	. ,				
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D2887*	165	164		
5% Distillation Point	°C	ASTM D2887*		184		
10% Distill Point	°C	ASTM D2887*	201	194		
15% Distillation Point	°C	ASTM D2887*		201		
20% Distill Point	°C	ASTM D2887*	216	208		
30% Distill Point	°C	ASTM D2887*	230	221		
40% Distill Point	°C	ASTM D2887*	243	233		
50% Distill Point	°C	ASTM D2887*	255	245		
60% Distill Point	°C	ASTM D2887*	267	259		
70% Distill Point	°C	ASTM D2887*	280	272		
80% Distill Point	°C	ASTM D2887*	295	288		
85% Distillation Point	°C	ASTM D2887*		299		
90% Distill Point	°C	ASTM D2887*	310	310		
95% Distillation Point		ASTM D2887*	0.44	330		
Final Boiling Point	°C	ASTM D2887*	341	361		
IGNITION QUALIT	ΓΥ	method	limit/base	current	history1	history2
API Gravity		ASTM D1298*	37.7	39		
Cetane Index		ASTM D4737*	<40.0	50		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	<1.0	0		
Sodium	ppm	ASTM D5185(m)	< 0.1	2		
Potassium	ppm	ASTM D5185(m)	<0.1	<1		
Water	%	ASTM D6304*	< 0.05	0.00		
ppm Water	ppm	ASTM D6304*	< 500	0		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	△ 6142		
Particles >6µm		ASTM D7647	>640	686		
Particles >14µm		ASTM D7647	>80	25		
Particles >21µm		ASTM D7647	>20	5		
Particles >38µm		ASTM D7647	>4	0		
Particles >71μm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>18/16/13	<u>^</u> 20/17/12		



FUEL REPORT





CALA ISO 17025:2017 Accredited

Laboratory

Laboratory Sample No. Lab Number Unique Number

: CU0019836

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 CUMMINS EASTERN CANADA LP

: 02607621 : 5708707

Recieved : 09 Jan 2024 Diagnosed : 16 Jan 2024

Diagnostician : Kevin Marson Test Package : FUEL (Additional Tests: CC Flash, GC-PercFuel, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

F: (450)638-6731

Contact: Service Manager

315 AV LIBERTE

CANDIAC, QC

CA J5R 6Z7

T: