




PROBLEM SUMMARY


Area
PUMPHOUSE/HOOD COOLING PUMPS
 Machine Id
C - Hood Cooling 2 Electric Pump IB
 Component
Lube System
 Fluid
PETRO CANADA HYDREX AW 100 (1 GAL)

Sample Rating Trend



COMPONENT CONDITION SUMMARY

Particle Trend



RECOMMENDATION

Check seals and/or filters for points of contaminant entry. We advise that you check all areas where contaminants can enter the system. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you follow the water drain-off procedure for this component. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample in 30-45 days to monitor this situation.

PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	SEVERE	SEVERE
Particles >4µm	ASTM D7647	>5000	🔴 239928	🔴 95253	🔴 184671
Particles >6µm	ASTM D7647	>1300	🔴 206511	🔴 23382	🔴 46919
Particles >14µm	ASTM D7647	>160	🔴 86020	🔴 1655	🔴 2055
Particles >21µm	ASTM D7647	>40	🔴 32309	🔴 427	🔴 342
Particles >38µm	ASTM D7647	>10	🔴 1757	11	3
Particles >71µm	ASTM D7647	>3	🔴 47	1	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	🔴 25/25/24	🔴 24/22/18	🔴 25/23/18
Appearance	scalar Visual*	NORML	🟡 HAZY	NORML	NORML
Free Water	scalar Visual*		🟡 1%	NEG	NEG

Customer Id: LEWBOSC
 Sample No.: WC0898658
 Lab Number: 02608049
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Water Drain-off	---	---	?	We advise that you follow the water drain-off procedure for this component.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Dirt Access	---	---	?	We advise that you check all areas where contaminants can enter the system.
Check Seals	---	---	?	Check seals and/or filters for points of contaminant entry.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

HISTORICAL DIAGNOSIS

16 Aug 2023 Diag: Kevin Marson

ISO



We advise that you check all areas where contaminants can enter the system. We advise that you check for visible metal particles in the oil. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. We suspect that the abnormal contaminant(s) is the result of incorrect sampling technique. **DISCLAIMER:** Interpretation of results is based on the sample as received from the customer. The condition of the sample and the method of sampling cannot be verified. Light concentration of visible metal present. There is a high amount of particulates (2 to 100 microns in size) present in the oil. Light concentration of visible dirt/debris present in the oil. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

view report



31 May 2023 Diag: Bill Quesnel

ISO



We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. All component wear rates are normal. There is a high amount of particulates (2 to 100 microns in size) present in the oil. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



27 Jan 2023 Diag: Kevin Marson

ISO



Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Particles >6µm are severely high. Particles >4µm are severely high. Oil Cleanliness are severely high. Particles >14µm are abnormally high. Particles >21µm are notably high. The water content is negligible. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. Viscosity of sample indicates oil is within ISO 150 range, advise investigate. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
PUMPHOUSE/HOOD COOLING PUMPS
 Machine Id
C - Hood Cooling 2 Electric Pump IB

Component
Lube System
 Fluid

PETRO CANADA HYDREX AW 100 (1 GAL)

DIAGNOSIS

Recommendation

Check seals and/or filters for points of contaminant entry. We advise that you check all areas where contaminants can enter the system. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you follow the water drain-off procedure for this component. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample in 30-45 days to monitor this situation.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the oil. There is a moderate concentration of water present in the oil. Free water present. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0898658	WC0850127	WC0824413
Sample Date	Client Info	10 Jan 2024	16 Aug 2023	31 May 2023
Machine Age	hrs	0	0	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		SEVERE	SEVERE	SEVERE

WEAR METALS

method	limit/base	current	history1	history2
PQ	ASTM D8184* >DFLT	0	0	0
Iron	ppm ASTM D5185(m) >20	14	19	25
Chromium	ppm ASTM D5185(m) >20	0	<1	0
Nickel	ppm ASTM D5185(m) >20	<1	<1	0
Titanium	ppm ASTM D5185(m)	0	0	0
Silver	ppm ASTM D5185(m)	0	0	0
Aluminum	ppm ASTM D5185(m) >20	<1	<1	<1
Lead	ppm ASTM D5185(m) >20	<1	0	<1
Copper	ppm ASTM D5185(m) >20	<1	<1	<1
Tin	ppm ASTM D5185(m) >20	0	0	0
Antimony	ppm ASTM D5185(m)	0	0	0
Vanadium	ppm ASTM D5185(m)	0	0	0
Beryllium	ppm ASTM D5185(m)	0	0	0
Cadmium	ppm ASTM D5185(m)	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185(m) 0	<1	<1	<1
Barium	ppm ASTM D5185(m) 0	<1	<1	2
Molybdenum	ppm ASTM D5185(m) 0	0	0	0
Manganese	ppm ASTM D5185(m) 0	0	<1	<1
Magnesium	ppm ASTM D5185(m) 0	1	1	1
Calcium	ppm ASTM D5185(m) 50	51	52	57
Phosphorus	ppm ASTM D5185(m) 330	339	351	363
Zinc	ppm ASTM D5185(m) 430	423	412	376
Sulfur	ppm ASTM D5185(m) 760	2731	2584	2811
Lithium	ppm ASTM D5185(m)	<1	<1	<1

CONTAMINANTS






method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185(m) >15	6	4	4
Sodium	ppm ASTM D5185(m)	80	5	8
Potassium	ppm ASTM D5185(m) >20	1	<1	<1
Water	% ASTM D6304* >5	0.238	---	---
ppm Water	ppm ASTM D6304* >50000	2389	---	---

FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	239928	95253	184671
Particles >6µm	ASTM D7647 >1300	206511	23382	46919
Particles >14µm	ASTM D7647 >160	86020	1655	2055
Particles >21µm	ASTM D7647 >40	32309	427	342
Particles >38µm	ASTM D7647 >10	1757	11	3
Particles >71µm	ASTM D7647 >3	47	1	0
Oil Cleanliness	ISO 4406 (c) >19/17/14	25/25/24	24/22/18	25/23/18



OIL ANALYSIS REPORT



FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.60	0.33	0.57	0.41

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	▲ LIGHT	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	VLITE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	▲ LIGHT	NONE
Sand/Dirt	scalar	Visual*	NONE	LIGHT	NONE	VLITE
Appearance	scalar	Visual*	NORML	▲ HAZY	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>5	.5%	NEG	NEG
Free Water	scalar	Visual*		▲ 1%	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	101	94.9	98.4	108

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------

Color			
Bottom			
PrtFilter	no image		no image



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **STELCO - BOSC - Basic Oxygen Slab Caster**
Sample No. : WC0898658 **Received** : 10 Jan 2024 2330 Regional Road #3, Door: BOSC8
Lab Number : **02608049** **Diagnosed** : 16 Jan 2024 NANTICOKE, ON
Unique Number : 5709135 **Diagnostician** : Kevin Marson CA N0A 1L0
Test Package : IND 2 (Additional Tests: KF, PQ)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

Contact: Tom Walden
 Thomas.Walden@stelco.com
 T: (519)587-4541
 F: (519)587-7702