


# OIL ANALYSIS REPORT

Sample Rating Trend

**NORMAL**



Area  
**GREATER SHEDIAC SEWERAGE [180532]**  
Machine Id  
**KOHLER 4732002440**

Component  
**Diesel Engine**  
Fluid  
**DIESEL ENGINE OIL SAE 15W40 (--- GAL)**

## DIAGNOSIS

**Recommendation**  
Resample at the next service interval to monitor.

**Wear**  
Metal levels are typical for a new component breaking in.

**Contamination**  
There is no indication of any contamination in the oil.

**Fluid Condition**  
The condition of the oil is acceptable for the time in service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WA0020820</b>	WA0019332	---
Sample Date	Client Info		<b>04 Jan 2024</b>	16 Feb 2023	---
Machine Age	hrs	Client Info	<b>257</b>	228	---
Oil Age	hrs	Client Info	<b>29</b>	68	---
Oil Changed	Client Info		<b>Changed</b>	Changed	---
Sample Status			<b>NORMAL</b>	NORMAL	---

## CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>5	<b>&lt;1.0</b>	<1.0	---
Water	WC Method	>0.2	<b>NEG</b>	NEG	---
Glycol	WC Method		<b>NEG</b>	NEG	---

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m) >100	<b>1</b>	2	---
Chromium	ppm	ASTM D5185(m) >20	<b>0</b>	0	---
Nickel	ppm	ASTM D5185(m) >4	<b>&lt;1</b>	0	---
Titanium	ppm	ASTM D5185(m)	<b>0</b>	<1	---
Silver	ppm	ASTM D5185(m) >3	<b>0</b>	0	---
Aluminum	ppm	ASTM D5185(m) >20	<b>1</b>	3	---
Lead	ppm	ASTM D5185(m) >40	<b>0</b>	0	---
Copper	ppm	ASTM D5185(m) >330	<b>&lt;1</b>	<1	---
Tin	ppm	ASTM D5185(m) >15	<b>0</b>	0	---
Antimony	ppm	ASTM D5185(m)	<b>0</b>	<1	---
Vanadium	ppm	ASTM D5185(m)	<b>0</b>	0	---
Beryllium	ppm	ASTM D5185(m)	<b>0</b>	0	---
Cadmium	ppm	ASTM D5185(m)	<b>0</b>	0	---

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 250	<b>8</b>	65	---
Barium	ppm	ASTM D5185(m) 10	<b>0</b>	0	---
Molybdenum	ppm	ASTM D5185(m) 100	<b>58</b>	78	---
Manganese	ppm	ASTM D5185(m)	<b>0</b>	<1	---
Magnesium	ppm	ASTM D5185(m) 450	<b>864</b>	25	---
Calcium	ppm	ASTM D5185(m) 3000	<b>1093</b>	2227	---
Phosphorus	ppm	ASTM D5185(m) 1150	<b>993</b>	1093	---
Zinc	ppm	ASTM D5185(m) 1350	<b>1113</b>	1139	---
Sulfur	ppm	ASTM D5185(m) 4250	<b>2696</b>	3318	---
Lithium	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	---


## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >25	<b>3</b>	5	---
Sodium	ppm	ASTM D5185(m) >158	<b>1</b>	2	---
Potassium	ppm	ASTM D5185(m) >20	<b>0</b>	0	---

## INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	ASTM D7844* >3	<b>0</b>	0	---
Nitration	Abs/cm	ASTM D7624* >20	<b>4.7</b>	7.4	---
Sulfation	Abs./1mm	ASTM D7415* >30	<b>18.1</b>	17.7	---

# OIL ANALYSIS REPORT











FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs./1mm	ASTM D7414*	>25	12.2	---

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	---	---
Yellow Metal	scalar	Visual*	NONE	---	---
Precipitate	scalar	Visual*	NONE	---	---
Silt	scalar	Visual*	NONE	---	---
Debris	scalar	Visual*	NONE	---	---
Sand/Dirt	scalar	Visual*	NONE	---	---
Appearance	scalar	Visual*	NORML	---	---
Odor	scalar	Visual*	NORML	NORML	---
Emulsified Water	scalar	Visual*	>0.2	NEG	---
Free Water	scalar	Visual*		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D7279(m)	14.4	14.9	14.0

## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WA0020820 **Received** : 16 Jan 2024  
**Lab Number** : 02608936 **Diagnosed** : 16 Jan 2024  
**Unique Number** : 5710022 **Diagnostician** : Wes Davis  
**Test Package** : MOB 1 ( Additional Tests: Visual )

**Wajax Power Systems**  
 485 VENTURE DR  
 MONCTON, NB  
 CA E1H 2P4  
 Contact: Doug Balsler  
 dbalsler@wajax.com  
 T: (506)855-5371  
 F: (506)870-4448

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.