PROBLEM SUMMARY

Sample Rating Trend



ISO

Area
Lime Kilns Route #1
Machine Id
102371 Kiln #3 Feed Table Hydraulics
Component
Hydraulic System
Fluid
ESSO NUTO H ISO 68 (30 GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation.

PROBLEMATIC TEST RESULTS

Sample Status				**SEVERE**	SEVERE	SEVERE
Particles >4µm		ASTM D7647	>5000	**62367**	89411	84744
Particles >6µm		ASTM D7647	>1300	**3132**	9209	12343
Oil Cleanliness		ISO 4406 (c)	>19/17/14	**23/19/14**	24/20/15	24/21/16

Customer Id: BEAING
Sample No.: WC0877631
Lab Number: 02608986
Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:
Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Seals	---	---	?	Check seals and/or filters for points of contaminant entry.

HISTORICAL DIAGNOSIS

16 Nov 2023 Diag: Wes Davis

ISO

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation.All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report

20 Apr 2023 Diag: Wes Davis

ISO

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.All component wear rates are normal. There is a high amount of particulates (2 to 100 microns in size) present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report

06 Oct 2022 Diag: Wes Davis

ISO

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.All component wear rates are normal. Particles >14µm are severely high. Particles >21µm are severely high. Particles >6µm are severely high. Oil Cleanliness are severely high. Particles >4µm are severely high. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report

OIL ANALYSIS REPORT

Sample Rating Trend



ISO

Area
Lime Kilns Route #1
Machine Id
102371 Kiln #3 Feed Table Hydraulics
Component
Hydraulic System
Fluid
ESSO NUTO H ISO 68 (30 GAL)

DIAGNOSIS

Recommendation

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**WC0877631**	WC0868739	WC0804946
Sample Date		Client Info		**12 Dec 2023**	16 Nov 2023	20 Apr 2023
Machine Age	mths	Client Info		**0**	0	0
Oil Age	mths	Client Info		**0**	0	0
Oil Changed		Client Info		**N/A**	N/A	N/A
Sample Status				**SEVERE**	SEVERE	SEVERE

CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>0.05	**NEG**	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>20	**6**	7	7
Chromium	ppm	ASTM D5185(m)	>20	**12**	13	11
Nickel	ppm	ASTM D5185(m)	>20	**<1**	<1	<1
Titanium	ppm	ASTM D5185(m)		**0**	0	0
Silver	ppm	ASTM D5185(m)		**0**	<1	0
Aluminum	ppm	ASTM D5185(m)	>20	**<1**	<1	<1
Lead	ppm	ASTM D5185(m)	>20	**1**	1	1
Copper	ppm	ASTM D5185(m)	>20	**11**	11	18
Tin	ppm	ASTM D5185(m)	>20	**<1**	<1	1
Antimony	ppm	ASTM D5185(m)		**0**	0	<1
Vanadium	ppm	ASTM D5185(m)		**0**	0	0
Beryllium	ppm	ASTM D5185(m)		**0**	0	0
Cadmium	ppm	ASTM D5185(m)		**0**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	**<1**	<1	<1
Barium	ppm	ASTM D5185(m)	0	**0**	<1	0
Molybdenum	ppm	ASTM D5185(m)	0	**0**	0	0
Manganese	ppm	ASTM D5185(m)		**0**	0	<1
Magnesium	ppm	ASTM D5185(m)	5	**2**	2	2
Calcium	ppm	ASTM D5185(m)	50	**203**	200	217
Phosphorus	ppm	ASTM D5185(m)	330	**319**	315	340
Zinc	ppm	ASTM D5185(m)	420	**344**	349	345
Sulfur	ppm	ASTM D5185(m)	3100	**7416**	7018	6952
Lithium	ppm	ASTM D5185(m)		**<1**	<1	<1

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>15	**<1**	<1	3
Sodium	ppm	ASTM D5185(m)		**0**	<1	0
Potassium	ppm	ASTM D5185(m)	>20	**0**	<1	0

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	**62367**	89411	84744
Particles >6µm		ASTM D7647	>1300	**3132**	9209	12343
Particles >14µm		ASTM D7647	>160	**102**	185	637
Particles >21µm		ASTM D7647	>40	**23**	32	140
Particles >38µm		ASTM D7647	>10	**1**	1	2
Particles >71µm		ASTM D7647	>3	**0**	1	0
Oil Cleanliness		ISO 4406 (c)	>19/17/14	**23/19/14**	24/20/15	24/21/16

OIL ANALYSIS REPORT

Particle Trend



Particle Trend



Acid Number



Viscosity @ 40°C



FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	.40	**0.31**	0.40	0.38

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	**NONE**	NONE	NONE
Precipitate	scalar	Visual*	NONE	**VLITE**	NONE	NONE
Silt	scalar	Visual*	NONE	**NONE**	NONE	NONE
Debris	scalar	Visual*	NONE	**NONE**	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	**NONE**	NONE	NONE
Appearance	scalar	Visual*	NORML	**NORML**	NORML	NORML
Odor	scalar	Visual*	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	Visual*	>0.05	**NEG**	NEG	NEG
Free Water	scalar	Visual*		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	68.8	**66.2**	66.3	65.0

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					



GRAPHS

Ferrous Alloys



Non-ferrous Metals



Viscosity @ 40°C



Particle Count



Acid Number



CALA
ISO 17025:2017 Accredited Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0877631 **Recieved** : 16 Jan 2024
Lab Number : 02608986 **Diagnosed** : 17 Jan 2024
Unique Number : 5710072 **Diagnostician** : Kevin Marson
Test Package : IND 2

To discuss this sample report, contact Customer Service at 1-800-268-2131.
Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
Validity of results and interpretation are based on the sample and information as supplied.

CARMEUSE LIME
374681 OXFORD COUNTY ROAD 6,, P.O. BOX 190
INGERSOLL, ON
CA N5C 3K5
Contact: Jeff Geddes
jeff.geddes@carmeusena.com
T: (519)423-6283
F: (519)423-6568