


## **FUEL REPORT**

# [6100246482] 47290255004196

Component **Diesel Fuel** 

No.2 DIESEL FUEL (ULTRALOW SULPHUR) (



## DIAGNOSIS

#### Recommendation

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you filter this fluid before use. The filter change at the time of sampling has been noted. Resample in 30-45 days to monitor this situation.

#### Corrosion

{not applicable}

#### Contaminants

There is a high amount of silt (particulates < 14 microns in size) present in the fuel. The water content is negligible. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code.


### Fuel Condition

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel (US EPA/CGSB-3.517-3 type B).

R) ( GAL)				Jan 2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WA0020714		
Sample Date		Client Info		11 Jan 2024		
Machine Age	hrs	Client Info		0		
Sample Status				SEVERE		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Specific Gravity		ASTM D1298*	0.839	0.833		
Fuel Color	text	Visual Screen*	Yllow	Green		
Visc @ 40°C	cSt	ASTM D7279(m)	3.0	2		
Pensky-Martens Flash Point	°C	ASTM D7215*	52	51.7		
SULFUR CONTE	NT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185(m)	10	12		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D2887*	165	160		
5% Distillation Point	°C	ASTM D2887*		181		
10% Distill Point	°C	ASTM D2887*	201	189		
15% Distillation Point	°C	ASTM D2887*		196		
20% Distill Point	°C	ASTM D2887*	216	203		
30% Distill Point	°C	ASTM D2887*	230	216		
40% Distill Point	°C	ASTM D2887*	243	229		
50% Distill Point	°C	ASTM D2887*	255	241		
60% Distill Point	°C	ASTM D2887*	267	254		
70% Distill Point	°C	ASTM D2887*	280	268		
80% Distill Point	°C	ASTM D2887*	295	283		
85% Distillation Point	°C	ASTM D2887*		295		
90% Distill Point	°C	ASTM D2887*	310	306		
95% Distillation Point	°C	ASTM D2887*		324		
Final Boiling Point	°C	ASTM D2887*	341	356		
IGNITION QUALIT	ΓΥ	method	limit/base	current	history1	history2
API Gravity		ASTM D1298*	37.7	38		
Cetane Index		ASTM D4737*	<40.0	46		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	<1.0	0		
Sodium	ppm	ASTM D5185(m)	< 0.1	<1		
Potassium	ppm	ASTM D5185(m)	<0.1	0		
Water	%	ASTM D6304*	< 0.05	0.004		
ppm Water	ppm	ASTM D6304*	<500	47		
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	93847		
Particles >6μm		ASTM D7647	>1300	<b>A</b> 8958		
Particles >14µm		ASTM D7647	>160	45		
Particles >21µm		ASTM D7647	>40	11		
Particles >38µm		ASTM D7647	>10	1		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>18/17/14	<b>2</b> 4/20/13		



## **FUEL REPORT**





CALA ISO 17025:2017 Accredited

Laboratory

Laboratory Sample No. Lab Number **Unique Number** 

: WA0020714 : 02609145

: 5710231

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Recieved

: 16 Jan 2024 Diagnosed : 22 Jan 2024

Diagnostician : Kevin Marson

Test Package : FUEL ( Additional Tests: CC Flash, GC-PercFuel, PrtCount ) To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

**Wajax Power Systems** 485 VENTURE DR MONCTON, NB CA E1H 2P4 Contact: Doug Balser dbalser@wajax.com T: (506)855-5371

F: (506)870-4448