




PROBLEM SUMMARY

Sample Rating Trend

WEAR




Area
Direct Strip Mill/Finishing
 Machine Id
NL1 ROUGHER MORGOIL SYSTEM (DSC016) (S/N 1000016795)
 Component
Gear Lube System
 Fluid
SHELL OMALA 680 (6000 LTR)




COMPONENT CONDITION SUMMARY


Non-ferrous Metals




Water (KF)



Particle Trend



Ferrous Alloys



RECOMMENDATION

We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. We advise that you check for visible metal particles in the oil. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We recommend you service the filters on this component. Re-sampling is suggested to confirm test results prior to significant maintenance activities being performed. Please indicate that this is a resample on your Sample Information Form (SIF). We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	ABNORMAL	NORMAL
Iron	ppm	ASTM D5185(m)	>150	▲ 256	157	152
Tin	ppm	ASTM D5185(m)	>10	● 65	▲ 10	5
Antimony	ppm	ASTM D5185(m)	>5	▲ 4	<1	<1
Water	%	ASTM D6304*	>0.1	▲ 0.145	0.079	---
ppm Water	ppm	ASTM D6304*	>1000	▲ 1459	793.8	---
Particles >14µm		ASTM D7647	>20000	▲ 46653	1851	3214
Oil Cleanliness		ISO 4406 (c)	>27/26/21	▲ 26/26/23	27/24/18	25/24/19
White Metal	scalar	Visual*	NONE	▲ VLITE	NONE	VLITE
Emulsified Water	scalar	Visual*	>0.1	▲ .2%	.2%	NEG
PrtFilter					no image	no image

Customer Id: ALGSSM
 Sample No.: WC0837454
 Lab Number: 02610440
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition. Re-sampling is suggested to confirm test results prior to significant maintenance activities being performed. Please indicate that this is a resample on your Sample Information Form (SIF).
Contact Required	---	---	?	Please contact your representative for information regarding the proper sampling kits for your service.
Alert	---	---	?	NOTE: We recommend using IND 3 test kits,
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Water Access	---	---	?	We advise that you check for the source of water entry.
Check For Visual Metal	---	---	?	We advise that you check for visible metal particles in the oil.
Check Seals	---	---	?	Check seals and/or filters for points of contaminant entry.
Filter Fluid	---	---	?	We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil.

HISTORICAL DIAGNOSIS

14 Nov 2023 Diag: Kevin Marson



We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid. Tin ppm levels are abnormal. A sharp increase in the tin level is noted. Bearing and/or bushing wear is indicated. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



26 Sep 2023 Diag: Kevin Marson



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



08 Aug 2023 Diag: Kevin Marson



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report






OIL ANALYSIS REPORT

Sample Rating Trend

WEAR



Area
Direct Strip Mill/Finishing
 Machine Id
NL1 ROUGHER MORGOIL SYSTEM (DSC016) (S/N 1000016795)
 Component
Gear Lube System
 Fluid
SHELL OMALA 680 (6000 LTR)



DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. We advise that you check for visible metal particles in the oil. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We recommend you service the filters on this component. Re-sampling is suggested to confirm test results prior to significant maintenance activities being performed. Please indicate that this is a resample on your Sample Information Form (SIF). We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.

Wear

Tin Tin ppm levels are severe. Iron and antimony ppm levels are abnormal. A sharp increase in the tin level is noted. Moderate concentration of visible metal present. Gear wear is indicated. Bearing and/or bushing wear is indicated. The low ferrous density (PQ) index indicates the wear metal levels are due to corrosion.


Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. There is a moderate concentration of water present in the oil. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code.

Fluid Condition

The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

Particle Filter (Magn: 100 x)



SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0837454	WC0837421	WC0837460
Sample Date	Client Info		18 Jan 2024	14 Nov 2023	26 Sep 2023
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	ABNORMAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*		29	0	0
Iron	ppm	ASTM D5185(m) >150	▲ 256	157	152
Chromium	ppm	ASTM D5185(m) >10	3	1	1
Nickel	ppm	ASTM D5185(m) >10	1	<1	<1
Titanium	ppm	ASTM D5185(m)	0	0	0
Silver	ppm	ASTM D5185(m)	0	<1	<1
Aluminum	ppm	ASTM D5185(m) >25	3	2	2
Lead	ppm	ASTM D5185(m) >100	1	<1	<1
Copper	ppm	ASTM D5185(m) >50	9	2	1
Tin	ppm	ASTM D5185(m) >10	● 65	▲ 10	5
Antimony	ppm	ASTM D5185(m) >5	▲ 4	<1	<1
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	2	2	1
Barium	ppm	ASTM D5185(m)	0	0	<1
Molybdenum	ppm	ASTM D5185(m)	0	0	0
Manganese	ppm	ASTM D5185(m)	4	<1	<1
Magnesium	ppm	ASTM D5185(m)	1	<1	<1
Calcium	ppm	ASTM D5185(m)	4	4	4
Phosphorus	ppm	ASTM D5185(m) 512	179	173	173
Zinc	ppm	ASTM D5185(m) 3.8	6	6	5
Sulfur	ppm	ASTM D5185(m) 8167	8252	8279	8267
Lithium	ppm	ASTM D5185(m)	<1	<1	<1

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >50	4	2	3
Sodium	ppm	ASTM D5185(m)	5	4	4
Potassium	ppm	ASTM D5185(m) >20	4	2	2
Water	%	ASTM D6304* >0.1	▲ 0.145	0.079	---
ppm Water	ppm	ASTM D6304* >1000	▲ 1459	793.8	---

FLUID CLEANLINESS


	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>1280000	503279	861810	274051
Particles >6µm	ASTM D7647	>640000	377994	151825	121814
Particles >14µm	ASTM D7647	>20000	▲ 46653	1851	3214
Particles >21µm	ASTM D7647	>5000	6269	195	380
Particles >38µm	ASTM D7647	>1300	104	2	6
Particles >71µm	ASTM D7647	>320	0	0	1

Oil Cleanliness ISO 4406 (c) >27/26/21 **▲ 26/26/23** 27/24/18 25/24/19




OIL ANALYSIS REPORT


Non-ferrous Metals




Particle Count




Water (KF)



Particle Trend



Ferrous Alloys



FLUID DEGRADATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.68	0.57	0.55

VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	▲ VLITE	NONE	VLITE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	VLITE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.1	▲ .2%	.2%	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	680	701	683	687

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color			
Bottom			
PrtFilter		no image	no image



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **ALGOMA STEEL INC. - STORES DEPT.**
Sample No. : WC0837454 **Received** : 22 Jan 2024 301 WALLACE TERRACE
Lab Number : 02610440 **Diagnosed** : 25 Jan 2024 SAULT STE MARIE, ON
Unique Number : 5711526 **Diagnostician** : Kevin Marson CA P6C 1K8
Test Package : IND 2 (Additional Tests: BottomAnalysis, FILTERPATCH, KF, PQ, PrtFilter, TAN Man Contact: Algoma Reliability
 algomareliability@algoma.com
 To discuss this sample report, contact Customer Service at 1-800-268-2131. T: (705)206-1059
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. F: (705)945-3585
 Validity of results and interpretation are based on the sample and information as supplied.