



# COOLANT REPORT

Sample Rating Trend

OFF SPEC



Machine Id  
**TJ034211**

Component  
**Coolant**

Fluid  
**EXTENDED LIFE COOLANT (--- GAL)**



## DIAGNOSIS

### ▲ Recommendation

We recommend that you drain the system and refill with a 50/50 long-life coolant/water mixture. We recommend an early resample to monitor this condition.

### ▲ Corrosion

Aluminum, iron and lead ppm levels are abnormal. The iron level is high indicating rust in the system which clogs the cooling system. The high metal levels indicate corrosion in the system.

### ▲ Contaminants

There is no indication of any contamination in the component(unconfirmed).

### ▲ Coolant Condition

The nitrite level is acceptable. The glycol level is too high which leads to over-heating and additive drop-out. The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>WC0408651</b>	---	---
Sample Date	Client Info			<b>27 Feb 2024</b>	---	---
Machine Age	hrs	Client Info		<b>0</b>	---	---
Oil Age	hrs	Client Info		<b>0</b>	---	---
Oil Changed	Client Info			<b>N/A</b>	---	---
Sample Status				<b>SEVERE</b>	---	---

PHYSICAL TEST RESULTS		method	limit/base	current	history1	history2
Glycol Type	FT-IR			<b>UNK</b>	---	---
Specific Gravity	ASTM D1298*			<b>1.088</b>	---	---
pH	Scale 0-14	ASTM D1287*	9.0	<b>7.17</b>	---	---
Nitrites	ppm	Alcan Test Kit*		<b>1400</b>	---	---
Reserve Alkalinity	Scale 0-20	ASTM D1121*		<b>8.1</b>	---	---
Percentage Glycol	%	ASTM D3321*	50	<b>▲ 68.6</b>	---	---
Freezing Point	°C	ASTM D3321*	-40	<b>▲ -54</b>	---	---
Boiling Point	°C	WC Method*		<b>114</b>	---	---
Carboxylate				<b>---</b>	---	---

CORROSION INHIBITORS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)		<b>18</b>	---	---
Phosphorus	ppm	ASTM D5185(m)		<b>18</b>	---	---
Boron	ppm	ASTM D5185(m)		<b>1654</b>	---	---
Molybdenum	ppm	ASTM D5185(m)		<b>9</b>	---	---





CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>15	<b>▲ 46</b>	---	---
Aluminum	ppm	ASTM D5185(m)	>10	<b>▲ 16</b>	---	---
Copper	ppm	ASTM D5185(m)	>10	<b>2</b>	---	---
Lead	ppm	ASTM D5185(m)	>10	<b>▲ 44</b>	---	---
Tin	ppm	ASTM D5185(m)	>10	<b>5</b>	---	---
Silver	ppm	ASTM D5185(m)	>10	<b>&lt;1</b>	---	---
Zinc	ppm	ASTM D5185(m)		<b>10</b>	---	---



CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D5185(m)		<b>10419</b>	---	---
Potassium	ppm	ASTM D5185(m)		<b>825</b>	---	---

SCALE POTENTIAL		method	limit/base	current	history1	history2
Calcium	ppm	ASTM D5185(m)	>100	<b>2</b>	---	---
Magnesium	ppm	ASTM D5185(m)	>40	<b>2</b>	---	---
Hardness	mg/L CaCO3	In-house*	<75	<b>11</b>	---	---









# COOLANT REPORT



VISUAL	method	limit/base	current	history1	history2
Coolant Color	Visual*	Orange/R	<b>Blue</b>	---	---
Coolant Appearance	Visual*	Clear	<b>Clear</b>	---	---
Color				no image	no image
Bottom				no image	no image

## GRAPHS



ISO 17025:2017 Accredited Laboratory  
 To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC0408651 **Received** : 08 Mar 2024  
**Lab Number** : **02620964** **Tested** : 08 Mar 2024  
**Unique Number** : 5746083 **Diagnosed** : 11 Mar 2024 - Kevin Marson  
**Test Package** : COOL ( Additional Tests: GlycolType, PQ )

**GENREP LTD.**  
 121 WATLINE AVENUE  
 MISSISSAUGA, ON  
 CA L4Z 1P2  
 Contact: Amit Singh  
 asingh@genrep.com  
 T: (905)502-9950  
 F: (905)502-9960