




OIL ANALYSIS REPORT

Sample Rating Trend



Area
[1-10K00T88]
 Machine Id
YORK SLYM436900
 Component
Chiller
 Fluid
YORK TYPE K (--- GAL)

DIAGNOSIS

- Recommendation**
Resample in 3 months to monitor this situation.
- Wear**
Iron ppm levels are abnormal. Compressor rotor wear, rotor thrust bearing wear, compressor rotor main bearing wear or possibly slide valve wear indicated.
- Contamination**
The water content is negligible. There is no indication of any contamination in the oil.
- Fluid Condition**
The AN level is acceptable for this fluid.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	GTT0001827	GTT68280	GTT68281
Sample Date	Client Info	30 Jan 2024	06 Apr 2023	25 Jan 2022
Machine Age	hrs	0	---	---
Oil Age	hrs	0	---	---
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	NORMAL	NORMAL

WEAR METALS

method	limit/base	current	history1	history2
Iron ppm	ASTM D5185(m) >8	▲ 66	42	2
Chromium ppm	ASTM D5185(m) >2	<1	0	<1
Nickel ppm	ASTM D5185(m)	<1	---	---
Titanium ppm	ASTM D5185(m)	0	---	---
Silver ppm	ASTM D5185(m) >2	0	---	---
Aluminum ppm	ASTM D5185(m) >3	<1	<1	<1
Lead ppm	ASTM D5185(m) >2	0	0	<1
Copper ppm	ASTM D5185(m) >8	1	<1	<1
Tin ppm	ASTM D5185(m) >4	0	<1	<1
Antimony ppm	ASTM D5185(m)	0	---	---
Vanadium ppm	ASTM D5185(m)	0	---	---
Beryllium ppm	ASTM D5185(m)	0	---	---
Cadmium ppm	ASTM D5185(m)	0	---	---

ADDITIVES

method	limit/base	current	history1	history2
Boron ppm	ASTM D5185(m) 0	<1	---	---
Barium ppm	ASTM D5185(m) 0	0	---	---
Molybdenum ppm	ASTM D5185(m) 0	0	---	---
Manganese ppm	ASTM D5185(m) 0	0	---	---
Magnesium ppm	ASTM D5185(m) 0	<1	---	---
Calcium ppm	ASTM D5185(m) 0	0	---	---
Phosphorus ppm	ASTM D5185(m) 5	0	---	---
Zinc ppm	ASTM D5185(m) 0	<1	2	<1
Sulfur ppm	ASTM D5185(m) 10	0	---	---
Lithium ppm	ASTM D5185(m)	<1	---	---

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon ppm	ASTM D5185(m) >15	3	---	---
Sodium ppm	ASTM D5185(m)	<1	---	---
Potassium ppm	ASTM D5185(m) >20	<1	---	---
ppm Water	ASTM D6304* >300	19	242	104



FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g	ASTM D974* 0.03	0.06	0.144	0.169

OIL ANALYSIS REPORT

VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	NONE	---	---
Yellow Metal	scalar	Visual*	NONE	NONE	---	---
Precipitate	scalar	Visual*	NONE	NONE	---	---
Silt	scalar	Visual*	NONE	NONE	---	---
Debris	scalar	Visual*	NONE	NONE	---	---
Sand/Dirt	scalar	Visual*	NONE	NONE	---	---
Appearance	scalar	Visual*	NORML	NORML	---	---
Odor	scalar	Visual*	NORML	NORML	---	---

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	32.0	62.5	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image

GRAPHS



Sample No. : GTT0001827
Lab Number : 02620992
Unique Number : 5746111
Test Package : IND 2 (Additional Tests: KV40)
Received : 08 Mar 2024
Tested : 11 Mar 2024
Diagnosed : 11 Mar 2024 - Bill Quesnel

Johnson Controls - Markham
 Accounts Payable A-33, P.O. Box 2012
 Milwaukee, WI
 US 532012012
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-905-847-9300 Ext 26.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Damages: Seller shall in no event be liable for special, incidental, or consequential damages, of a commercial nature, resulting from any cause.

T:
F: