

# **OIL ANALYSIS REPORT**

Acid Number (AN)


mg KOH/g ASTM D974\* 0.07



Area [291426] YORK SAAM540720

Chiller

REFRIGERATION OIL (POE) (--- GAL)



Sample Rating Trend



## Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

All component wear rates are normal.

## Contamination

The water content is negligible. There is no indication of any contamination in the oil.

## **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

(POE) ( GAL)		Feb 2015 No	v2015 Aug2017 Sep2018	Aug 2019 Oct 2020 Jan 2022 Nov 20	22 Feb2024	
SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		GTT0002148	GTT60361	GTT60362
Sample Date		Client Info		09 Feb 2024	23 Nov 2022	27 Jan 2022
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>8	2	<1	1
Chromium	ppm	ASTM D5185(m)	>2	0	<1	<1
Nickel	ppm	ASTM D5185(m)		<1		
Titanium	ppm	ASTM D5185(m)		0		
Silver	ppm	ASTM D5185(m)	>2	0		
Aluminum	ppm	ASTM D5185(m)	>3	<1	<1	<1
Lead	ppm	ASTM D5185(m)	>2	0	<1	<1
Copper	ppm	ASTM D5185(m)	>8	<1	<1	<1
Tin	ppm	ASTM D5185(m)	>4	<1	<1	<1
Antimony	ppm	ASTM D5185(m)		0		
Vanadium	ppm	ASTM D5185(m)		0		
Beryllium	ppm	ASTM D5185(m)		0		
Cadmium	ppm	ASTM D5185(m)		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	0		
Barium	ppm	ASTM D5185(m)	0	0		
Molybdenum	ppm	ASTM D5185(m)	0	0		
Manganese	ppm	ASTM D5185(m)	0	0		
Magnesium	ppm	ASTM D5185(m)	0	0		
Calcium	ppm	ASTM D5185(m)	10	0		
Phosphorus	ppm	ASTM D5185(m)	250	0		
Zinc	ppm	ASTM D5185(m)	0	2	<1	<1
Sulfur	ppm	ASTM D5185(m)	400	0		
Lithium	ppm	ASTM D5185(m)		<1		
CONTAMINANT	S	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>15	7		
Sodium	ppm	ASTM D5185(m)		<1		
Potassium	ppm	ASTM D5185(m)	>20	<1		
ppm Water	ppm		>300	<10	254	59
FLUID DEGRAD	ATION	method	limit/base	current	history1	history2
A -! -! NI:I (ANI)	1/011/	A OTA A DOZ 4*	0.07	0.00	0.044	0.000

0.014

0.03

0.029



# **OIL ANALYSIS REPORT**

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE		
Yellow Metal	scalar	Visual*	NONE	NONE		
Precipitate	scalar	Visual*	NONE	NONE		
Silt	scalar	Visual*	NONE	NONE		
Debris	scalar	Visual*	NONE	NONE		
Sand/Dirt	scalar	Visual*	NONE	NONE		
Appearance	scalar	Visual*	NORML	NORML		
Odor	scalar	Visual*	NORML	NORML		
FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)		33.0		
SAMPLE IMAGES		method	limit/base	current	history1	history2
Color					no image	no image
Bottom					no image	no image



 Sample No.
 : GTT0002148
 Received
 : 08 Mar 2024

 Lab Number
 : 02620994
 Tested
 : 11 Mar 2024

 University of the property of t

Unique Number : 5746113 Diagnosed : 11 Mar 2024 - Bill Quesnel Test Package : IND 2 ( Additional Tests: KV40 )

To discuss this sample report, contact Customer Service at 1-905-847-9300 Ext 26.

Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

Damages: Seller shall in no event be liable for special, incidental, or consequential damages, of a commercial nature, resulting from any cause.

**Modern Niagara Building Services** 

85 Denzil Doyle Ct Kanata, ON CA K2M 2G8

Contact: Service Manager

Contact/Location: Service Manager - GTT0000419

T:

F: