OIL ANALYSIS REPORT

Sample Rating Trend



ISO

Area
1 White Oil/028 #1HTU/P Pump/201A 1 Stage HTU Charge
Machine Id
N/A 28P201A (RECIP)
Component
Pump
Fluid
PETRO CANADA COMPRO COMPRESSOR OIL 150 (150 LTR)

DIAGNOSIS

Recommendation
We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

Wear
All component wear rates are normal.

Contamination
There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code.

Fluid Condition
The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**WC0902154**	WC0783253	WC0301700
Sample Date		Client Info		**25 Feb 2024**	17 Feb 2023	06 Jan 2022
Machine Age	hrs	Client Info		**0**	0	0
Oil Age	hrs	Client Info		**0**	0	0
Oil Changed		Client Info		**N/A**	N/A	N/A
Sample Status				**ABNORMAL**	ABNORMAL	NORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>.1	**NEG**	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>90	**2**	2	<1
Chromium	ppm	ASTM D5185(m)	>5	**0**	0	0
Nickel	ppm	ASTM D5185(m)	>5	**<1**	0	<1
Titanium	ppm	ASTM D5185(m)	>3	**0**	0	0
Silver	ppm	ASTM D5185(m)	>3	**0**	0	<1
Aluminum	ppm	ASTM D5185(m)	>7	**<1**	<1	<1
Lead	ppm	ASTM D5185(m)	>12	**0**	0	<1
Copper	ppm	ASTM D5185(m)	>30	**2**	2	2
Tin	ppm	ASTM D5185(m)	>9	**0**	0	<1
Antimony	ppm	ASTM D5185(m)		**0**	<1	0
Vanadium	ppm	ASTM D5185(m)		**0**	0	0
Beryllium	ppm	ASTM D5185(m)		**0**	0	0
Cadmium	ppm	ASTM D5185(m)		**0**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	**0**	<1	<1
Barium	ppm	ASTM D5185(m)	0	**0**	0	0
Molybdenum	ppm	ASTM D5185(m)	0	**0**	0	0
Manganese	ppm	ASTM D5185(m)		**0**	0	0
Magnesium	ppm	ASTM D5185(m)	70	**<1**	0	0
Calcium	ppm	ASTM D5185(m)	0	**0**	0	<1
Phosphorus	ppm	ASTM D5185(m)	60	**<1**	2	3
Zinc	ppm	ASTM D5185(m)	2	**1**	<1	1
Sulfur	ppm	ASTM D5185(m)	5300	**3354**	3248	3279
Lithium	ppm	ASTM D5185(m)		**<1**	<1	<1

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>60	**0**	<1	<1
Sodium	ppm	ASTM D5185(m)		**<1**	0	0
Potassium	ppm	ASTM D5185(m)	>20	**<1**	0	<1

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		**24182**	20617	296
Particles >6µm		ASTM D7647	>1300	▲ **6370**	▲ 5237	62
Particles >14µm		ASTM D7647	>160	● **273**	● 217	4
Particles >21µm		ASTM D7647	>40	**46**	40	1
Particles >38µm		ASTM D7647	>10	**2**	1	0
Particles >71µm		ASTM D7647	>3	**1**	0	0
Oil Cleanliness		ISO 4406 (c)	>--/17/14	▲ **22/20/15**	▲ 22/20/15	15/13/9

OIL ANALYSIS REPORT

Particle Trend



Particle Trend



Acid Number



Viscosity @ 40°C



FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.3	**0.10**	0.12	0.12

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	**NONE**	NONE	NONE
Precipitate	scalar	Visual*	NONE	**NONE**	NONE	NONE
Silt	scalar	Visual*	NONE	**NONE**	NONE	NONE
Debris	scalar	Visual*	NONE	**NONE**	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	**NONE**	NONE	NONE
Appearance	scalar	Visual*	NORML	**NORML**	NORML	NORML
Odor	scalar	Visual*	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	Visual*	>.1	**NEG**	NEG	NEG
Free Water	scalar	Visual*		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	150	**143**	149	147

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					



GRAPHS

Ferrous Alloys



Non-ferrous Metals



Viscosity @ 40°C



Particle Count



Acid Number



CALA
ISO 17025:2017 Accredited Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0902154 **Received** : 11 Mar 2024
Lab Number : 02621260 **Tested** : 12 Mar 2024
Unique Number : 5746379 **Diagnosed** : 12 Mar 2024 - Wes Davis
Test Package : IND 2 (Additional Tests: TAN Man)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
Validity of results and interpretation are based on the sample and information as supplied.

Petro Canada Lubricants Inc.
385 Southdown Road
Mississauga, ON
CA L5J 2Y3
Contact: Kyle Blezard
kyle.blezard@HFSinclair.com
T: (905)403-6768
F: (905)822-6025