




# PROBLEM SUMMARY

## Sample Rating Trend

ISO




Area  
**1 White Oil/028 #1HTU/P Pump/201B 1 Stage HTU Charge**  
 Machine Id  
**28GP201B**  
 Component  
**Gearbox**  
 Fluid  
**PETRO CANADA ENDURATEX SYNTHETIC EP 220 (50 LTR)**



## COMPONENT CONDITION SUMMARY

### ▲ Particle Trend



## RECOMMENDATION

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation.

## PROBLEMATIC TEST RESULTS

Sample Status		<b>SEVERE</b>	SEVERE	SEVERE
Particles >6µm	ASTM D7647 >5000	<b>▲ 56329</b>	▲ 54491	▲ 66251
Oil Cleanliness	ISO 4406 (c) >--/19/16	<b>▲ 24/23/16</b>	▲ 25/23/17	▲ 24/23/17

Customer Id: PETMIS  
 Sample No.: WC0902156  
 Lab Number: 02621263  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Wes Davis +1 905-569-8600 x223  
[wesd@wearcheck.ca](mailto:wesd@wearcheck.ca)

To change component or sample information:  
 Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Seals	---	---	?	Check seals and/or filters for points of contaminant entry.

HISTORICAL DIAGNOSIS

17 Feb 2023 Diag: Kevin Marson



Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Particles >6µm and oil cleanliness and oil cleanliness are severely high. Particles >14µm are notably high. The water content is negligible. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The AN level is above the recommended limit. The oil is no longer serviceable.

view report



06 Jan 2022 Diag: Kevin Marson



Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Particles >6µm are severely high. Particles >14µm are notably high. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The AN level is above the recommended limit. The oil is no longer serviceable.

view report



29 Apr 2021 Diag: Kevin Marson



Check seals and/or filters for points of contaminant entry. We recommend that you drain the oil from the component if this has not already been done. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Particles >6µm are severely high. Particles >14µm are abnormally high. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The AN level is above the recommended limit. The oil is no longer serviceable.

view report






# OIL ANALYSIS REPORT

Sample Rating Trend

ISO

Area  
**1 White Oil/028 #1HTU/P Pump/201B 1 Stage HTU Charge**  
Machine Id  
**28GP201B**

Component  
**Gearbox**  
Fluid  
**PETRO CANADA ENDURATEX SYNTHETIC EP 220 (50 LTR)**



## DIAGNOSIS

### ▲ Recommendation

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation.

### Wear

All component wear rates are normal.

### ▲ Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code.

### Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0902156</b>	WC0783255	WC0568052
Sample Date	Client Info		<b>25 Feb 2024</b>	17 Feb 2023	06 Jan 2022
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>SEVERE</b>	SEVERE	SEVERE

## CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.2	<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>200	<b>19</b>	12	11
Chromium	ppm	ASTM D5185(m)	>15	<b>0</b>	0	0
Nickel	ppm	ASTM D5185(m)	>15	<b>&lt;1</b>	<1	<1
Titanium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)		<b>0</b>	0	<1
Aluminum	ppm	ASTM D5185(m)	>25	<b>&lt;1</b>	<1	<1
Lead	ppm	ASTM D5185(m)	>100	<b>0</b>	3	1
Copper	ppm	ASTM D5185(m)	>200	<b>4</b>	61	23
Tin	ppm	ASTM D5185(m)	>25	<b>0</b>	1	<1
Antimony	ppm	ASTM D5185(m)	>5	<b>0</b>	<1	0
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	0	0

## ADDITIVES





	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	33	<b>27</b>	30	32
Barium	ppm	ASTM D5185(m)	5	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185(m)		<b>0</b>	0	0
Manganese	ppm	ASTM D5185(m)		<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185(m)	5	<b>3</b>	<1	<1
Calcium	ppm	ASTM D5185(m)	5	<b>8</b>	0	1
Phosphorus	ppm	ASTM D5185(m)	437	<b>419</b>	445	312
Zinc	ppm	ASTM D5185(m)	5	<b>8</b>	59	39
Sulfur	ppm	ASTM D5185(m)	5000	<b>4969</b>	4889	4614
Lithium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	<1

## CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>50	<b>25</b>	<1	0
Sodium	ppm	ASTM D5185(m)		<b>8</b>	<1	<1
Potassium	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	<1	1

## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		<b>131509</b>	212872	141229
Particles >6µm	ASTM D7647	>5000	<b>▲ 56329</b>	▲ 54491	▲ 66251
Particles >14µm	ASTM D7647	>640	<b>484</b>	● 1175	● 1192
Particles >21µm	ASTM D7647	>160	<b>31</b>	181	34
Particles >38µm	ASTM D7647	>40	<b>2</b>	4	0
Particles >71µm	ASTM D7647	>10	<b>1</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>--/19/16	<b>▲ 24/23/16</b>	▲ 25/23/17	▲ 24/23/17




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.7	<b>0.95</b>	▲ 1.72	▲ 2.41






VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	Visual*	NONE	<b>NONE</b>	NONE	LIGHT
Debris	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	Visual*	NORML	<b>NORML</b>	▲ WGOIL	NORML
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	Visual*	>0.2	<b>NEG</b>	NEG	NEG
Free Water	scalar	Visual*		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	223	<b>221</b>	226	220

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC0902156 **Received** : 11 Mar 2024  
**Lab Number** : **02621263** **Tested** : 12 Mar 2024  
**Unique Number** : 5746382 **Diagnosed** : 12 Mar 2024 - Wes Davis  
**Test Package** : IND 2 ( Additional Tests: TAN Man )

**Petro Canada Lubricants Inc.**  
 385 Southdown Road  
 Mississauga, ON  
 CA L5J 2Y3  
 Contact: Kyle Blezard  
 kyle.blezard@HFSinclair.com  
 T: (905)403-6768  
 F: (905)822-6025

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.