




PROBLEM SUMMARY

Sample Rating Trend




ISO



Area
Plate Mill/166 Hot Mill
 Machine Id
#5 FURNACE HYDRAULICS (PLS003) (S/N 1000001515)
 Component
Hydraulic System
 Fluid
FIRE-RESISTANT FLUID ISO 32 (--- GAL)



COMPONENT CONDITION SUMMARY



RECOMMENDATION

Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. We advise that you check all areas where contaminants can enter the system. We advise that you add water to increase the water concentration level to 40%. Ensure that only distilled water or boiler feed water condensate are used for make-up. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please specify the brand, type, and viscosity of the oil on your next sample.

PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	ABNORMAL	ABNORMAL
Water	%	ASTM D6304*	>55	▲ 20.0	▲ 23.8
ppm Water	ppm	ASTM D6304*	>55000	▲ 200000	▲ 238000
Particles >4µm		ASTM D7647	>5000	▲ 56567	▲ 15000
Particles >6µm		ASTM D7647	>1300	▲ 14499	▲ 3750
Particles >14µm		ASTM D7647	>160	▲ 916	▲ 480
Particles >21µm		ASTM D7647	>40	▲ 172	● 60
Oil Cleanliness		ISO 4406 (c)	>19/17/14	▲ 23/21/17	▲ 21/19/16
Visc @ 40°C	cSt	ASTM D7279(m)	32	▲ 157	▲ 126

Customer Id: ALGSSM
 Sample No.: WC0813610
 Lab Number: 02621606
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Service/change Fluid	---	---	?	We advise that you add water to increase the water concentration level to 40%. Ensure that only distilled water or boiler feed water condensate are used for make-up.
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Alert	---	---	?	Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment.
Information Required	---	---	?	Please specify the brand, type, and viscosity of the oil on your next sample. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Dirt Access	---	---	?	We advise that you check all areas where contaminants can enter the system.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

HISTORICAL DIAGNOSIS

WATER



23 Jan 2021 Diag: Kevin Marson

Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. We advise that you add water to increase the water concentration level to 40%. Ensure that only distilled water or boiler feed water condensate are used for make-up. We recommend you service the filters on this component. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please specify the brand, type, and viscosity of the oil on your next sample. All component wear rates are normal. Water contamination levels are abnormally low. ppm Water contamination levels are abnormally low. Particles >14µm are abnormally high. Particles >4µm are abnormally high. Particles >6µm are abnormally high. Particles >21µm are notably high. The water concentration level is lower than acceptable for this fluid. Viscosity of sample indicates oil is within ISO 150 range, advise investigate. The AN level is acceptable for this fluid. The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



WATER



25 Sep 2020 Diag: Kevin Marson

Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. We advise that you add water to increase the water concentration level to 40%. Ensure that only distilled water or boiler feed water condensate are used for make-up. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please specify the brand, type, and viscosity of the oil on your next sample. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water concentration level is lower than acceptable for this fluid. Viscosity of sample indicates oil is within ISO 150 range, advise investigate. The AN level is acceptable for this fluid. The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable.

view report



WATER



31 Jul 2020 Diag: Kevin Marson

Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. We advise that you add water to increase the water concentration level to 40%. Ensure that only distilled water or boiler feed water condensate are used for make-up. We recommend you service the filters on this component. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please specify the brand, type, and viscosity of the oil on your next sample. All component wear rates are normal. Water contamination levels are abnormally low. ppm Water contamination levels are abnormally low. Particles >4µm are abnormally high. Particles >6µm are abnormally high. Particles >14µm are notably high. The water concentration level is lower than acceptable for this fluid. Viscosity of sample indicates oil is within ISO 150 range, advise investigate. The AN level is acceptable for this fluid. The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report






OIL ANALYSIS REPORT

Sample Rating Trend

ISO



Area
Plate Mill/166 Hot Mill
 Machine Id
#5 FURNACE HYDRAULICS (PLS003) (S/N 1000001515)
 Component
Hydraulic System
 Fluid
FIRE-RESISTANT FLUID ISO 32 (--- GAL)



DIAGNOSIS

Recommendation

Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. We advise that you check all areas where contaminants can enter the system. We advise that you add water to increase the water concentration level to 40%. Ensure that only distilled water or boiler feed water condensate are used for make-up. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the oil.

Fluid Condition

The water concentration level is lower than acceptable for this fluid. Viscosity of sample indicates oil is within ISO 150 range, advise investigate. The AN level is acceptable for this fluid. The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0813610	WC0496422	WC0494791
Sample Date	Client Info		08 Mar 2024	23 Jan 2021	25 Sep 2020
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	ABNORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>20	0	1	<1
Chromium	ppm	ASTM D5185(m)	>20	0	<1	<1
Nickel	ppm	ASTM D5185(m)	>20	0	<1	<1
Titanium	ppm	ASTM D5185(m)		0	<1	<1
Silver	ppm	ASTM D5185(m)		<1	1	0
Aluminum	ppm	ASTM D5185(m)	>20	0	0	0
Lead	ppm	ASTM D5185(m)	>20	0	4	2
Copper	ppm	ASTM D5185(m)	>20	0	1	1
Tin	ppm	ASTM D5185(m)	>20	0	<1	<1
Antimony	ppm	ASTM D5185(m)		0	<1	2
Vanadium	ppm	ASTM D5185(m)		0	<1	<1
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	<1	<1

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	5	<1	3	<1
Barium	ppm	ASTM D5185(m)	5	<1	0	<1
Molybdenum	ppm	ASTM D5185(m)	5	0	5	<1
Manganese	ppm	ASTM D5185(m)		0	<1	<1
Magnesium	ppm	ASTM D5185(m)	5	0	<1	1
Calcium	ppm	ASTM D5185(m)	50	0	3	<1
Phosphorus	ppm	ASTM D5185(m)	175	2	21	0
Zinc	ppm	ASTM D5185(m)	62	0	<1	<1
Sulfur	ppm	ASTM D5185(m)	500	56	30	33
Lithium	ppm	ASTM D5185(m)		<1	<1	<1

CONTAMINANTS






	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>15	0	<1	<1
Sodium	ppm	ASTM D5185(m)		29	60	39
Potassium	ppm	ASTM D5185(m)	>20	16	90	21
Water	%	ASTM D6304*	>55	▲ 20.0	▲ 23.8	▲ 23.9
ppm Water	ppm	ASTM D6304*	>55000	▲ 200000	▲ 238000	▲ 239000

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	▲ 56567	▲ 15000	3750
Particles >6µm	ASTM D7647	>1300	▲ 14499	▲ 3750	970
Particles >14µm	ASTM D7647	>160	▲ 916	▲ 480	60
Particles >21µm	ASTM D7647	>40	▲ 172	● 60	7
Particles >38µm	ASTM D7647	>10	6	7	0
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	▲ 23/21/17	▲ 21/19/16	19/17/13



OIL ANALYSIS REPORT



FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	3.63	6.90	5.89	6.09
Alkiline Reserve (Oils)	ml KOH/g	ASTM D1121*		170	175	176

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	VLITE	VLITE
Sand/Dirt	scalar	Visual*	NONE	NONE	VLITE	NONE
Appearance	scalar	Visual*	NORML	FRGLY	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>55	>10%	>10%	>10%
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
pH	Scale 0-14	ASTM D1287*		9.08	9.13	9.10
Visc @ 40°C	cSt	ASTM D7279(m)	32	▲ 157	▲ 126	▲ 134

SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						
Bottom						
PrtFilter						



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0813610 **Received** : 12 Mar 2024
Lab Number : **02621606** **Tested** : 14 Mar 2024
Unique Number : 5746725 **Diagnosed** : 14 Mar 2024 - Kevin Marson
Test Package : IND 2 (Additional Tests: KF, pH, ReserveAlk, TAN Man)

ALGOMA STEEL INC. - STORES DEPT.
 301 WALLACE TERRACE
 SAULT STE MARIE, ON
 CA P6C 1K8
 Contact: Algoma Reliability
 algomareliability@algoma.com
 T: (705)206-1059
 F: (705)945-3585

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.