



OIL ANALYSIS REPORT

Sample Rating Trend

WATER



Area
10050 Ch #LR Circ 1 [GTT224-317]
 Machine Id
CARRIER 2003Q02700(1)
 Component
Chiller
 Fluid
COMP OIL (POE) ISO 220 (--- GAL)



DIAGNOSIS

Recommendation

If not recently done change any filter driers to reduce moisture level. We recommend an early resample to monitor this condition. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

Copper ppm levels are abnormal. The elevated copper reading suggests the effects of oil migration through the evaporator (oil loss from the compressor) possibly occurring during intervals of operation at low cooling load conditions.

Contamination

The elevated moisture content is associated with POE oils which are hygroscopic, and can absorb moisture from sampling and processing.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	GTT0002015	---	---
Sample Date	Client Info	01 Mar 2024	---	---
Machine Age	hrs Client Info	0	---	---
Oil Age	hrs Client Info	0	---	---
Oil Changed	Client Info	N/A	---	---
Sample Status		ABNORMAL	---	---

WEAR METALS

method	limit/base	current	history1	history2
Iron ppm ASTM D5185(m)	>8	<1	---	---
Chromium ppm ASTM D5185(m)	>2	0	---	---
Nickel ppm ASTM D5185(m)		<1	---	---
Titanium ppm ASTM D5185(m)		0	---	---
Silver ppm ASTM D5185(m)	>2	0	---	---
Aluminum ppm ASTM D5185(m)	>3	<1	---	---
Lead ppm ASTM D5185(m)	>2	2	---	---
Copper ppm ASTM D5185(m)	>8	9	---	---
Tin ppm ASTM D5185(m)	>4	0	---	---
Antimony ppm ASTM D5185(m)		0	---	---
Vanadium ppm ASTM D5185(m)		0	---	---
Beryllium ppm ASTM D5185(m)		0	---	---
Cadmium ppm ASTM D5185(m)		0	---	---

ADDITIVES

method	limit/base	current	history1	history2
Boron ppm ASTM D5185(m)	5	0	---	---
Barium ppm ASTM D5185(m)	5	0	---	---
Molybdenum ppm ASTM D5185(m)	5	0	---	---
Manganese ppm ASTM D5185(m)		0	---	---
Magnesium ppm ASTM D5185(m)	5	<1	---	---
Calcium ppm ASTM D5185(m)	5	0	---	---
Phosphorus ppm ASTM D5185(m)	400	2	---	---
Zinc ppm ASTM D5185(m)	5	16	---	---
Sulfur ppm ASTM D5185(m)	100	0	---	---
Lithium ppm ASTM D5185(m)		<1	---	---

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon ppm ASTM D5185(m)	>15	48	---	---
Sodium ppm ASTM D5185(m)		0	---	---
Potassium ppm ASTM D5185(m)	>20	<1	---	---
ppm Water ppm ASTM D6304*	>100	446	---	---



FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g ASTM D974*	0.40	0.06	---	---

OIL ANALYSIS REPORT

VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	NONE	---	---
Yellow Metal	scalar	Visual*	NONE	NONE	---	---
Precipitate	scalar	Visual*	NONE	NONE	---	---
Silt	scalar	Visual*	NONE	NONE	---	---
Debris	scalar	Visual*	NONE	NONE	---	---
Sand/Dirt	scalar	Visual*	NONE	NONE	---	---
Appearance	scalar	Visual*	NORML	NORML	---	---
Odor	scalar	Visual*	NORML	NORML	---	---

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	220	209	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image

GRAPHS



Sample No. : GTT0002015
Lab Number : 02622184
Unique Number : 5747303
Test Package : IND 2 (Additional Tests: KV40)
Received : 14 Mar 2024
Tested : 20 Mar 2024
Diagnosed : 20 Mar 2024 - Bill Quesnel

*To discuss this sample report, contact Customer Service at 1-905-847-9300 Ext 26.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Damages: Seller shall in no event be liable for special, incidental, or consequential damages, of a commercial nature, resulting from any cause.*

General Refrigeration

CA
 Contact: Service Manager
 bcrooks@general-refrigeration.ca
 T:
 F: