OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL

Area
[152268]
Machine Id
ALBA HPU A MONT
Component
Hydraulic System
Fluid
SHELL TELLUS 32 (245 LTR)

DIAGNOSIS

Recommendation
Resample at the next service interval to monitor.

Wear
All component wear rates are normal.

Contamination
The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**WC0779177**	WC0779126	---
Sample Date		Client Info		**12 Mar 2024**	14 Sep 2023	---
Machine Age	mths	Client Info		**336**	28	---
Oil Age	mths	Client Info		**114**	9	---
Oil Changed		Client Info		**N/A**	Not Changd	---
Sample Status				**NORMAL**	NORMAL	---

CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>0.05	**NEG**	NEG	---

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>20	**<1**	<1	---
Chromium	ppm	ASTM D5185(m)	>20	**0**	0	---
Nickel	ppm	ASTM D5185(m)	>20	**0**	<1	---
Titanium	ppm	ASTM D5185(m)		**0**	0	---
Silver	ppm	ASTM D5185(m)		**0**	0	---
Aluminum	ppm	ASTM D5185(m)	>20	**<1**	<1	---
Lead	ppm	ASTM D5185(m)	>20	**<1**	<1	---
Copper	ppm	ASTM D5185(m)	>20	**2**	2	---
Tin	ppm	ASTM D5185(m)	>20	**0**	0	---
Antimony	ppm	ASTM D5185(m)		**0**	0	---
Vanadium	ppm	ASTM D5185(m)		**0**	0	---
Beryllium	ppm	ASTM D5185(m)		**0**	0	---
Cadmium	ppm	ASTM D5185(m)		**0**	0	---

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		**0**	<1	---
Barium	ppm	ASTM D5185(m)		**0**	0	---
Molybdenum	ppm	ASTM D5185(m)		**0**	0	---
Manganese	ppm	ASTM D5185(m)		**0**	0	---
Magnesium	ppm	ASTM D5185(m)	11	**6**	6	---
Calcium	ppm	ASTM D5185(m)	35	**45**	45	---
Phosphorus	ppm	ASTM D5185(m)	259	**273**	293	---
Zinc	ppm	ASTM D5185(m)	277	**309**	324	---
Sulfur	ppm	ASTM D5185(m)	1865	**2621**	2538	---
Lithium	ppm	ASTM D5185(m)		**<1**	<1	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>15	**2**	2	---
Sodium	ppm	ASTM D5185(m)		**<1**	<1	---
Potassium	ppm	ASTM D5185(m)	>20	**<1**	0	---

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	**1517**	4661	---
Particles >6µm		ASTM D7647	>1300	**228**	1148	---
Particles >14µm		ASTM D7647	>160	**13**	71	---
Particles >21µm		ASTM D7647	>40	**3**	18	---
Particles >38µm		ASTM D7647	>10	**1**	1	---
Particles >71µm		ASTM D7647	>3	**1**	1	---
Oil Cleanliness		ISO 4406 (c)	>19/17/14	**18/15/11**	19/17/13	---

OIL ANALYSIS REPORT

Particle Trend



Acid Number



Viscosity @ 40°C



Particle Trend



FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.32	**0.31**	0.34	---

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	**NONE**	NONE	---
Yellow Metal	scalar	Visual*	NONE	**NONE**	NONE	---
Precipitate	scalar	Visual*	NONE	**NONE**	NONE	---
Silt	scalar	Visual*	NONE	**NONE**	NONE	---
Debris	scalar	Visual*	NONE	**NONE**	NONE	---
Sand/Dirt	scalar	Visual*	NONE	**NONE**	NONE	---
Appearance	scalar	Visual*	NORML	**NORML**	NORML	---
Odor	scalar	Visual*	NORML	**NORML**	NORML	---
Emulsified Water	scalar	Visual*	>0.05	**NEG**	NEG	---
Free Water	scalar	Visual*		**NEG**	NEG	---

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	32.32	**31.3**	31.1	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					*no image*
Bottom					*no image*

GRAPHS

Ferrous Alloys

Non-ferrous Metals



Viscosity @ 40°C



Particle Count



Acid Number



ISO 17025:2017 Accredited Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0779177
Lab Number : 02622333
Unique Number : 5747452
Test Package : IND 2

Received : 15 Mar 2024
Tested : 18 Mar 2024
Diagnosed : 18 Mar 2024 - Wes Davis

To discuss this sample report, contact Customer Service at 1-800-268-2131.
Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
Validity of results and interpretation are based on the sample and information as supplied.

ALGONQUIN POWER SYSTEMS INC.
354 DAVIS ROAD
OAKVILLE, ON
CA L6J 2X1
Contact: Gary Gazankas
gary.gazankas@algonquinpower.com
T: (905)465-6119
F: (905)273-4514