




# OIL ANALYSIS REPORT

Sample Rating Trend

**NORMAL**

Area  
**31 WOODROOM**  
 Machine Id  
**CHIPS TO STORAGE BLOWER - REDUCER (S/N 315802B)**  
 Component  
**Gear Reducer**  
 Fluid  
**MOBIL MOBILGEAR 600 XP 220 (5 GAL)**



## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>WC</b>	WC	WC
Sample Date	Client Info	<b>11 Mar 2024</b>	15 Jan 2024	11 Jul 2023
Machine Age	hrs	Client Info	<b>0</b>	0
Oil Age	hrs	Client Info	<b>0</b>	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>NORMAL</b>	NORMAL	NORMAL

## CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method >0.2	<b>NEG</b>	NEG	NEG

## WEAR METALS

method	limit/base	current	history1	history2	
PQ	ASTM D8184*	<b>23</b>	0	0	
Iron	ppm	ASTM D5185(m) >250	<b>42</b>	35	31
Chromium	ppm	ASTM D5185(m) >5	<b>&lt;1</b>	0	<1
Nickel	ppm	ASTM D5185(m) >5	<b>&lt;1</b>	<1	<1
Titanium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)	<b>0</b>	<1	0
Aluminum	ppm	ASTM D5185(m) >20	<b>&lt;1</b>	<1	<1
Lead	ppm	ASTM D5185(m) >50	<b>0</b>	<1	<1
Copper	ppm	ASTM D5185(m) >50	<b>1</b>	4	4
Tin	ppm	ASTM D5185(m) >5	<b>0</b>	0	0
Antimony	ppm	ASTM D5185(m) >5	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)	<b>0</b>	0	<1

## ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	<b>28</b>	27	28
Barium	ppm	ASTM D5185(m)	<b>2</b>	<1	<1
Molybdenum	ppm	ASTM D5185(m)	<b>0</b>	0	<1
Manganese	ppm	ASTM D5185(m)	<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185(m)	<b>&lt;1</b>	2	2
Calcium	ppm	ASTM D5185(m)	<b>2</b>	12	13
Phosphorus	ppm	ASTM D5185(m)	<b>326</b>	359	391
Zinc	ppm	ASTM D5185(m)	<b>5</b>	12	14
Sulfur	ppm	ASTM D5185(m)	<b>15261</b>	15101	14851
Lithium	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	<1

## CONTAMINANTS




method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m) >60	<b>4</b>	6	11
Sodium	ppm	ASTM D5185(m)	<b>&lt;1</b>	0	<1
Potassium	ppm	ASTM D5185(m) >20	<b>1</b>	<1	<1

## FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974*	<b>0.72</b>	0.78	0.75




# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	VLITE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	220	214	208

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC  
**Lab Number** : 02622463  
**Unique Number** : 5747582  
**Test Package** : IND 2 ( Additional Tests: TAN Man )  
**Received** : 15 Mar 2024  
**Tested** : 15 Mar 2024  
**Diagnosed** : 15 Mar 2024 - Wes Davis

**AV GROUP NB INC.**  
 103 PINDER ROAD,, NACKAWIC MILL  
 NACKAWIC, NB  
 CA E6G 1W4  
 Contact: Basil Fadulalla  
 basil.fadulalla@adityabirla.com

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

T:  
F: