


PROBLEM SUMMARY

Area 2GS

2GS G4 GENERATOR NDE BEARING 1


Bearing

MOBIL TERESSTIC 100 (15 GAL)





COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

| PROBLEMATIC TEST RESULTS | | | | | | | | |
|--------------------------|--------------|-----------|-----------------|------------------|--------------|--|--|--|
| Sample Status | | | SEVERE | SEVERE | ATTENTION | | | |
| Particles >4µm | ASTM D7647 | >1300 | A 78312 | 1 24908 | 15139 | | | |
| Particles >6µm | ASTM D7647 | >320 | 19377 | 2739 | 1678 | | | |
| Particles >14µm | ASTM D7647 | >40 | 4 396 | 4 95 | 59 | | | |
| Particles >21µm | ASTM D7647 | >10 | 44 | 18 | 12 | | | |
| Oil Cleanliness | ISO 4406 (c) | >17/15/12 | 23/21/16 | 2 2/19/14 | 21/18/13 | | | |

Customer Id: ENE271OTT **Sample No.:** WC0908272 Lab Number: 02622726 Test Package: IND 3

To manage this report scan the QR code

To discuss the diagnosis or test data: Kevin Marson +1 (289)291-4644 x4644 Kevin.Marson@wearcheck.com

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 gloria.gonzalez@wearcheck.com

| RECOMMENDED ACTIONS | | | | | | |
|---------------------|--------|------|---------|--|--|--|
| Action | Status | Date | Done By | Description | | |
| Change Filter | | | ? | We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. | | |
| Resample | | | ? | Resample in 30-45 days to monitor this situation. | | |
| Check Breathers | | | ? | The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. | | |
| Check Dirt Access | | | ? | We advise that you check all areas where contaminants can enter the system. | | |
| Filter Fluid | | | ? | We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. | | |

HISTORICAL DIAGNOSIS

14 Feb 2024 Diag: Kevin Marson

ISO



Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. The ferrography results are normal indicating no abnormal wear in the system. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.



03 Sep 2020 Diag: Bill Quesnel

WEAR



We recommend you service the filters on this component. Resample at the next service interval to monitor.Lead ppm levels are noted. All other component wear rates are normal. The direct-reading & analytical ferrographic results are normal indicating no abnormal wear in the system. There is a light amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



10 Dec 2015 Diag: Kevin Marson

WEAR



We recommend an early resample to monitor this condition.Lead ppm levels are noted. All other component wear rates are normal. The direct-reading & analytical ferrographic results are normal indicating no abnormal wear in the system. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.






OIL ANALYSIS REPORT

Area 2GS

2GS G4 GENERATOR NDE BEARING 1

Bearing

MOBIL TERESSTIC 100 (15 GAL)



DIAGNOSIS

Recommendation

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

Wear

All component wear rates are normal. The ferrography results are normal indicating no abnormal wear in the system.

▲ Contaminants

There is a high amount of particulates (2 to 100 microns in size) present in the oil. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code.


Oil Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

| SAMPLE INFORM | MATION | method | limit/base | current | history1 | history2 |
|---------------|--------|---------------|------------|-------------|-------------|-------------|
| Sample Number | | Client Info | | WC0908272 | WC0908282 | WC0488743 |
| Sample Date | | Client Info | | 06 Mar 2024 | 14 Feb 2024 | 03 Sep 2020 |
| Machine Age | yrs | Client Info | | 22 | 0 | 0 |
| Oil Age | yrs | Client Info | | 0 | 30 | 6 |
| Oil Changed | | Client Info | | N/A | Not Changd | Filtered |
| Sample Status | | | | SEVERE | SEVERE | ATTENTION |
| CONTAMINATIO | N | method | limit/base | current | history1 | history2 |
| Water | | WC Method | >2 | NEG | NEG | NEG |
| WEAR METALS | | method | limit/base | current | history1 | history2 |
| PQ | | ASTM D8184* | | 0 | 0 | 0 |
| Iron | ppm | ASTM D5185(m) | >20 | <1 | <1 | <1 |
| Chromium | ppm | ASTM D5185(m) | >20 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185(m) | >20 | <1 | 0 | <1 |
| Titanium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185(m) | | 0 | 0 | <1 |
| Aluminum | ppm | ASTM D5185(m) | >20 | <1 | <1 | <1 |
| Lead | ppm | ASTM D5185(m) | >20 | 4 | 18 | 53 |
| Copper | ppm | ASTM D5185(m) | >20 | <1 | <1 | <1 |
| Tin | ppm | ASTM D5185(m) | >20 | <1 | 1 | 1 |
| Antimony | ppm | ASTM D5185(m) | | <1 | <1 | <1 |
| Vanadium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| Beryllium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| ADDITIVES | | method | limit/base | current | history1 | history2 |
| Boron | ppm | ASTM D5185(m) | | 0 | 0 | <1 |
| Barium | ppm | ASTM D5185(m) | | 0 | 0 | <1 |
| Molybdenum | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| Magnesium | ppm | ASTM D5185(m) | | 0 | <1 | <1 |
| Calcium | ppm | ASTM D5185(m) | | <1 | 1 | <1 |
| Phosphorus | ppm | ASTM D5185(m) | | 0 | 0 | 1 |
| Zinc | ppm | ASTM D5185(m) | | <1 | 2 | 3 |
| Sulfur | ppm | ASTM D5185(m) | | 8050 | 8006 | 7506 |
| Lithium | ppm | ASTM D5185(m) | | <1 | <1 | <1 |
| CONTAMINANTS | ; | method | limit/base | current | history1 | history2 |
| Silicon | ppm | ASTM D5185(m) | >15 | <1 | 2 | <1 |
| Sodium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| Potassium | ppm | ASTM D5185(m) | >20 | <1 | <1 | <1 |



OIL ANALYSIS REPORT



| FLUID CLEANLIN | ESS | method | limit/base | current | history1 | history2 |
|------------------|----------|---------------|------------|-----------------|------------------|----------|
| Particles >4µm | | ASTM D7647 | >1300 | 78312 | 2 4908 | 15139 |
| Particles >6µm | | ASTM D7647 | >320 | 19377 | 2739 | 1678 |
| Particles >14µm | | ASTM D7647 | >40 | 396 | <u> </u> | 59 |
| Particles >21µm | | ASTM D7647 | >10 | <u>44</u> | 1 8 | 12 |
| Particles >38µm | | ASTM D7647 | >3 | 3 | 2 | 0 |
| Particles >71µm | | ASTM D7647 | >3 | 2 | 2 | 0 |
| Oil Cleanliness | | ISO 4406 (c) | >17/15/12 | 23/21/16 | 2 2/19/14 | 21/18/13 |
| FLUID DEGRADA | TION | method | limit/base | current | history1 | history2 |
| Acid Number (AN) | mg KOH/g | ASTM D974* | 0.06 | 0.05 | 0.04 | 0.08 |
| VISUAL | | method | limit/base | current | history1 | history2 |
| White Metal | scalar | Visual* | NONE | NONE | NONE | NONE |
| Yellow Metal | scalar | Visual* | NONE | NONE | NONE | NONE |
| Precipitate | scalar | Visual* | NONE | NONE | NONE | NONE |
| Silt | scalar | Visual* | NONE | NONE | NONE | NONE |
| Debris | scalar | Visual* | NONE | NONE | NONE | NONE |
| Sand/Dirt | scalar | Visual* | NONE | NONE | NONE | NONE |
| Appearance | scalar | Visual* | NORML | NORML | NORML | NORML |
| Odor | scalar | Visual* | NORML | NORML | NORML | NORML |
| Emulsified Water | scalar | Visual* | >2 | NEG | NEG | NEG |
| Free Water | scalar | Visual* | | NEG | NEG | NEG |
| FLUID PROPERT | IES | method | limit/base | current | history1 | history2 |
| Visc @ 40°C | cSt | ASTM D7279(m) | 100.0 | 97.0 | 97.2 | 97.0 |
| SAMPLE IMAGES | 3 | method | limit/base | current | history1 | history2 |
| Color | | | | 200 | | |
| Bottom | | | | | | |



CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No.

Lab Number : 02622726

: WC0908272

Unique Number : 5747845

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Received : 18 Mar 2024 **Tested** : 22 Mar 2024 Diagnosed : 22 Mar 2024 - Kevin Marson

Test Package: IND 3 (Additional Tests: PRTCOUNT, TAN Man) To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

Validity of results and interpretation are based on the sample and information as supplied.

4 Booth Street Ottawa, ON **CA K1R 6K8**

Contact: Cheryl Gharib info@portagepower.com T:

Portage Power - Energy Ottawa

F: x:




FERROGRAPHY REPORT

Area 2GS Machine Id 2GS


2GS G4 GENERATOR NDE BEARING 1

Bearing

MOBIL TERESSTIC 100 (15 GAL)








| DR-FERROGRAP | HY | method | limit/base | current | history1 | history2 |
|----------------------------|------------|-------------|------------|---------|----------|----------|
| Large Particles | | DR-Ferr* | | 8.7 | 10.1 | 0.4 |
| Small Particles | | DR-Ferr* | | 3.9 | 6.1 | 0.2 |
| Total Particles | | DR-Ferr* | > | 12.6 | 16.2 | 0.6 |
| Large Particles Percentage | % | DR-Ferr* | | 38.1 | 24.7 | 33.3 |
| Severity Index | | DR-Ferr* | | 42 | 40 | 0.1 |
| FERROGRAPHY | | method | limit/base | current | history1 | history2 |
| Ferrous Rubbing | Scale 0-10 | ASTM D7684* | | 3 | 3 | 2 |
| Ferrous Sliding | Scale 0-10 | ASTM D7684* | | | | |
| Ferrous Cutting | Scale 0-10 | ASTM D7684* | | | | |
| Ferrous Rolling | Scale 0-10 | ASTM D7684* | | 1 | 1 | 1 |
| Ferrous Break-in | Scale 0-10 | ASTM D7684* | | | | |
| Ferrous Spheres | Scale 0-10 | ASTM D7684* | | | | |
| Ferrous Black Oxides | Scale 0-10 | ASTM D7684* | | 1 | 1 | 1 |
| Ferrous Red Oxides | Scale 0-10 | ASTM D7684* | | | | |
| Ferrous Corrosive | Scale 0-10 | ASTM D7684* | | | | 1 |
| Ferrous Other | Scale 0-10 | ASTM D7684* | | | | |
| Nonferrous Rubbing | Scale 0-10 | ASTM D7684* | | | | |
| Nonferrous Sliding | Scale 0-10 | ASTM D7684* | | | | |
| Nonferrous Cutting | Scale 0-10 | ASTM D7684* | | | | |
| Nonferrous Rolling | Scale 0-10 | ASTM D7684* | | | | |
| Nonferrous Other | Scale 0-10 | ASTM D7684* | | | | |
| Carbonaceous Material | Scale 0-10 | ASTM D7684* | | | | |
| Lubricant Degradation | Scale 0-10 | ASTM D7684* | | | | |
| Sand/Dirt | Scale 0-10 | ASTM D7684* | | 1 | 1 | 2 |
| Fibres | Scale 0-10 | ASTM D7684* | | | | |
| Spheres | Scale 0-10 | ASTM D7684* | | | | |
| Other | Scale 0-10 | ASTM D7684* | | 1 | 1 | |

WEAR

All component wear rates are normal. The ferrography results are normal indicating no abnormal wear in the system.



This page left intentionally blank