



OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Machine Id
SOLAR WINDSOR SALT
 Component
Turbine
 Fluid
SUMMIT SH-32T (--- GAL)

DIAGNOSIS

Recommendation

This is a baseline read-out on the submitted sample.

Contamination

MPC (Membrane Patch Colorimetry) test indicates acceptable levels of varnish present.




SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			WC0582415	---	---
Sample Date	Client Info			13 Mar 2024	---	---
Machine Age	hrs	Client Info		6	---	---
Oil Age	hrs	Client Info		0	---	---
Oil Changed	Client Info			Filtered	---	---
Sample Status				NORMAL	---	---

CONTAMINATION		method	limit/base	current	history1	history2
Water	WC Method		>0.03	NEG	---	---

FLUID DEGRADATION		method	limit/base	current	history1	history2
MPC Varnish Potential	Scale	ASTM D7843(m)*	>15	4	---	---

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	---	---
Yellow Metal	scalar	Visual*	NONE	NONE	---	---
Precipitate	scalar	Visual*	NONE	NONE	---	---
Silt	scalar	Visual*	NONE	NONE	---	---
Debris	scalar	Visual*	NONE	NONE	---	---
Sand/Dirt	scalar	Visual*	NONE	NONE	---	---
Appearance	scalar	Visual*	NORML	NORML	---	---
Odor	scalar	Visual*	NORML	NORML	---	---

SAMPLE IMAGES

	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image
MPC				no image	no image

MPC (Varnish Test)



Sample Color & Clarity

