


OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Area
WAJAX
Machine Id
DETROIT GD10689B

Component
Diesel Engine
Fluid
DIESEL ENGINE OIL SAE 40 (--- GAL)

DIAGNOSIS

Recommendation

Échantillonner de nouveau l'équipement au prochain intervalle de vidange afin d'en surveiller la condition.

Wear

Les taux d'usure de tous les composants sont normaux.

Contamination

Il n'y a aucun indice de contamination dans l'huile.

Fluid Condition

L'état de l'huile est acceptable pour la durée de service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			WA0020970	GD0005500	---
Sample Date	Client Info			13 Mar 2024	22 Mar 2023	---
Machine Age	hrs	Client Info		1763	1739	---
Oil Age	hrs	Client Info		0	0	---
Oil Changed	Client Info			Changed	Changed	---
Sample Status				NORMAL	NORMAL	---

CONTAMINATION		method	limit/base	current	history1	history2
Fuel	WC Method	>3.0		<1.0	<1.0	---
Water	WC Method	>0.2		NEG	NEG	---
Glycol	WC Method			NEG	NEG	---


WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>200	1	2	---
Chromium	ppm	ASTM D5185(m)	>20	0	0	---
Nickel	ppm	ASTM D5185(m)	>2	0	<1	---
Titanium	ppm	ASTM D5185(m)	>2	0	0	---
Silver	ppm	ASTM D5185(m)	>2	0	0	---
Aluminum	ppm	ASTM D5185(m)	>30	0	<1	---
Lead	ppm	ASTM D5185(m)	>30	0	<1	---
Copper	ppm	ASTM D5185(m)	>30	1	1	---
Tin	ppm	ASTM D5185(m)	>15	0	<1	---
Antimony	ppm	ASTM D5185(m)		0	<1	---
Vanadium	ppm	ASTM D5185(m)		0	0	---
Beryllium	ppm	ASTM D5185(m)		0	0	---
Cadmium	ppm	ASTM D5185(m)		0	0	---

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	250	0	2	---
Barium	ppm	ASTM D5185(m)	10	0	0	---
Molybdenum	ppm	ASTM D5185(m)	100	44	47	---
Manganese	ppm	ASTM D5185(m)		0	<1	---
Magnesium	ppm	ASTM D5185(m)	450	719	754	---
Calcium	ppm	ASTM D5185(m)	3000	772	867	---
Phosphorus	ppm	ASTM D5185(m)	1150	753	867	---
Zinc	ppm	ASTM D5185(m)	1350	866	927	---
Sulfur	ppm	ASTM D5185(m)	4250	2472	2744	---
Lithium	ppm	ASTM D5185(m)		<1	<1	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>30	2	5	---
Sodium	ppm	ASTM D5185(m)	>216	1	2	---
Potassium	ppm	ASTM D5185(m)	>20	<1	0	---

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	ASTM D7844*	>0.8	0	0	---
Nitration	Abs/cm	ASTM D7624*	>20	5.5	4.0	---
Sulfation	Abs./1mm	ASTM D7415*	>30	15.9	15.7	---

OIL ANALYSIS REPORT



FLUID DEGRADATION		method	limit/base	current	history1	history2
-------------------	--	--------	------------	---------	----------	----------

Oxidation	Abs./1mm	ASTM D7414*	>25	11.1	6.5	---
-----------	----------	-------------	-----	-------------	-----	-----

VISUAL		method	limit/base	current	history1	history2
--------	--	--------	------------	---------	----------	----------

Emulsified Water	scalar	Visual*	>0.2	NEG	NEG	---
------------------	--------	---------	------	------------	-----	-----


Free Water	scalar	Visual*		NEG	NEG	---
------------	--------	---------	--	------------	-----	-----

FLUID PROPERTIES		method	limit/base	current	history1	history2
------------------	--	--------	------------	---------	----------	----------

Visc @ 100°C	cSt	ASTM D7279(m)	14.4	14.0	14.3	---
--------------	-----	---------------	------	-------------	------	-----

GRAPHS


Iron (ppm)




Lead (ppm)




Aluminum (ppm)




Chromium (ppm)




Copper (ppm)



Silicon (ppm)



Viscosity @ 100°C



Soot %



ISO 17025:2017
Accredited
Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WA0020970
Lab Number : 02623254
Unique Number : 5748373
Test Package : MOB 1

Received : 20 Mar 2024
Tested : 20 Mar 2024
Diagnosed : 20 Mar 2024 - Kevin Marson

Generatrice Drummond
 243 rue des ARTISANS
 SAINT-GERMAIN-DE-GRANTHAM, QC
 CA J0C 1K0
 Contact: Valerie Poirier
 poiirivalerie@generatricedrummond.com
 T: (819)398-6811
 F: (819)398-7022

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.