

OIL ANALYSIS REPORT

Sample Rating Trend



PBK G UGBR/THBR

Component Bearing

MOBIL DTE OIL HVY MEDIUM (170 LTR)

DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you follow the water drain-off procedure for this component. We recommend an early resample to monitor this condition.

Wear

Copper ppm levels are abnormal. Bearing wear is indicated.

Contamination

Free water present.


Fluid Condition


The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0455749	WC0455716	WC0455746
Sample Date		Client Info		01 Feb 2024	24 May 2023	15 Nov 2022
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	SEVERE	SEVERE
CONTAMINATION	V	method	limit/base	current	history1	history2
Water		WC Method	>2	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184*		0	0	0
Iron	ppm	ASTM D5185(m)	>63	8	8	6
Chromium	ppm	ASTM D5185(m)	>20	0	0	0
Nickel	ppm	ASTM D5185(m)	>20	0	<1	0
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)		0	0	0
Aluminum	ppm	ASTM D5185(m)	>2	0	<1	0
Lead	ppm	ASTM D5185(m)	>161	11	43	57
Copper	ppm	ASTM D5185(m)	>13	<u> </u>	▲ 17	▲ 18
Tin	ppm	ASTM D5185(m)	>27	0	<1	<1
Antimony	ppm	ASTM D5185(m)		0	<1	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	<1	1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		0	0	<1
Barium	ppm	ASTM D5185(m)		0	0	0
Molybdenum	ppm	ASTM D5185(m)		0	0	0
Manganese	ppm	ASTM D5185(m)		0	<1	<1
Magnesium	ppm	ASTM D5185(m)		0	0	0
Calcium	ppm	ASTM D5185(m)		0	0	0
Phosphorus	ppm	ASTM D5185(m)		120	139	130
Zinc	ppm	ASTM D5185(m)		20	28	31
Sulfur	ppm	ASTM D5185(m)		1253	1322	1337
Lithium	ppm	ASTM D5185(m)		<1	<1	<1
CONTAMINANTS	,	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>12	0	<1	<1
Sodium	ppm	ASTM D5185(m)		0	0	<1
Potassium	ppm	ASTM D5185(m)	>20	0	0	<1
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*		0.05	0.05	0.05




OIL ANALYSIS REPORT











VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	VLITE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	▲ WGOIL	▲ WGOIL	▲ WGOIL
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>2	.5%	.2%	1%
Free Water	scalar	Visual*		<u>^</u> 5%	<u>^</u> 5%	<u></u> 5%
FLUID PROPERTIES		method	limit/base	current	history1	history2
I LOID I HOI LITTILO		motriou	minu base	Carrent	riistory i	1113101 y Z


I LOID I NOI LIN	TILO	method	IIIIII/Dase	Current	HISTORY	HISTORYZ
Visc @ 40°C	cSt	ASTM D7279(m)	65.1	64.5	64.2	63.6


SAMPLE IMAGES	method	limit/base	current	history1	history2


Color






















CALA ISO 17025:2017 Accredited Laboratory

Unique Number : 5749450

Laboratory Sample No.

Lab Number : 02624331

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 : WC0455749

Received

: 25 Mar 2024 Tested Diagnosed

: 26 Mar 2024

: 26 Mar 2024 - Kevin Marson

Test Package : IND 2 (Additional Tests: TAN Man)

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

NEWFOUNDLAND POWER INC.

50 DUFFY PLACE, PO BOX 8910 ST. JOHNS, NL CA A1B 3P6

Contact: Paul Martin pmartin@newfoundlandpower.com

F: (709)737-2926

Submitted By: Corey Frizzell

T: