



OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Area
[WC001333-1]
 Machine Id
HUSSMANN RACK E
 Component
Reciprocating Compressor
 Fluid
{not provided} (--- GAL)



DIAGNOSIS

Recommendation
 Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear
 All component wear rates are normal.

Contamination
 The water content is negligible. There is no indication of any contamination in the oil.

Fluid Condition
 The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0794349	---	---
Sample Date	Client Info		12 Feb 2024	---	---
Machine Age	yrs Client Info		0	---	---
Oil Age	yrs Client Info		0	---	---
Oil Changed	Client Info		N/A	---	---
Sample Status			NORMAL	---	---

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*		0	---	---
Iron	ppm ASTM D5185(m)	>50	0	---	---
Chromium	ppm ASTM D5185(m)	>10	0	---	---
Nickel	ppm ASTM D5185(m)		0	---	---
Titanium	ppm ASTM D5185(m)		0	---	---
Silver	ppm ASTM D5185(m)		0	---	---
Aluminum	ppm ASTM D5185(m)	>25	0	---	---
Lead	ppm ASTM D5185(m)	>25	0	---	---
Copper	ppm ASTM D5185(m)	>50	2	---	---
Tin	ppm ASTM D5185(m)	>15	0	---	---
Antimony	ppm ASTM D5185(m)		0	---	---
Vanadium	ppm ASTM D5185(m)		0	---	---
Beryllium	ppm ASTM D5185(m)		0	---	---
Cadmium	ppm ASTM D5185(m)		0	---	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm ASTM D5185(m)		<1	---	---
Barium	ppm ASTM D5185(m)		0	---	---
Molybdenum	ppm ASTM D5185(m)		0	---	---
Manganese	ppm ASTM D5185(m)		0	---	---
Magnesium	ppm ASTM D5185(m)		0	---	---
Calcium	ppm ASTM D5185(m)		0	---	---
Phosphorus	ppm ASTM D5185(m)		1	---	---
Zinc	ppm ASTM D5185(m)		<1	---	---
Sulfur	ppm ASTM D5185(m)		14	---	---
Lithium	ppm ASTM D5185(m)		<1	---	---

CONTAMINANTS




	method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185(m)	>25	0	---	---
Sodium	ppm ASTM D5185(m)		<1	---	---
Potassium	ppm ASTM D5185(m)	>20	0	---	---
Water	% ASTM D6304*	>0.1	0.035	---	---
ppm Water	ppm ASTM D6304*	>1000	359	---	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D974*		0.10	---	---



OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	---
Yellow Metal	scalar	Visual*	NONE	NONE	---
Precipitate	scalar	Visual*	NONE	NONE	---
Silt	scalar	Visual*	NONE	NONE	---
Debris	scalar	Visual*	NONE	NONE	---
Sand/Dirt	scalar	Visual*	NONE	NONE	---
Appearance	scalar	Visual*	NORML	NORML	---
Odor	scalar	Visual*	NORML	NORML	---
Emulsified Water	scalar	Visual*	>0.1	NEG	---
Free Water	scalar	Visual*		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	25.0	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color		no image	no image
Bottom		no image	no image

GRAPHS



ISO 17025:2017
Accredited
Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0794349 **Received** : 26 Mar 2024
Lab Number : 02624691 **Tested** : 26 Mar 2024
Unique Number : 5749810 **Diagnosed** : 27 Mar 2024 - Kevin Marson
Test Package : IND 2 (Additional Tests: KF, TAN Man)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

Neelands Group Limited
 4131 Palladium Way
 Burlington, ON
 CA L7M 0V9
 Contact: Mike Squires
 mike.squires@neelands.com
 T: (905)975-0794
 F: (905)334-7090