



PROBLEM SUMMARY

Sample Rating Trend


VISUAL METAL



Machine Id
11565247 CRUSHER TOGGLE


Component
Hydraulic System

Fluid
SHELL TELLUS 68 (3470 LTR)



COMPONENT CONDITION SUMMARY


▲ Particle Trend



RECOMMENDATION

Check seals and/or filters for points of contaminant entry. We advise that you check for visible metal particles in the oil. Wear particles and/or ppm levels are abnormally high indicating the need to review OEM limits with attention to components that may generate this type of wear. Include all test results and maintenance activities that have been performed since the abnormal condition was first detected in this review. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. An inspection for the source(s) of wear may be warranted at this time. Re-sampling is suggested to confirm test results prior to significant maintenance activities being performed. Please indicate that this is a resample on your Sample Information Form (SIF). Resample in 30-45 days to monitor this situation.

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	ABNORMAL	NORMAL
Particles >4µm		ASTM D7647	>5000	▲ 79226	▲ 19210	2002
Particles >6µm		ASTM D7647	>1300	▲ 8980	▲ 5983	559
Particles >14µm		ASTM D7647	>160	▲ 404	▲ 892	66
Oil Cleanliness		ISO 4406 (c)	>19/17/14	▲ 23/20/16	▲ 21/20/17	18/16/13
White Metal	scalar	Visual*	NONE	▲ LTMOD	NONE	NONE
PrtFilter					no image	no image

Customer Id: INCOOLE
 Sample No.: WC0811773
 Lab Number: 02624780
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Inspect Wear Source	---	---	?	An inspection for the source(s) of wear may be warranted at this time.
Monitor	---	---	?	Wear particles and/or ppm levels are abnormally high indicating the need to review OEM limits with attention to components that may generate this type of wear. Include all test results and maintenance activities that have been performed since the abnormal condition was first detected in this review.
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	Resample in 30-45 days to monitor this situation. Re-sampling is suggested to confirm test results prior to significant maintenance activities being performed. Please indicate that this is a resample on your Sample Information Form (SIF).
Alert	---	---	?	Wear particles and/or ppm levels are abnormally high indicating the need to review OEM limits with attention to components that may generate this type of wear. Include all test results and maintenance activities that have been performed since the abnormal condition was first detected in this review.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check For Visual Metal	---	---	?	We advise that you check for visible metal particles in the oil.
Check Seals	---	---	?	Check seals and/or filters for points of contaminant entry.

HISTORICAL DIAGNOSIS

11 Oct 2023 Diag: Wes Davis

ISO



We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a moderate amount of particulates (2 to 100 microns in size) present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



13 Sep 2023 Diag: Wes Davis

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



16 May 2023 Diag: Kevin Marson

ISO



We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Confirm the source of the lubricant being utilized for top-up/fill. Resample in 30-45 days to monitor this situation. All component wear rates are normal. There is a high amount of particulates (2 to 100 microns in size) present in the oil. Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



VISUAL METAL



Machine Id
11565247 CRUSHER TOGGLE

Component
Hydraulic System

Fluid
SHELL TELLUS 68 (3470 LTR)

DIAGNOSIS

▲ Recommendation

Check seals and/or filters for points of contaminant entry. We advise that you check for visible metal particles in the oil. Wear particles and/or ppm levels are abnormally high indicating the need to review OEM limits with attention to components that may generate this type of wear. Include all test results and maintenance activities that have been performed since the abnormal condition was first detected in this review. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. An inspection for the source(s) of wear may be warranted at this time. Re-sampling is suggested to confirm test results prior to significant maintenance activities being performed. Please indicate that this is a resample on your Sample Information Form (SIF). Resample in 30-45 days to monitor this situation.

▲ Wear

Moderate concentration of visible metal present.


▲ Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

Particle Filter (Magn: 100 x)



SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0811773	WC0811802	WC0754994
Sample Date	Client Info		29 Feb 2024	11 Oct 2023	13 Sep 2023
Machine Age	mths	Client Info	0	0	0
Oil Age	mths	Client Info	0	0	0
Oil Changed	Client Info		N/A	Not Changd	N/A
Sample Status			SEVERE	ABNORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.05	NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m) >20	13	7	0
Chromium	ppm	ASTM D5185(m) >20	4	1	0
Nickel	ppm	ASTM D5185(m) >20	0	<1	<1
Titanium	ppm	ASTM D5185(m)	0	0	0
Silver	ppm	ASTM D5185(m)	0	<1	<1
Aluminum	ppm	ASTM D5185(m) >20	<1	<1	0
Lead	ppm	ASTM D5185(m) >20	0	2	0
Copper	ppm	ASTM D5185(m) >20	3	4	<1
Tin	ppm	ASTM D5185(m) >20	0	0	0
Antimony	ppm	ASTM D5185(m)	0	0	0
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	<1	3	<1
Barium	ppm	ASTM D5185(m)	0	<1	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0
Manganese	ppm	ASTM D5185(m)	0	0	0
Magnesium	ppm	ASTM D5185(m) 11	63	75	69
Calcium	ppm	ASTM D5185(m) 39	12	15	9
Phosphorus	ppm	ASTM D5185(m) 260	277	320	283
Zinc	ppm	ASTM D5185(m) 279	346	389	350
Sulfur	ppm	ASTM D5185(m) 2109	646	772	662
Lithium	ppm	ASTM D5185(m)	<1	<1	<1

CONTAMINANTS





	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >15	0	<1	0
Sodium	ppm	ASTM D5185(m)	<1	<1	<1
Potassium	ppm	ASTM D5185(m) >20	<1	0	20

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	▲ 79226	▲ 19210	2002
Particles >6µm	ASTM D7647	>1300	▲ 8980	▲ 5983	559
Particles >14µm	ASTM D7647	>160	▲ 404	▲ 892	66
Particles >21µm	ASTM D7647	>40	● 59	▲ 223	14
Particles >38µm	ASTM D7647	>10	1	8	0
Particles >71µm	ASTM D7647	>3	0	1	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	▲ 23/20/16	▲ 21/20/17	18/16/13



OIL ANALYSIS REPORT



FLUID DEGRADATION	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974*	0.37	0.48	0.36	0.35

VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	▲ LTMOD	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.05	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	69.43	63.4	64.0	65.5

SAMPLE IMAGES	method	limit/base	current	history1	history2	
Color						
Bottom						
PrtFilter					no image	no image



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0811773
Lab Number : **02624780**
Unique Number : 5749899
Test Package : IND 2 (Additional Tests: Bottom, BottomAnalysis, FilterPatch, PrtFilter, TAN Mar

Vale - Coleman Mine
 COLEMAN MINE (PLANT 10), 117 Mine Road
 LEVACK, ON
 CA P0M 2C0
 Contact: Ryan Davies
 ryan.davies@vale.com
 T: (705)682-8952
 F: (705)966-4114

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.