




OIL ANALYSIS REPORT



Machine Id
LIDM04BE (S/N GZJ00279)
 Component
Biogas Engine
 Fluid
CHEVRON HDAX 9500 GAS ENGINE OIL 40 (540 LTR)

Sample Rating Trend



PH



DIAGNOSIS

▲ Recommendation

Nous avons pris note que la vidange d'huile a été effectuée au moment de l'échantillonnage. Échantillonner de nouveau l'équipement au prochain intervalle de vidange afin d'en surveiller la condition.

Wear

Les taux d'usure de tous les composants sont normaux.

Contamination

Il n'y a aucun indice de contamination dans l'huile.

▲ Fluid Condition

Le niveau de i-pH est anormalement bas. Le niveau de AN est supérieur à la limite recommandée. Le niveau de BN est inférieur à la normale. l'huile ne peut plus être utilisée.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0904329	WC0904341	WC0904359
Sample Date	Client Info		25 Mar 2024	18 Mar 2024	11 Mar 2024
Machine Age	hrs	Client Info	49770	49603	49477
Oil Age	hrs	Client Info	472	305	179
Oil Changed	Client Info		Changed	Not Changd	Not Changd
Sample Status			ABNORMAL	ABNORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Water	WC Method	>0.1	NEG	NEG	NEG
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>15	10	9	7
Chromium	ppm	ASTM D5185(m)	>4	0	0	0
Nickel	ppm	ASTM D5185(m)	>2	0	0	<1
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)	>5	0	0	0
Aluminum	ppm	ASTM D5185(m)	>6	4	3	3
Lead	ppm	ASTM D5185(m)	>9	0	<1	0
Copper	ppm	ASTM D5185(m)	>6	2	2	1
Tin	ppm	ASTM D5185(m)	>4	1	2	1
Antimony	ppm	ASTM D5185(m)		2	2	1
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)		4	4	4
Barium	ppm	ASTM D5185(m)		0	0	0
Molybdenum	ppm	ASTM D5185(m)		<1	1	1
Manganese	ppm	ASTM D5185(m)		0	0	0
Magnesium	ppm	ASTM D5185(m)		13	13	13
Calcium	ppm	ASTM D5185(m)		1798	1827	1738
Phosphorus	ppm	ASTM D5185(m)		248	260	253
Zinc	ppm	ASTM D5185(m)		310	306	299
Sulfur	ppm	ASTM D5185(m)		3144	3284	2955
Lithium	ppm	ASTM D5185(m)		<1	<1	<1

CONTAMINANTS




	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>181	87	78	59
Sodium	ppm	ASTM D5185(m)		<1	<1	<1
Potassium	ppm	ASTM D5185(m)	>20	1	1	3

INFRA-RED

	method	limit/base	current	history1	history2	
Soot %	%	ASTM D7844*		0	0	0
Nitration	Abs/cm	ASTM D7624*	>20	5.6	5.5	5.4
Sulfation	Abs./1mm	ASTM D7415*	>30	26.1	23.5	21.8



OIL ANALYSIS REPORT











FLUID DEGRADATION	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	ASTM D7414*	>25	15.2	13.3	11.9
Acid Number (AN)	mg KOH/g	ASTM D974*	1.1	▲ 3.70	▲ 4.03	2.84
Base Number (BN)	mg KOH/g	ASTM D2896*	5.4	▲ 2.30	▲ 2.41	3.06
i-pH	Scale 0-14	ASTM D7946*	<4.5	▲ 3.51	▲ 4.23	4.55

VISUAL	method	limit/base	current	history1	history2	
Emulsified Water	scalar	Visual*	>0.1	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D7279(m)	13.4	13.5	13.4

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0904329 **Received** : 27 Mar 2024
Lab Number : 02624927 **Tested** : 28 Mar 2024
Unique Number : 5750046 **Diagnosed** : 28 Mar 2024 - Kevin Marson
Test Package : MOB 2 (Additional Tests: i-pH, TAN Auto, TAN Man)

EDL NA Recips-Lydia
 6985 CHEMIN DES SOURCES
 LACHUTE, QC
 CA J8H 2C5
 Contact: Eloi Legault
 eloi.legault@energydi.com
 T: (450)526-4001
 F:

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.