

OIL ANALYSIS REPORT

SAB2 SAB2 G11 Governor

Hydraulic System

ESSO TERESSO ISO 46 (6160 LTR)

·····

Sample Rating Trend



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.

Component wear rates appear to be normal (unconfirmed).

Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

v/2014 Ju2015 Jan2017 Apr2018 Ju2019 Nov2020 Feb2022 Jun2023										
SAMPLE INFORM	MOITAN	method	limit/base	current	history1	history2				
Sample Number		Client Info		WC0890824	WC0801599	WC0858056				
Sample Date		Client Info		27 Mar 2024	07 Jan 2024	25 Oct 2023				
Machine Age	hrs	Client Info		0	0	0				
Oil Age	hrs	Client Info		0	0	0				
Oil Changed		Client Info		N/A	N/A	N/A				
Sample Status				NORMAL	NORMAL	NORMAL				
CONTAMINATION	١	method	limit/base	current	history1	history2				
Water		WC Method	>0.05	NEG	NEG	NEG				
WEAR METALS		method	limit/base	current	history1	history2				
Iron	ppm	ASTM D5185(m)	>20	<1	<1	<1				
Chromium	ppm	ASTM D5185(m)	>20	0	0	0				
Nickel	ppm	ASTM D5185(m)	>20	0	<1	<1				
Titanium	ppm	ASTM D5185(m)		0	0	0				
Silver	ppm	ASTM D5185(m)		0	0	<1				
Aluminum	ppm	ASTM D5185(m)	>20	0	<1	0				
Lead	ppm	ASTM D5185(m)	>20	0	<1	<1				
Copper	ppm	ASTM D5185(m)	>20	0	0	<1				
Tin	ppm	ASTM D5185(m)	>20	0	0	0				
Antimony	ppm	ASTM D5185(m)		0	0	0				
Vanadium	ppm	ASTM D5185(m)		0	0	0				
Beryllium	ppm	ASTM D5185(m)		0	0	0				
Cadmium	ppm	ASTM D5185(m)		0	0	0				
ADDITIVES		method	limit/base	current	history1	history2				
Boron	ppm	ASTM D5185(m)	0	0	0	<1				
Barium	ppm	ASTM D5185(m)		0	0	<1				
Molybdenum	ppm	ASTM D5185(m)	0	0	0	0				
Manganese	ppm	ASTM D5185(m)		0	0	0				
Magnesium	ppm	ASTM D5185(m)	0	0	0	0				
Calcium	ppm	ASTM D5185(m)	0	0	0	<1				
Phosphorus	ppm	ASTM D5185(m)	2.4	1	<1	1				
Zinc	ppm	ASTM D5185(m)	0	<1	<1	<1				
Sulfur	ppm	ASTM D5185(m)		1790	1946	1841				
Lithium	ppm	ASTM D5185(m)		<1	<1	<1				
CONTAMINANTS		method	limit/base	current	history1	history2				
Silicon	ppm	ASTM D5185(m)	>15	0	0	0				
Sodium	ppm	ASTM D5185(m)		0	0	0				
Potassium	ppm	ASTM D5185(m)	>20	<1	<1	0				
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2				
Particles >4µm		ASTM D7647	>2500	368	314	2025				
Particles >6µm		ASTM D7647	>640	144	112	545				
Particles >14µm		ASTM D7647	>80	17	14	32				
Particles >14µm Particles >21µm		ASTM D7647 ASTM D7647	>80 >20	17 3	14	32 8				
Particles >21μm		ASTM D7647	>20 >4	3	4	8				

ISO 4406 (c) >18/16/13


16/14/11


15/14/11


Oil Cleanliness




OIL ANALYSIS REPORT









FLUID DEGRADA	method				history2		
Acid Number (AN) mg KOH/g		ASTM D974*	0.02	0.06	0.06	0.09	
VISUAL		method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE	
Yellow Metal scalar		Visual*	NONE NONE		NONE	NONE	
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE	
Silt	scalar	Visual*	NONE	NONE	NONE	NONE	
Debris	scalar	Visual*	NONE	NONE	NONE	NONE	
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE	
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML	
Odor scalar		Visual*	NORML	NORML	NORML	NORML	
Emulsified Water	scalar	Visual*	>0.05	NEG	NEG	NEG	
Free Water	scalar	Visual*		NEG	NEG	NEG	
FLUID PROPERT	TES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	46	45.4	45.6	45.5	
SAMPLE IMAGES	method	limit/base	limit/base current history1		history2		
			100				

Ferr	ous A	Alloys	;					Par	ticle	Coun	t				
7222								491,520							
	annan chi	omium						122,880							
*****	wwwww Dic	kel	441					30,720 Severe							
4	15	17	18	119	20	22	23	₹ 7,680	44						-
May1/14	Jul15/15	Jan 10/17	Apr13/18	Jul29/19	Nov11/20	Feb8/22	Jun5/23	7,680 Abnormal 1,920 480	mal	1					
Non-			1etals					480			``				
2222		oper 1						D 120	\	1					
	aaaaaa lea							120 - 120 -							
	1 1 1 1	42 ⁹ 293-02		North L				8+			/	\			
4	-	desired to the same	Street, or other Designation of the last o	Jul29/19	1/20	Feb 8/22	Jun5/23	2+					\		
May1/14	Jul15/15	Jan10/17	Apr13/18	Jul2	Nov11/20	율	Jun	0							
Visc	osity	@ 40	0°C					- Aci	6). d Nui	, mber	14μ	21 _µ	t i	38μ	71
Abnor	mal							No. 1.50 Seve							
Base								Acid Number (mg KOH/g)	ormal						
Abnor	mal				12.1			0.50 - Base		00013			1111	10000000	1111
May1/14	Jul15/15	117	Apr13/18	Jul29/19 +	720	Feb 8/22 -	Jun5/23 +	Acid 00.00 May1/14	Jul15/15	77	Apr13/18	Jul29/19	720	Feb 8/22	Jun5/23
5	5	Jan 10/17	113	129	Nov11/20	ep 8	Sur S	ay1	115	Jan 10/17	113	129	Nov11/20	698	un5,



CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No. Lab Number : 02625206 Unique Number : 5750325

: WC0890824

Test Package : IND 2 (Additional Tests: TAN Man)

Color

Bottom

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Received

: 28 Mar 2024 **Tested** Diagnosed

: 01 Apr 2024

: 01 Apr 2024 - Kevin Marson

NIAGARA PLANT GROUP,, 14000 NIAGARA PKWY NIAGARA ON THE LAKE, ON CA LOS 1J0

Contact: Michael Brochu mike.brochu@opg.com T: (905)357-0322

Ontario Power Generation

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

F: (905)374-5466