


OIL ANALYSIS REPORT

29 AIR COMPRESSORS Sullair Air Compressor #5 (S/N 295114)

Air Compressor

SULLAIR SULLUBE (23 GAL)





DIAGNOSIS

Recommendation

We recommend that you drain the oil from the component if this has not already been done. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The water content is negligible. There is no indication of any contamination in the oil.


Fluid Condition

The AN level is above the recommended limit. The oil viscosity is higher than normal. Viscosity of sample indicates oil is within ISO 46 range, advise investigate. The oil is no longer serviceable.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		wc		
Sample Date		Client Info		21 Mar 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184*		0		
Iron	ppm	ASTM D5185(m)	>50	1		
Chromium	ppm	ASTM D5185(m)	>4	0		
Nickel	ppm	ASTM D5185(m)	>4	0		
Titanium	ppm	ASTM D5185(m)		0		
Silver	ppm	ASTM D5185(m)		0		
Aluminum	ppm	ASTM D5185(m)	>10	<1		
Lead	ppm	ASTM D5185(m)	>20	0		
Copper	ppm	ASTM D5185(m)	>40	4		
Tin	ppm	ASTM D5185(m)	>5	0		
Antimony	ppm	ASTM D5185(m)		0		
Vanadium	ppm	ASTM D5185(m)		0		
Beryllium	ppm	ASTM D5185(m)		0		
Cadmium	ppm	ASTM D5185(m)		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	12	<1		
Barium	ppm	ASTM D5185(m)	500	753		
Molybdenum	ppm	ASTM D5185(m)	0.0	0		
Manganese	ppm	ASTM D5185(m)		0		
Magnesium	ppm	ASTM D5185(m)	0.0	1		
Calcium	ppm	ASTM D5185(m)	8.2	4		
Phosphorus	ppm	ASTM D5185(m)	4.0	0		
Zinc	ppm	ASTM D5185(m)	0.1	22		
Sulfur	ppm	ASTM D5185(m)	240	363		
Lithium	ppm	ASTM D5185(m)		<1		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>25	0		
Sodium	ppm	ASTM D5185(m)		87		
Potassium	ppm	ASTM D5185(m)	>20	13		
Water	%	ASTM D6304*	>0.6	0.118		
ppm Water	ppm	ASTM D6304*	>6000	1186		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
	mg KOH/g	ASTM D974*		1.49		



OIL ANALYSIS REPORT





CALA ISO 17025:2017 Accredited

Laboratory

Sample No. Lab Number

: WC

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 : 02625723

Tested Unique Number : 5750842 Diagnosed Test Package: IND 2 (Additional Tests: KF, TAN Man)

Received : 01 Apr 2024 : 03 Apr 2024

: 03 Apr 2024 - Kevin Marson

AV GROUP NB INC. 103 PINDER ROAD,, NACKAWIC MILL NACKAWIC, NB **CA E6G 1W4**

Contact: Jeremy Sharp Jeremy.Sharp@adityabirla.com

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

T: F: