


## **OIL ANALYSIS REPORT**

Sample Rating Trend



NORMAL



# MANITOU 732 FOR411

Component

**Front Right Planetary** 

SAE 80W90 (--- GAL)

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the

### **Fluid Condition**

The condition of the oil is acceptable for the time in service.

				Mar2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0902364		
Sample Date		Client Info		23 Mar 2024		
Machine Age	hrs	Client Info		10755		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATION	V	method	limit/base	current	history1	history2
Water		WC Method	>0.2	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>500	252		
Chromium	ppm	ASTM D5185(m)	>10	2		
Nickel	ppm	ASTM D5185(m)	>10	0		
Titanium	ppm	ASTM D5185(m)		1		
Silver	ppm	ASTM D5185(m)		0		
Aluminum	ppm	ASTM D5185(m)	>25	10		
Lead	ppm	ASTM D5185(m)	>25	11		
Copper	ppm	ASTM D5185(m)	>75	499		
Tin	ppm	ASTM D5185(m)	>10	0		
Antimony	ppm	ASTM D5185(m)	>5	0		
Vanadium	ppm	ASTM D5185(m)		0		
Beryllium	ppm	ASTM D5185(m)		0		
Cadmium	ppm	ASTM D5185(m)		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	200	210		
Barium	ppm	ASTM D5185(m)	0	<1		
Molybdenum	ppm	ASTM D5185(m)	0	0		
Manganese	ppm	ASTM D5185(m)		1		
Magnesium	ppm	ASTM D5185(m)	0	6		
Calcium	ppm	ASTM D5185(m)	20	758		
Phosphorus	ppm	ASTM D5185(m)	1000	990		
Zinc	ppm	ASTM D5185(m)	20	584		
Sulfur	ppm	ASTM D5185(m)	22000	13520		
Lithium	ppm	ASTM D5185(m)		<1		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>75	56		
Sodium	ppm	ASTM D5185(m)	>50	4		


ASTM D5185(m) >20

ppm

Potassium



### **OIL ANALYSIS REPORT**





CALA ISO 17025:2017 Accredited

Laboratory

Laboratory Sample No.

Lab Number : 02625755 Unique Number : 5750874 Test Package : MOB 1

: WC0902364 Received **Tested** 

Diagnosed

: 01 Apr 2024 : 01 Apr 2024

: 02 Apr 2024 - Kevin Marson

1350 Government Rd. W, MACASSA COMPLEX Kirkland Lake, ON

CA P2N 3J1 Contact: Mitch Lamontagne

 $AEM\_KL\_macassao il samplere sults@agnico eagle.com$ T: (705)567-5208

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

F: (705)567-5221 Contact/Location: Mitch Lamontagne - KIR370KIR