


OIL ANALYSIS REPORT



CIBC 81 Bay St Ch#4 [GTT224-342] **YORK SLFM209870**

Componer Chiller

YORK TYPE K (--- GAL)





DIAGNOSIS

Recommendation

If not recently done change any filter driers to reduce moisture level. We recommend an early resample to monitor this condition.

All component wear rates are normal.

Contamination

The elevated moisture content is associated with POE oils which are hygroscopic, and can absorb moisture from sampling and processing.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jul2021	Jan 2022 Jul 2022	Apr2023 Nov2023	Mar2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		GTT0000674	GTT0000820	GTT67530
Sample Date		Client Info		15 Mar 2024	07 Nov 2023	03 Apr 2023
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ATTENTION	NORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>8	2	3	2
Chromium	ppm	ASTM D5185(m)	>2	0	0	<1
Nickel	ppm	ASTM D5185(m)		0	<1	
Titanium	ppm	ASTM D5185(m)		0	0	
Silver	ppm	ASTM D5185(m)	>2	0	<1	
Aluminum	ppm	ASTM D5185(m)	>3	0	<1	<1
Lead	ppm	ASTM D5185(m)	>2	0	<1	<1
Copper	ppm	ASTM D5185(m)	>8	<1	<1	<1
Tin	ppm	ASTM D5185(m)	>4	0	0	<1
Antimony	ppm	ASTM D5185(m)		0	0	
Vanadium	ppm	ASTM D5185(m)		0	0	
Beryllium	ppm	ASTM D5185(m)		0	0	
Cadmium	ppm	ASTM D5185(m)		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	<1	<1	
Barium	ppm	ASTM D5185(m)	0	<1	<1	
Molybdenum	ppm	ASTM D5185(m)	0	0	0	
Manganese	ppm	ASTM D5185(m)	0	0	0	
Magnesium	ppm	ASTM D5185(m)	0	0	0	
Calcium	ppm	ASTM D5185(m)	0	0	<1	
Phosphorus	ppm	ASTM D5185(m)	5	0	0	
Zinc	ppm	ASTM D5185(m)	0	<1	<1	<1
Sulfur	ppm	ASTM D5185(m)	10	7	5	
Lithium	ppm	ASTM D5185(m)		<1	<1	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>15	1	4	
Sodium	ppm	ASTM D5185(m)		<1	2	
Potassium	ppm	ASTM D5185(m)	>20	<1	1	
ppm Water	ppm	ASTM D6304*	>300	444	261	357
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.03	0.01	0.02	0.005



OIL ANALYSIS REPORT

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	
Precipitate	scalar	Visual*	NONE	NONE	NONE	
Silt	scalar	Visual*	NONE	NONE	NONE	
Debris	scalar	Visual*	NONE	NONE	NONE	
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	
Appearance	scalar	Visual*	NORML	NORML	NORML	
Odor	scalar	Visual*	NORML	NORML	NORML	
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	32.0	34.6	30.0	
SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						no image
Bottom						no image



 Sample No.
 : GTT0000674
 Received
 : 01 Apr 2024

 Lab Number
 : 02625901
 Tested
 : 04 Apr 2024

 Unique Number
 : 5759033
 Diagnosed
 : 04 Apr 2024

Unique Number : 5759033 Diagnosed : 04 Apr 2024 - Bill Quesnel Test Package : IND 2 (Additional Tests: KV40)

To discuss this sample report, contact Customer Service at 1-905-847-9300 Ext 26.

Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

Damages: Seller shall in no event be liable for special, incidental, or consequential damages, of a commercial nature, resulting from any cause.

Johnson Controls - Markham

Accounts Payable A-33, P.O. Box 2012

Milwaukee, WI US 532012012

Contact: Service Manager

T:

F: