



OIL ANALYSIS REPORT

Sample Rating Trend

WATER



Area
Green Wood Ch#1 Circ 2 [GTT224-343]
 Machine Id
TRANE U14H00031(1,2)
 Component
Chiller
 Fluid
COMP OIL (POE) ISO 68 (--- GAL)



DIAGNOSIS

Recommendation

If not recently done change any filter driers to reduce moisture level. We recommend an early resample to monitor this condition. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

The elevated moisture content is associated with POE oils which are hygroscopic, and can absorb moisture from sampling and processing.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	GTT0002017	---	---
Sample Date	Client Info	14 Mar 2024	---	---
Machine Age	hrs Client Info	0	---	---
Oil Age	hrs Client Info	0	---	---
Oil Changed	Client Info	N/A	---	---
Sample Status		ATTENTION	---	---

WEAR METALS

method	limit/base	current	history1	history2
Iron ppm ASTM D5185(m)	>8	7	---	---
Chromium ppm ASTM D5185(m)	>2	0	---	---
Nickel ppm ASTM D5185(m)		0	---	---
Titanium ppm ASTM D5185(m)		0	---	---
Silver ppm ASTM D5185(m)	>2	0	---	---
Aluminum ppm ASTM D5185(m)	>3	0	---	---
Lead ppm ASTM D5185(m)	>2	0	---	---
Copper ppm ASTM D5185(m)	>8	0	---	---
Tin ppm ASTM D5185(m)	>4	2	---	---
Antimony ppm ASTM D5185(m)		0	---	---
Vanadium ppm ASTM D5185(m)		0	---	---
Beryllium ppm ASTM D5185(m)		0	---	---
Cadmium ppm ASTM D5185(m)		0	---	---

ADDITIVES

method	limit/base	current	history1	history2
Boron ppm ASTM D5185(m)	5	7	---	---
Barium ppm ASTM D5185(m)	5	0	---	---
Molybdenum ppm ASTM D5185(m)	5	0	---	---
Manganese ppm ASTM D5185(m)		0	---	---
Magnesium ppm ASTM D5185(m)	5	0	---	---
Calcium ppm ASTM D5185(m)	5	0	---	---
Phosphorus ppm ASTM D5185(m)	400	<1	---	---
Zinc ppm ASTM D5185(m)	5	19	---	---
Sulfur ppm ASTM D5185(m)	100	3	---	---
Lithium ppm ASTM D5185(m)		<1	---	---

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon ppm ASTM D5185(m)	>15	4	---	---
Sodium ppm ASTM D5185(m)		0	---	---
Potassium ppm ASTM D5185(m)	>20	1	---	---
ppm Water ppm ASTM D6304*	>300	332	---	---



FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g ASTM D974*	0.40	0.26	---	---

OIL ANALYSIS REPORT

VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	NONE	---	---
Yellow Metal	scalar	Visual*	NONE	NONE	---	---
Precipitate	scalar	Visual*	NONE	NONE	---	---
Silt	scalar	Visual*	NONE	NONE	---	---
Debris	scalar	Visual*	NONE	NONE	---	---
Sand/Dirt	scalar	Visual*	NONE	NONE	---	---
Appearance	scalar	Visual*	NORML	NORML	---	---
Odor	scalar	Visual*	NORML	NORML	---	---

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	68	64.5	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image

GRAPHS



Sample No. : GTT0002017
Lab Number : 02625913
Unique Number : 5759045
Test Package : IND 2 (Additional Tests: KV40)

Received : 01 Apr 2024
Tested : 04 Apr 2024
Diagnosed : 04 Apr 2024 - Bill Quesnel

To discuss this sample report, contact Customer Service at 1-905-847-9300 Ext 26.

Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

Damages: Seller shall in no event be liable for special, incidental, or consequential damages, of a commercial nature, resulting from any cause.

General Refrigeration

CA
 Contact: Service Manager
 bcrooks@general-refrigeration.ca
 T:
 F: