




# CLEANLINESS TEST REPORT

## Sample Rating Trend

**NORMAL**



Area  
**[651003-0014]**  
 Part Number  
**AT503300**  
 Component  
**Hose Assembly**  
 Fluid  
**KEROSENE (695 mL)**

### DIAGNOSIS

#### Recommendation

This is a baseline read-out on the submitted sample. The hose or hose assembly fluid sample for analysis was collected in accordance with ISO/TS 18409 : Hydraulic fluid power - Methods of collecting a fluid sample for analysing the cleanliness of a hose or hose assembly.

#### Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. Cleanliness as per JDS-G169 Fluid Cleanliness Class 5.4 (ISO 4406 --/20/15).

### SAMPLE INFORMATION

| method        | limit/base  | current            | history1    | history2 |
|---------------|-------------|--------------------|-------------|----------|
| Sample Number | Client Info | <b>PH</b>          | PH          | ---      |
| Sample Date   | Client Info | <b>01 Apr 2024</b> | 05 Feb 2024 | ---      |
| Machine Age   | hrs         | <b>0</b>           | 0           | ---      |
| Oil Age       | hrs         | <b>0</b>           | 0           | ---      |
| Oil Changed   | Client Info | <b>N/A</b>         | N/A         | ---      |
| Sample Status |             | <b>NORMAL</b>      | ABNORMAL    | ---      |

### CONTAMINATION

| method | limit/base | current    | history1 | history2 |
|--------|------------|------------|----------|----------|
| Water  | WC Method  | <b>NEG</b> | NEG      | ---      |

### FLUID CLEANLINESS


| method          | limit/base             | current         | history1   | history2 |
|-----------------|------------------------|-----------------|------------|----------|
| Particles >4µm  | ASTM D7647             | <b>6166</b>     | 64805      | ---      |
| Particles >6µm  | ASTM D7647 >10000      | <b>1805</b>     | ▲ 31494    | ---      |
| Particles >14µm | ASTM D7647 >320        | <b>119</b>      | ▲ 1913     | ---      |
| Particles >21µm | ASTM D7647 >80         | <b>25</b>       | ▲ 399      | ---      |
| Particles >38µm | ASTM D7647 >20         | <b>2</b>        | 18         | ---      |
| Particles >71µm | ASTM D7647 >4          | <b>0</b>        | 1          | ---      |
| Oil Cleanliness | ISO 4406 (c) >--/20/15 | <b>20/18/14</b> | ▲ 23/22/18 | ---      |

### VISUAL

| method       | limit/base     | current      | history1 | history2 |
|--------------|----------------|--------------|----------|----------|
| White Metal  | scalar Visual* | <b>NONE</b>  | NONE     | ---      |
| Yellow Metal | scalar Visual* | <b>NONE</b>  | NONE     | ---      |
| Precipitate  | scalar Visual* | <b>NONE</b>  | NONE     | ---      |
| Silt         | scalar Visual* | <b>NONE</b>  | NONE     | ---      |
| Debris       | scalar Visual* | <b>NONE</b>  | NONE     | ---      |
| Sand/Dirt    | scalar Visual* | <b>NONE</b>  | NONE     | ---      |
| Appearance   | scalar Visual* | <b>NORML</b> | NORML    | ---      |
| Odor         | scalar Visual* | <b>NORML</b> | NORML    | ---      |


### SAMPLE IMAGES

| method    | limit/base | current | history1 | history2 |
|-----------|------------|---------|----------|----------|
| Color     |            |         |          | no image |
| Bottom    |            |         |          | no image |
| PrtFilter |            |         |          | no image |






# CLEANLINESS TEST REPORT



## GRAPHS



ISO 17025:2017  
Accredited  
Laboratory

**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : PH  
**Lab Number** : 02625936  
**Unique Number** : 5759068  
**Test Package** : TEST ( Additional Tests: PrtCount, PrtFilter, PrtFilterPic )

**Received** : 02 Apr 2024  
**Tested** : 02 Apr 2024  
**Diagnosed** : 02 Apr 2024 - Bill Quesnel

**PARKER HANNIFIN CANADA**  
 160 CHISHOLM DRIVE  
 MILTON, ON  
 CA L9T 3G9  
 Contact: Tom Raznatovic  
 tomislav.raznatovic@parker.com

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

T:  
F: