




# PROBLEM SUMMARY

Area  
**5 Utilities/030 Boiler House/B Blower/Fan/713 #13 FD East**  
 Machine Id  
**N/A 30TB713**  
 Component  
**Turbine**  
 Fluid  
**PETRO CANADA TURBOFLO 68 (20 LTR)**

Sample Rating Trend




ISO




## COMPONENT CONDITION SUMMARY

▲ Particle Trend



▲ Water (KF)



## RECOMMENDATION

Check seals and/or filters for points of contaminant entry. We advise that you check all areas where contaminants can enter the system. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample in 30-45 days to monitor this situation. We suspect that the abnormal contaminant(s) is the result of incorrect sampling technique. **DISCLAIMER:** Interpretation of results is based on the sample as received from the customer. The condition of the sample and the method of sampling cannot be verified.

## PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	SEVERE	SEVERE
Water	%	ASTM D6304*	>0.03	▲ 0.054	▲ 0.147	0.003
ppm Water	ppm	ASTM D6304*	>300	▲ 543	▲ 1475	28.4
Particles >4µm		ASTM D7647	>2500	▲ 63702	▲ 52536	▲ 24425
Particles >6µm		ASTM D7647	>640	▲ 16503	▲ 11620	▲ 8264
Particles >14µm		ASTM D7647	>80	▲ 614	▲ 194	▲ 985
Particles >21µm		ASTM D7647	>20	▲ 96	● 30	▲ 304
Oil Cleanliness		ISO 4406 (c)	>18/16/13	▲ 23/21/16	▲ 23/21/15	▲ 22/20/17
Debris	scalar	Visual*	NONE	▲ LIGHT	NONE	NONE
Appearance	scalar	Visual*	NORML	▲ HAZY	▲ HAZY	▲ WGOIL
Emulsified Water	scalar	Visual*	>0.03	▲ .2%	▲ .5%	.2%

Customer Id: PETMIS  
 Sample No.: WC0925273  
 Lab Number: 02626054  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
 Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Alert	---	---	?	We suspect that the abnormal contaminant(s) is the result of incorrect sampling technique. DISCLAIMER: Interpretation of results is based on the sample as received from the customer. The condition of the sample and the method of sampling cannot be verified.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Dirt Access	---	---	?	We advise that you check all areas where contaminants can enter the system.
Check Seals	---	---	?	Check seals and/or filters for points of contaminant entry.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

## HISTORICAL DIAGNOSIS

### 05 Jan 2024 Diag: Bill Quesnel

WATER



We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. We advise that you follow the water drain-off procedure for this component. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. There is a high concentration of water present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



### 02 Nov 2023 Diag: Kevin Marson

ISO



We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. Copper ppm levels are abnormal. There is a high amount of particulates (2 to 100 microns in size) present in the oil. The water content is negligible. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

view report



### 07 Sep 2022 Diag: Kevin Marson

ISO



We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We advise that you follow the water drain-off procedure for this component. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Particles >6µm are severely high. Oil Cleanliness are severely high. Particles >4µm are severely high. Particles >4µm are severely high. ppm Water and water, water and water contamination levels are abnormal. Particles >14µm are notably high. There is a moderate concentration of water present in the oil. Free water present. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area  
**5 Utilities/030 Boiler House/B Blower/Fan/713 #13 FD East**  
Machine Id  
**N/A 30TB713**  
Component  
**Turbine**  
Fluid  
**PETRO CANADA TURBOFLO 68 (20 LTR)**

## DIAGNOSIS

### ▲ Recommendation

Check seals and/or filters for points of contaminant entry. We advise that you check all areas where contaminants can enter the system. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample in 30-45 days to monitor this situation. We suspect that the abnormal contaminant(s) is the result of incorrect sampling technique. **DISCLAIMER:** Interpretation of results is based on the sample as received from the customer. The condition of the sample and the method of sampling cannot be verified.

### Wear

All component wear rates are normal.

### ▲ Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the oil. There is a moderate concentration of water present in the oil. Light concentration of visible dirt/debris present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0925273</b>	WC0894084	WC0831865
Sample Date	Client Info		<b>01 Apr 2024</b>	05 Jan 2024	02 Nov 2023
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>SEVERE</b>	SEVERE	SEVERE

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m) >15	<b>6</b>	1	3
Chromium	ppm	ASTM D5185(m) >4	<b>0</b>	0	0
Nickel	ppm	ASTM D5185(m) >2	<b>0</b>	0	0
Titanium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)	<b>0</b>	0	<1
Aluminum	ppm	ASTM D5185(m) >10	<b>0</b>	<1	0
Lead	ppm	ASTM D5185(m)	<b>0</b>	0	1
Copper	ppm	ASTM D5185(m) >5	<b>&lt;1</b>	<1	▲ 9
Tin	ppm	ASTM D5185(m) >5	<b>0</b>	0	0
Antimony	ppm	ASTM D5185(m)	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 0	<b>0</b>	0	<1
Barium	ppm	ASTM D5185(m) 0	<b>0</b>	0	<1
Molybdenum	ppm	ASTM D5185(m) 0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185(m) 0	<b>0</b>	0	0
Magnesium	ppm	ASTM D5185(m) 0	<b>&lt;1</b>	<1	<1
Calcium	ppm	ASTM D5185(m) 0	<b>0</b>	2	<1
Phosphorus	ppm	ASTM D5185(m) 120	<b>&lt;1</b>	<1	2
Zinc	ppm	ASTM D5185(m) 0.0	<b>&lt;1</b>	<1	5
Sulfur	ppm	ASTM D5185(m) 50	<b>556</b>	626	753
Lithium	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	<1


## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >15	<b>0</b>	0	0
Sodium	ppm	ASTM D5185(m)	<b>4</b>	7	2
Potassium	ppm	ASTM D5185(m) >20	<b>&lt;1</b>	<1	0
Water	%	ASTM D6304* >0.03	▲ <b>0.054</b>	▲ 0.147	0.003
ppm Water	ppm	ASTM D6304* >300	▲ <b>543</b>	▲ 1475	28.4


## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	▲ <b>63702</b>	▲ 52536	▲ 24425
Particles >6µm	ASTM D7647	>640	▲ <b>16503</b>	▲ 11620	▲ 8264
Particles >14µm	ASTM D7647	>80	▲ <b>614</b>	▲ 194	▲ 985
Particles >21µm	ASTM D7647	>20	▲ <b>96</b>	● 30	▲ 304
Particles >38µm	ASTM D7647	>4	<b>3</b>	2	▲ 26
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	2
Oil Cleanliness	ISO 4406 (c)	>18/16/13	▲ <b>23/21/16</b>	▲ 23/21/15	▲ 22/20/17


### Particle Trend




### Water (KF)




### Water (KF)



### Acid Number



### Viscosity @ 40°C



### FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974*	0.05	<b>0.03</b>	0.03	0.03


### VISUAL

	method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	Visual*	NONE	<b>▲ LIGHT</b>	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	<b>VLITE</b>	NONE	NONE
Appearance	scalar	Visual*	NORML	<b>▲ HAZY</b>	▲ HAZY	▲ WGOIL
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	Visual*	>0.03	<b>▲ .2%</b>	▲ .5%	.2%
Free Water	scalar	Visual*		<b>NEG</b>	NEG	NEG

### FLUID PROPERTIES


	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	68.4	<b>66.0</b>	66.4	67.0

### SAMPLE IMAGES




### GRAPHS


#### Ferrous Alloys




#### Non-ferrous Metals




#### Viscosity @ 40°C



#### Particle Count



#### Acid Number



ISO 17025:2017  
Accredited  
Laboratory

**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC0925273  
**Lab Number** : 02626054  
**Unique Number** : 5759186  
**Test Package** : IND 2 ( Additional Tests: KF, TAN Man )

**Received** : 02 Apr 2024  
**Tested** : 03 Apr 2024  
**Diagnosed** : 03 Apr 2024 - Kevin Marson

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

**Petro Canada Lubricants Inc.**  
 385 Southdown Road  
 Mississauga, ON  
 CA L5J 2Y3  
 Contact: Kyle Blezard  
 kyle.blezard@HFSinclair.com  
 T: (905)403-6768  
 F: (905)822-6025