




OIL ANALYSIS REPORT

Sample Rating Trend



DIRT



Area
5 Utilities/030 Boiler House/C Compressor/707 #7 Air Compressor
 Machine Id
N/A 30MC707 IB MOTOR

Component
Inboard Bearing

Fluid
PETRO CANADA TURBOFLO 32 (2 LTR)

DIAGNOSIS

Recommendation

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

Elemental level of silicon (Si) above normal indicating ingress of seal material.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0925276	WC0894087	WC0831868
Sample Date	Client Info		01 Apr 2024	05 Jan 2024	05 Jul 2023
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>2	NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m) >20	0	<1	0
Chromium	ppm	ASTM D5185(m) >20	0	0	0
Nickel	ppm	ASTM D5185(m) >20	0	<1	0
Titanium	ppm	ASTM D5185(m)	0	0	0
Silver	ppm	ASTM D5185(m)	0	0	<1
Aluminum	ppm	ASTM D5185(m) >20	0	<1	0
Lead	ppm	ASTM D5185(m) >20	0	0	<1
Copper	ppm	ASTM D5185(m) >20	<1	<1	<1
Tin	ppm	ASTM D5185(m) >20	0	<1	0
Antimony	ppm	ASTM D5185(m)	0	0	0
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 0	0	0	<1
Barium	ppm	ASTM D5185(m) 0	0	0	<1
Molybdenum	ppm	ASTM D5185(m) 0	0	0	0
Manganese	ppm	ASTM D5185(m)	0	0	0
Magnesium	ppm	ASTM D5185(m) 0	<1	<1	0
Calcium	ppm	ASTM D5185(m) 0	0	11	<1
Phosphorus	ppm	ASTM D5185(m) 120	<1	2	2
Zinc	ppm	ASTM D5185(m) 0.0	2	3	2
Sulfur	ppm	ASTM D5185(m) 0	661	751	1335
Lithium	ppm	ASTM D5185(m)	<1	<1	<1


CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >15	▲ 22	12	1
Sodium	ppm	ASTM D5185(m)	0	0	<1
Potassium	ppm	ASTM D5185(m) >20	0	<1	0


FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	4487	▲ 37249	● 17987
Particles >6µm	ASTM D7647	>2500	556	● 4800	▲ 5279
Particles >14µm	ASTM D7647	>160	31	● 259	▲ 389
Particles >21µm	ASTM D7647	>40	14	▲ 154	▲ 102
Particles >38µm	ASTM D7647	>10	3	▲ 29	4
Particles >71µm	ASTM D7647	>3	1	2	0
Oil Cleanliness	ISO 4406 (c)	>20/18/14	19/16/12	▲ 22/19/15	▲ 21/20/16


▲ Silicon (ppm)




Particle Trend




Acid Number



Viscosity @ 40°C



Particle Trend




FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974*	0.04	0.05	0.06	0.04
VISUAL						
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	LIGHT	NONE
Sand/Dirt	scalar	Visual*	NONE	VLITE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>2	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES


	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	34.0	33.5	▲ 29.1	36.3

SAMPLE IMAGES




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



Particle Count



Acid Number



ISO 17025:2017
Accredited
Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9

Sample No. : WC0925276

Lab Number : **02626086**

Unique Number : 5759218

Test Package : IND 2 (Additional Tests: TAN Man)

Received : 02 Apr 2024

Tested : 03 Apr 2024

Diagnosed : 03 Apr 2024 - Kevin Marson

Petro Canada Lubricants Inc.

385 Southdown Road

Mississauga, ON

CA L5J 2Y3

Contact: Kyle Blezard

kyle.blezard@HFSinclair.com

T: (905)403-6768

F: (905)822-6025

To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

Validity of results and interpretation are based on the sample and information as supplied.