

[BELL CANADA] DG-1 - DIESEL ENGINE

Sample No: GD0005686

Oil Type: {unknown}

SAMPLE INFORMATION

Sample Number	GD0005686	---	---	---
Sample Date	02 Apr 2024	---	---	---
Machine Hours	0	---	---	---
Oil Hours	0	---	---	---
Oil Changed	N/A	---	---	---
Sample Status	NORMAL	---	---	---

Generatrice Drummond
243 rue des ARTISANS
SAINT-GERMAIN-DE-GRANTHAM, QC
CA J0C 1K0
Contact: Valerie Poirier
poirievalerie@generatricedrummond.com
T: (819)398-6811
F: (819)398-7022

OIL CONDITION

Visc @ 100°C	cSt	█ 13.3	---	---	---
Oxidation (PA)	%	41	---	---	---

CONTAMINATION

Water	%	NEG	---	---	---
Soot %	%	█ 0	---	---	---
Nitration (PA)	%	43	---	---	---
Sulfation (PA)	%	42	---	---	---
Glycol	%	NEG	---	---	---
Fuel	%	<1.0	---	---	---
Silicon	ppm	█ 4	---	---	---
Sodium	ppm	█ 1	---	---	---
Potassium	ppm	█ 0	---	---	---

WEAR METALS

Iron	ppm	█ 3	---	---	---
Copper	ppm	█ <1	---	---	---
Lead	ppm	█ 0	---	---	---
Tin	ppm	█ 0	---	---	---
Aluminum	ppm	█ <1	---	---	---
Chromium	ppm	█ 0	---	---	---
Molybdenum	ppm	█ 55	---	---	---
Nickel	ppm	█ 0	---	---	---
Titanium	ppm	0	---	---	---
Silver	ppm	█ 0	---	---	---
Manganese	ppm	0	---	---	---
Vanadium	ppm	0	---	---	---

ADDITIVES

Calcium	ppm	█ 1032	---	---	---
Magnesium	ppm	█ 611	---	---	---
Zinc	ppm	█ 872	---	---	---
Phosphorus	ppm	775	---	---	---
Barium	ppm	█ 0	---	---	---
Boron	ppm	█ 1	---	---	---

Diagnosis

Échantillonner de nouveau l'équipement au prochain intervalle de vidange afin d'en surveiller la condition. Veuillez préciser la marque, le type et la viscosité de l'huile lors de votre prochain échantillon. Les taux d'usure de tous les composants sont normaux. Il n'y a aucun indice de contamination dans l'huile. L'état de l'huile est acceptable pour la durée de service.

Depot: GENSTN
Unique No: 5759539
Signed: Wes Davis
Report Date: 03 Apr 2024

GRAPHS

