OIL ANALYSIS REPORT

Sample Rating Trend



ISO

Area
Plastisol Line
Machine Id
Plastisol Embosser Hydraulic Pump (S/N 59-0835)
Component
Hydraulic System
Fluid
SUNOCO SUNVIS 846 ISO 46 (12 GAL)

DIAGNOSIS

Recommendation
We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear
All component wear rates are normal.

Contamination
There is a light amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**WC0867489**	WC0837280	WC0837268
Sample Date		Client Info		**21 Mar 2024**	04 Jan 2024	04 Oct 2023
Machine Age	hrs	Client Info		**0**	0	0
Oil Age	hrs	Client Info		**0**	0	0
Oil Changed		Client Info		**N/A**	N/A	N/A
Sample Status				**ATTENTION**	NORMAL	ATTENTION

CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>0.05	**NEG**	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>20	**<1**	<1	<1
Chromium	ppm	ASTM D5185(m)	>20	**0**	0	0
Nickel	ppm	ASTM D5185(m)	>20	**0**	0	0
Titanium	ppm	ASTM D5185(m)		**0**	0	0
Silver	ppm	ASTM D5185(m)		**0**	0	<1
Aluminum	ppm	ASTM D5185(m)	>20	**0**	<1	0
Lead	ppm	ASTM D5185(m)	>20	**0**	<1	<1
Copper	ppm	ASTM D5185(m)	>20	**2**	2	2
Tin	ppm	ASTM D5185(m)	>20	**0**	0	0
Antimony	ppm	ASTM D5185(m)		**0**	0	0
Vanadium	ppm	ASTM D5185(m)		**0**	0	0
Beryllium	ppm	ASTM D5185(m)		**0**	0	0
Cadmium	ppm	ASTM D5185(m)		**0**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		**0**	0	<1
Barium	ppm	ASTM D5185(m)		**0**	0	<1
Molybdenum	ppm	ASTM D5185(m)		**0**	0	0
Manganese	ppm	ASTM D5185(m)		**0**	0	0
Magnesium	ppm	ASTM D5185(m)		**<1**	<1	<1
Calcium	ppm	ASTM D5185(m)		**32**	31	31
Phosphorus	ppm	ASTM D5185(m)		**244**	245	250
Zinc	ppm	ASTM D5185(m)		**300**	288	298
Sulfur	ppm	ASTM D5185(m)		**5533**	5652	5442
Lithium	ppm	ASTM D5185(m)		**<1**	<1	<1

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>15	**0**	0	0
Sodium	ppm	ASTM D5185(m)		**0**	0	0
Potassium	ppm	ASTM D5185(m)	>20	**<1**	4	0

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	**8053**	3601	5168
Particles >6µm		ASTM D7647	>1300	**1080**	568	839
Particles >14µm		ASTM D7647	>160	**33**	35	33
Particles >21µm		ASTM D7647	>40	**8**	10	7
Particles >38µm		ASTM D7647	>10	**1**	1	1
Particles >71µm		ASTM D7647	>3	**1**	0	0
Oil Cleanliness		ISO 4406 (c)	>19/17/14	**20/17/12**	19/16/12	20/17/12

OIL ANALYSIS REPORT

Particle Trend



Particle Trend



Acid Number



Viscosity @ 40°C



FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*		**0.31**	0.43	0.30

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	**NONE**	NONE	NONE
Precipitate	scalar	Visual*	NONE	**NONE**	NONE	NONE
Silt	scalar	Visual*	NONE	**NONE**	NONE	NONE
Debris	scalar	Visual*	NONE	**NONE**	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	**NONE**	NONE	NONE
Appearance	scalar	Visual*	NORML	**NORML**	NORML	NORML
Odor	scalar	Visual*	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	Visual*	>0.05	**NEG**	NEG	NEG
Free Water	scalar	Visual*		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	46.0	**44.6**	44.6	44.6

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					



GRAPHS

Ferrous Alloys



Non-ferrous Metals



Viscosity @ 40°C



Particle Count



Acid Number



ISO 17025:2017 Accredited Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0867489
Lab Number : 02626619
Unique Number : 5759751
Test Package : IND 2

Received : 04 Apr 2024
Tested : 05 Apr 2024
Diagnosed : 05 Apr 2024 - Wes Davis

To discuss this sample report, contact Customer Service at 1-800-268-2131.
Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
Validity of results and interpretation are based on the sample and information as supplied.

CANADIAN GENERAL TOWER LTD.
52 MIDDLETON STREET, P.O. BOX 160
CAMBRIDGE, ON
CA N1S 2R4
Contact: Bob Abell
bob.abell@cgtower.com
T: (519)623-1630
F: (519)623-7018