


# **OIL ANALYSIS REPORT**

Sample Rating Trend



**NORMAL** 

Machine Id

# **Z-6704A CHOLORINATION XFMR RECTIFIER A**

Transformer Oil

**IRVING TRANSFORMER OIL (--- GAL)** 

#### Recommendation

Resample at the next service interval to monitor.

### Contamination

The water content is negligible. There is no indication of any contamination in the transformer oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the transformer oil is suitable for further service.

		May201	2 Mar2016	Jan2023 A	pr2024	
SAMPLE INFORM	<i>I</i> ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PP	PP	PP
Sample Date		Client Info		04 Apr 2024	08 Jan 2023	15 Mar 2016
Machine Age	days	Client Info		0	0	0
Oil Age	days	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>125	0		
Chromium	ppm	ASTM D5185(m)		0		
Nickel	ppm	ASTM D5185(m)		0		
Titanium	ppm	ASTM D5185(m)		0		
Silver	ppm	ASTM D5185(m)	>2	0		
Aluminum	ppm	ASTM D5185(m)	>5	0		
Lead	ppm	ASTM D5185(m)	>30	0		
Copper	ppm	ASTM D5185(m)	>10	0		
Tin	ppm	ASTM D5185(m)	>2	0		
Antimony	ppm	ASTM D5185(m)		0		
Vanadium	ppm	ASTM D5185(m)		0		
Beryllium	ppm	ASTM D5185(m)		0		
Cadmium	ppm	ASTM D5185(m)		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		0		
Barium	ppm	ASTM D5185(m)		0		
Molybdenum	ppm	ASTM D5185(m)		0		
Manganese	ppm	ASTM D5185(m)		0		
Magnesium	ppm	ASTM D5185(m)		<1		
Calcium	ppm	ASTM D5185(m)		0		
Phosphorus	ppm	ASTM D5185(m)		<1		
Zinc	ppm	ASTM D5185(m)		1		
Sulfur	ppm	ASTM D5185(m)		50		
Lithium	ppm	ASTM D5185(m)		<1		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>25	0		
Sodium	ppm	ASTM D5185(m)		0		
Potassium	ppm	ASTM D5185(m)	>20	<1		
Water	%	ASTM D6304*	>0.0035	0.002	0.002	
ppm Water	ppm	ASTM D6304*	>35	20	21.8	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2

Acid Number (AN) mg KOH/g ASTM D974\*


0.02

0.00

0.01



## **OIL ANALYSIS REPORT**





CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No.

: PP Lab Number

: 02627006 Unique Number : 5760138 Test Package: TRF 1 (Additional Tests: ICP, KV40, Spat)

To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Received : 05 Apr 2024 **Tested** Diagnosed

: 09 Apr 2024

: 19 Apr 2024 - Bill Quesnel

SUITE 1000,, 100 NEW GOWER STREET ST.JOHNS, NL **CA A1C 6K3** Contact: Sam Nash

> T: F: (709)722-3766

Validity of results and interpretation are based on the sample and information as supplied. Report Id: HIBSTJ [WCAMIS] 02627006 (Generated: 04/19/2024 16:09:40) Rev: 1

Contact/Location: Sam Nash - HIBSTJ

samantha.m.nash@exxonmobil.com

**HIBERNIA MGMT & DEVELOPMENT CO. LTD**