

OIL ANALYSIS REPORT

Sample Rating Trend





Area **1050 Notre Dame Ch#1 Circ 1** Machine rd **TRANE L05K04633** Chiller





Fluid REFRIG COMP OIL ISO 46 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

The water content is negligible. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

	IATION	method	limit/base	current	nistory i	nistory2
Sample Number		Client Info		GTT0002222		
Sample Date		Client Info		28 Mar 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>8	<1		
Chromium	ppm	ASTM D5185(m)	>2	0		
Nickel	ppm	ASTM D5185(m)		0		
Titanium	ppm	ASTM D5185(m)		0		
Silver	ppm	ASTM D5185(m)	>2	0		
Aluminum	ppm	ASTM D5185(m)	>3	0		
Lead	ppm	ASTM D5185(m)	>2	0		
Copper	ppm	ASTM D5185(m)	>8	<1		
Tin	ppm	ASTM D5185(m)	>4	0		
Antimony	ppm	ASTM D5185(m)		0		
Vanadium	ppm	ASTM D5185(m)		0		
Beryllium	ppm	ASTM D5185(m)		0		
Cadmium	nnm	ACTM DE10E(m)		•		
Gaumum	ppm	ASTM D5185(m)		0		
ADDITIVES	ррш	method	limit/base	current	 history1	history2
	ppm		limit/base 5	-		
ADDITIVES		method		current	history1	history2
ADDITIVES Boron	ppm	method ASTM D5185(m)	5	current	history1	history2
ADDITIVES Boron Barium	ppm ppm	method ASTM D5185(m) ASTM D5185(m)	5 5	current <1 0	history1 	history2
ADDITIVES Boron Barium Molybdenum	ppm ppm ppm	method ASTM D5185(m) ASTM D5185(m) ASTM D5185(m)	5 5	current <1 0 0	history1 	history2
ADDITIVES Boron Barium Molybdenum Manganese	ppm ppm ppm ppm	method ASTM D5185(m) ASTM D5185(m) ASTM D5185(m) ASTM D5185(m)	5 5 5	current <1 0 0 0	history1 	history2
ADDITIVES Boron Barium Molybdenum Manganese Magnesium	ppm ppm ppm ppm ppm	method ASTM D5185(m) ASTM D5185(m) ASTM D5185(m) ASTM D5185(m) ASTM D5185(m)	5 5 5 5	<pre>current <1 0 0 0 0 0 0 0 <1 </pre>	history1 	history2
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium	ppm ppm ppm ppm ppm	method ASTM D5185(m) ASTM D5185(m) ASTM D5185(m) ASTM D5185(m) ASTM D5185(m) ASTM D5185(m)	5 5 5 5 12	Current <1 0 0 0 0 0 0	history1	history2
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus	ppm ppm ppm ppm ppm ppm	method ASTM D5185(m) ASTM D5185(m) ASTM D5185(m) ASTM D5185(m) ASTM D5185(m) ASTM D5185(m) ASTM D5185(m)	5 5 5 5 12 12	<pre>current <1 0 0 0 0 0 0 0 <1 </pre>	history1	history2
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc	ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185(m)	5 5 5 12 12 12 12	current <1 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1 <1	history1	history2
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur	ppm ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185(m) ASTM D5185(m) ASTM D5185(m) ASTM D5185(m) ASTM D5185(m) ASTM D5185(m) ASTM D5185(m) ASTM D5185(m)	5 5 5 12 12 12 12	current <1 0 0 0 0 0 0 0 0 1 2 1 <1 16	history1	history2
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur Lithium	ppm ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185(m)	5 5 5 12 12 12 12 12 12 1000	current <1 0 0 0 0 0 0 0 0 1 <1 16 <1	history1	history2
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur Lithium CONTAMINANTS	ppm ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185(m)	5 5 5 12 12 12 12 12 1000	current <1 0 0 0 0 0 1 <1 16 <1 current	history1	history2
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur Lithium CONTAMINANTS Silicon	ppm ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185(m)	5 5 5 12 12 12 12 12 1000	current <1 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 <1 16 <1 current 23	history1	history2
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur Lithium CONTAMINANTS Silicon Sodium	ppm ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185(m)	5 5 5 12 12 12 12 12 12 1000 <i>limit/base</i> >15	current <1 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 <1 16 <1 current 23 <1	history1	history2
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur Lithium CONTAMINANTS Silicon Sodium Potassium	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185(m) ASTM D5185(m)	5 5 5 12 12 12 12 12 1000 limit/base >15	current <1 0 0 0 0 0 0 0 0 0 0 0 0 0 0 <1 16 <1 23 <1 0	history1	history2



OIL ANALYSIS REPORT

VISUAL		method	limit/base	current	history1	history2			
White Metal	scalar	Visual*	NONE	NONE					
Yellow Metal	scalar	Visual*	NONE	NONE					
Precipitate	scalar	Visual*	NONE	NONE					
Silt	scalar	Visual*	NONE	NONE					
Debris	scalar	Visual*	NONE	NONE					
Sand/Dirt	scalar	Visual*	NONE	NONE					
Appearance	scalar	Visual*	NORML	NORML					
Odor	scalar	Visual*	NORML	NORML					
FLUID PROPERT	IES	method	limit/base	current	history1	history2			
Visc @ 40°C	cSt	ASTM D7279(m)	46	47.1					
SAMPLE IMAGES		method	limit/base	current	history1	history2			
Color					no image	no image			
Bottom				0	no image	no image			
GRAPHS									



Sample No. : GTT0002222 Received : 05 Apr 2024 1510 Old Falconbridge Road Lab Number : 02627151 Tested : 10 Apr 2024 Unique Number : 5760283 Diagnosed : 10 Apr 2024 - Bill Quesnel Test Package : IND 2 (Additional Tests: KV40) Contact: Service Manager To discuss this sample report, contact Customer Service at 1-905-847-9300 Ext 26. invoices@ainsworth.com Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. T: (705)971-4097 Damages: Seller shall in no event be liable for special, incidental, or consequential damages, of a commercial nature, resulting from any cause.

Report Id: GTT0000985 [WCAMIS] 02627151 (Generated: 04/10/2024 17:53:15) Rev: 1

Contact/Location: Service Manager - GTT0000985

F:

Ainsworth

Sudbury, ON

CA P3A 4N8