




FUEL REPORT

Sample Rating Trend

ISO



Area
[155124]
Machine Id
85003605
Component
Diesel Fuel
Fluid
No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)

DIAGNOSIS

▲ Recommendation

We advise that you check all areas where contaminants can enter the system. We advise that you filter this fluid before use. We advise that you follow the water drain-off procedure for this component. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

▲ Contaminants

There is a high amount of particulates (2 to 100 microns in size) present in the fuel. Excessive free water present. There is no bacteria or fungus (yeast and/or mold) present in the sample.

Fuel Condition

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel (US EPA/CGSB-3.517-3 type B).

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			CU0023356	---	---
Sample Date	Client Info			05 Apr 2024	---	---
Machine Age	hrs	Client Info		6198	---	---
Sample Status				SEVERE	---	---

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
Specific Gravity		ASTM D1298*	0.839	0.851	---	---
Fuel Color	text	Visual Screen*	Yellow	Pink	---	---
Visc @ 40°C	cSt	ASTM D7279(m)	3.0	2.9	---	---
Pensky-Martens Flash Point	°C	ASTM D7215*	52	63	---	---

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185(m)	10	14	---	---

DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D2887*	165	174	---	---
5% Distillation Point	°C	ASTM D2887*		199	---	---
10% Distill Point	°C	ASTM D2887*	201	210	---	---
15% Distillation Point	°C	ASTM D2887*		217	---	---
20% Distill Point	°C	ASTM D2887*	216	225	---	---
30% Distill Point	°C	ASTM D2887*	230	238	---	---
40% Distill Point	°C	ASTM D2887*	243	250	---	---
50% Distill Point	°C	ASTM D2887*	255	262	---	---
60% Distill Point	°C	ASTM D2887*	267	274	---	---
70% Distill Point	°C	ASTM D2887*	280	287	---	---
80% Distill Point	°C	ASTM D2887*	295	301	---	---
85% Distillation Point	°C	ASTM D2887*		312	---	---
90% Distill Point	°C	ASTM D2887*	310	323	---	---
95% Distillation Point	°C	ASTM D2887*		341	---	---
Final Boiling Point	°C	ASTM D2887*	341	370	---	---






IGNITION QUALITY		method	limit/base	current	history1	history2
API Gravity		ASTM D1298*	37.7	34	---	---
Cetane Index		ASTM D4737*	<40.0	45	---	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	<1.0	0	---	---
Sodium	ppm	ASTM D5185(m)	<0.1	0	---	---
Potassium	ppm	ASTM D5185(m)	<0.1	0	---	---
Water	%	ASTM D6304*	<0.05	0.031	---	---
ppm Water	ppm	ASTM D6304*	<500	316	---	---

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	▲ 78512	---	---
Particles >6µm		ASTM D7647	>640	▲ 74047	---	---
Particles >14µm		ASTM D7647	>80	▲ 45902	---	---
Particles >21µm		ASTM D7647	>20	▲ 23819	---	---
Particles >38µm		ASTM D7647	>4	▲ 326	---	---
Particles >71µm		ASTM D7647	>3	1	---	---
Oil Cleanliness		ISO 4406 (c)	>18/16/13	▲ 23/23/23	---	---



FUEL REPORT




MICROBIAL	method	limit/base	current	history1	history2
Bacteria	CFU/ml ASTM D6469*	>=100000	0	---	---
Yeast	CFU/ml ASTM D6469*	>=100000	0	---	---
Mold	Colonies ASTM D6469*	MODER	NONE	---	---




HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm ASTM D5185(m)	<0.1	0	---	---
Nickel	ppm ASTM D5185(m)	<0.1	0	---	---
Lead	ppm ASTM D5185(m)	<0.1	0	---	---
Vanadium	ppm ASTM D5185(m)	<0.1	0	---	---
Iron	ppm ASTM D5185(m)	<0.1	<1	---	---
Calcium	ppm ASTM D5185(m)	<0.1	5	---	---
Magnesium	ppm ASTM D5185(m)	<0.1	0	---	---
Phosphorus	ppm ASTM D5185(m)	<0.1	3	---	---
Zinc	ppm ASTM D5185(m)	<0.1	4	---	---

SAMPLE IMAGES

	method	limit/base	current	history1	history2
Color					
Bottom					



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **CUMMINS CANADA ULC - GENERATOR DIVISION**
Sample No. : CU0023356 **Received** : 08 Apr 2024 **7175 PACIFIC CIRCLE**
Lab Number : **02627542** **Tested** : 15 Apr 2024 **MISSISSAUGA, ON**
Unique Number : 5760674 **Diagnosed** : 15 Apr 2024 - Kevin Marson **CA L5T 2A5**
Test Package : FUEL (Additional Tests: Bacteria, CC Flash, PrtCount) **Contact: Elisia Johnson**
To discuss this sample report, contact Customer Service at 1-800-268-2131. **elisia.johnson@cummins.com**
Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. **T: (905)795-0050**
Validity of results and interpretation are based on the sample and information as supplied. **F: (905)795-9252**