




PROBLEM SUMMARY

Area
PGS
 Machine Id
PGS Generator 6 Governor
 Component
Hydraulic System
 Fluid
ESSO TERESSO ISO 46 (19500 LTR)

Sample Rating Trend




WATER




COMPONENT CONDITION SUMMARY

▲ Particle Trend



▲ Water (KF)



RECOMMENDATION

We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. We advise that you check for visible metal particles in the oil. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation.

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	ABNORMAL	SEVERE
Water	%	ASTM D6304*	>0.05	▲ 0.201	---	---
ppm Water	ppm	ASTM D6304*	>500	▲ 2018	---	---
Particles >4µm		ASTM D7647	>2500	▲ 29151	▲ 13220	▲ 15000
Particles >6µm		ASTM D7647	>640	▲ 2343	600	▲ 3750
Oil Cleanliness		ISO 4406 (c)	>18/16/13	▲ 22/18/13	▲ 21/16/11	▲ 21/19/16
White Metal	scalar	Visual*	NONE	▲ VLITE	NONE	▲ LIGHT
Emulsified Water	scalar	Visual*	>0.05	▲ .5%	NEG	NEG

PrtFilter



Customer Id: ONTQUE
 Sample No.: WC
 Lab Number: 02628221
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	MISSED	Apr 12 2024	?	We recommend you service the filters on this component.
Resample	MISSED	Apr 12 2024	?	Resample in 30-45 days to monitor this situation.
Check Breathers	MISSED	Apr 12 2024	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Water Access	MISSED	Apr 12 2024	?	We advise that you check for the source of water entry.
Check For Visual Metal	MISSED	Apr 12 2024	?	We advise that you check for visible metal particles in the oil.
Check Seals	MISSED	Apr 12 2024	?	Check seals and/or filters for points of contaminant entry.
Filter Fluid	MISSED	Apr 12 2024	?	We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil.

HISTORICAL DIAGNOSIS



13 Jul 2021 Diag: Kevin Marson

We recommend you service the filters on this component. We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use. Component wear rates appear to be normal (unconfirmed). Particles >4µm are abnormally high. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service (unconfirmed). The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

[view report](#)



VISUAL METAL



16 Jul 2019 Diag: Kevin Marson

We advise that you check for visible metal particles in the oil. Wear particles and/or ppm levels are abnormally high indicating the need to review OEM limits with attention to components that may generate this type of wear. Include all test results and maintenance activities that have been performed since the abnormal condition was first detected in this review. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. An inspection for the source(s) of wear may be warranted at this time. Re-sampling is suggested to confirm test results prior to significant maintenance activities being performed. Please indicate that this is a resample on your Sample Information Form (SIF). We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use. Moderate concentration of visible metal present. Cutting wear particles are caused by either hard protuberances (mis-aligned components, etc.), or abrasives entering the system and embedding themselves in softer materials (sand, etc.), and gouging out mating surfaces. Particles >14µm are abnormally high. Particles >21µm are abnormally high. Particles >4µm are abnormally high. Particles >6µm are abnormally high. Particles >38µm are notably high. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service (unconfirmed). The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

[view report](#)



ISO



28 Jul 2017 Diag: Wes Davis

We recommend you service the filters on this component. We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use. All component wear rates are normal. Particles >4µm are abnormally high. Particles >6µm are abnormally high. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service (unconfirmed). The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

[view report](#)






OIL ANALYSIS REPORT

Area
PGS
 Machine Id
PGS Generator 6 Governor
 Component
Hydraulic System
 Fluid
ESSO TERESSO ISO 46 (19500 LTR)

Sample Rating Trend



WATER



DIAGNOSIS

▲ Recommendation

We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. We advise that you check for visible metal particles in the oil. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation.

▲ Wear

Moderate concentration of visible metal present. Cylinder wear is indicated.

▲ Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil. There is a moderate concentration of water present in the oil. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

Particle Filter (Magn: 100 x)



SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC	WC0600843	WC
Sample Date	Client Info		04 Apr 2024	13 Jul 2021	16 Jul 2019
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	ABNORMAL	SEVERE

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>20	<1	0	<1
Chromium	ppm	ASTM D5185(m)	>20	0	0	0
Nickel	ppm	ASTM D5185(m)	>20	0	<1	0
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)		0	0	0
Aluminum	ppm	ASTM D5185(m)	>20	0	0	<1
Lead	ppm	ASTM D5185(m)	>20	0	<1	<1
Copper	ppm	ASTM D5185(m)	>20	2	2	2
Tin	ppm	ASTM D5185(m)	>20	0	<1	0
Antimony	ppm	ASTM D5185(m)		0	<1	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	<1

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	0	<1	<1	<1
Barium	ppm	ASTM D5185(m)		0	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	<1	<1
Manganese	ppm	ASTM D5185(m)		0	0	<1
Magnesium	ppm	ASTM D5185(m)	0	0	0	<1
Calcium	ppm	ASTM D5185(m)	0	<1	<1	<1
Phosphorus	ppm	ASTM D5185(m)	2.4	4	2	2
Zinc	ppm	ASTM D5185(m)	0	1	<1	<1
Sulfur	ppm	ASTM D5185(m)		810	781	785
Lithium	ppm	ASTM D5185(m)		<1	<1	0

CONTAMINANTS






	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>15	0	<1	<1
Sodium	ppm	ASTM D5185(m)		2	0	0
Potassium	ppm	ASTM D5185(m)	>20	3	<1	0
Water	%	ASTM D6304*	>0.05	▲ 0.201	---	---
ppm Water	ppm	ASTM D6304*	>500	▲ 2018	---	---

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	▲ 29151	▲ 13220	▲ 15000
Particles >6µm	ASTM D7647	>640	▲ 2343	600	▲ 3750
Particles >14µm	ASTM D7647	>80	73	12	▲ 480
Particles >21µm	ASTM D7647	>20	18	4	▲ 60
Particles >38µm	ASTM D7647	>4	1	0	● 7
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>18/16/13	▲ 22/18/13	▲ 21/16/11	▲ 21/19/16



OIL ANALYSIS REPORT



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC
Lab Number : 02628221
Unique Number : 5761353
Test Package : IND 2 (Additional Tests: Bottom, BottomAnalysis, FilterPatch, KF, PrtFilter, TAN, Water)

Ontario Power Generation
 NIAGARA PLANT GROUP, 14000 NIAGARA PKWY
 NIAGARA ON THE LAKE, ON
 CA LOS 1J0
 Contact: Michael Brochu
 mike.brochu@opg.com

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.02	0.06	0.08	0.072

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	▲ VLITE	NONE	▲ LIGHT
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	▲ LIGHT
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	VLITE	VLITE
Sand/Dirt	scalar	Visual*	NONE	VLITE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.05	▲ .5%	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	46	43.6	43.5	43.7

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------

