




OIL ANALYSIS REPORT

Sample Rating Trend



VISCOSITY



Area
[156325]
 Machine Id
ULTRA 26
 Component
Gearbox
 Fluid
PETRO CANADA 220 (2 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please specify the component make and model with your next sample.

Wear

All component wear rates are normal.

Contamination

The water content is negligible. There is no indication of any contamination in the oil.

Fluid Condition

Viscosity of sample indicates oil is within ISO 320 range, advise investigate. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0929905	WC0829266	---
Sample Date	Client Info		10 Apr 2024	01 Aug 2023	---
Machine Age	hrs	Client Info	0	0	---
Oil Age	hrs	Client Info	0	0	---
Oil Changed	Client Info		N/A	N/A	---
Sample Status			ABNORMAL	ABNORMAL	---

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*		0	5	---
Iron	ppm	ASTM D5185(m) >200	13	33	---
Chromium	ppm	ASTM D5185(m) >10	0	<1	---
Nickel	ppm	ASTM D5185(m) >10	0	<1	---
Titanium	ppm	ASTM D5185(m)	0	<1	---
Silver	ppm	ASTM D5185(m)	0	0	---
Aluminum	ppm	ASTM D5185(m) >25	<1	<1	---
Lead	ppm	ASTM D5185(m) >50	0	3	---
Copper	ppm	ASTM D5185(m) >200	8	141	---
Tin	ppm	ASTM D5185(m) >10	0	2	---
Antimony	ppm	ASTM D5185(m) >5	0	0	---
Vanadium	ppm	ASTM D5185(m)	0	0	---
Beryllium	ppm	ASTM D5185(m)	0	0	---
Cadmium	ppm	ASTM D5185(m)	0	0	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	2	3	---
Barium	ppm	ASTM D5185(m)	<1	3	---
Molybdenum	ppm	ASTM D5185(m)	<1	3	---
Manganese	ppm	ASTM D5185(m)	0	<1	---
Magnesium	ppm	ASTM D5185(m)	<1	9	---
Calcium	ppm	ASTM D5185(m)	7	111	---
Phosphorus	ppm	ASTM D5185(m)	387	680	---
Zinc	ppm	ASTM D5185(m)	4	58	---
Sulfur	ppm	ASTM D5185(m)	1132	697	---
Lithium	ppm	ASTM D5185(m)	1	9	---

CONTAMINANTS





	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >50	1	5	---
Sodium	ppm	ASTM D5185(m)	0	3	---
Potassium	ppm	ASTM D5185(m) >20	1	8	---
Water	%	ASTM D6304* >0.2	0.004	---	---
ppm Water	ppm	ASTM D6304* >2000	46	---	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.41	0.22	---




OIL ANALYSIS REPORT









VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	---
Yellow Metal	scalar	Visual*	NONE	NONE	---
Precipitate	scalar	Visual*	NONE	NONE	---
Silt	scalar	Visual*	NONE	NONE	---
Debris	scalar	Visual*	NONE	NONE	---
Sand/Dirt	scalar	Visual*	NONE	NONE	---
Appearance	scalar	Visual*	NORML	NORML	---
Odor	scalar	Visual*	NORML	NORML	---
Emulsified Water	scalar	Visual*	>0.2	.2%	NEG
Free Water	scalar	Visual*		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	▲ 374	▲ 204	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0929905 **Received** : 12 Apr 2024
Lab Number : 02628598 **Tested** : 15 Apr 2024
Unique Number : 5761730 **Diagnosed** : 15 Apr 2024 - Kevin Marson
Test Package : IND 2 (Additional Tests: KF, TAN Man)

GRAND RIVER FOODS
 190 VONDRAU DRIVE
 CAMBRIDGE, ON
 CA N3E 1B8
 Contact: Dan Jean-Marie
 djeanmarie@grandriverfoods.com
 T: (519)653-3577
 F:

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.