




# PROBLEM SUMMARY

## Sample Rating Trend



ISO



Machine Id

### Mobil DELVAC 1300 Super

Component


New (Unused) Oil

Fluid

MOBIL DELVAC 1300 SUPER 10W30 (--- GAL)

## COMPONENT CONDITION SUMMARY

### ▲ Particle Trend



## RECOMMENDATION

Il s'agit du relevé de base de cette huile neuve (inutilisée). Le fluide peut servir. Échantillonner de nouveau dans 30 à 45 jours afin de contrôler la situation. NOTER: Des nouvelles huiles ne sont pas généralement filtrées ni garanties conformes à un code spécifique de propreté. Nous vous conseillons de vérifier le code cible de propreté pour votre application et vous recommandons de vous servir d'un dispositif portable de filtrage lors du remplissage de tout système avec un code de propreté inférieur au code de propreté ISO de ce produit. ( Customer Sample Comment: Échantillon pris dans le réservoir au magasin )

## PROBLEMATIC TEST RESULTS

| Sample Status   | ASTM D7647             | SEVERE     | SEVERE     | --- |
|-----------------|------------------------|------------|------------|-----|
| Particles >4µm  | >5000                  | ▲ 86384    | ▲ 89727    | --- |
| Particles >6µm  | >1300                  | ▲ 32246    | ▲ 38014    | --- |
| Particles >14µm | >160                   | ▲ 1405     | ▲ 2459     | --- |
| Particles >21µm | >40                    | ▲ 159      | ▲ 367      | --- |
| Oil Cleanliness | ISO 4406 (c) >19/17/14 | ▲ 24/22/18 | ▲ 24/22/18 | --- |

Customer Id: ALCBAI  
 Sample No.: WC0921471  
 Lab Number: 02628808  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
 Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

| Action   | Status | Date | Done By | Description                                                                                                                                                                                                                                                                                             |
|----------|--------|------|---------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Resample | ---    | ---  | ?       | Resample in 30-45 days to monitor this situation.                                                                                                                                                                                                                                                       |
| Alert    | ---    | ---  | ?       | NOTE: New oils are not generally filtered or guaranteed to a certain cleanliness code. We advise that you verify the target cleanliness code for your application and recommend the use of a portable filter cart to fill any system with a target code below the ISO cleanliness code of this product. |

## HISTORICAL DIAGNOSIS

ISO



### 11 Apr 2024 Diag: Kevin Marson

Il s'agit du relevé de base de cette huile neuve (inutilisée). Le fluide peut servir. Échantillonner de nouveau dans 30 à 45 jours afin de contrôler la situation. NOTER: Des nouvelles huiles ne sont pas généralement filtrées ni garanties conformes à un code spécifique de propreté. Nous vous conseillons de vérifier le code cible de propreté pour votre application et vous recommandons de vous servir d'un dispositif portable de filtrage lors du remplissage de tout système avec un code de propreté inférieur au code de propreté ISO de ce produit. (sans objet) Il y a une quantité élevée de matières particulaires (2 à 100 µm de taille) présente dans l'huile. Le résultat pour le BN indique que la réserve d'alcalinité est acceptable pour l'huile. Le AN est acceptable pour ce fluide. L'état de l'huile permet d'en l'utilisation. l'huile peut encore servir si la contamination peut être réduite à un niveau


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id

## Mobil DELVAC 1300 Super

Component

New (Unused) Oil

Fluid

MOBIL DELVAC 1300 SUPER 10W30 (--- GAL)

### DIAGNOSIS

#### ▲ Recommendation

Il s'agit du relevé de base de cette huile neuve (inutilisée). Le fluide peut servir. Échantillonner de nouveau dans 30 à 45 jours afin de contrôler la situation. NOTER: Des nouvelles huiles ne sont pas généralement filtrées ni garanties conformes à un code spécifique de propreté. Nous vous conseillons de vérifier le code cible de propreté pour votre application et vous recommandons de vous servir d'un dispositif portable de filtrage lors du remplissage de tout système avec un code de propreté inférieur au code de propreté ISO de ce produit. ( Customer Sample Comment: Échantillon pris dans le réservoir au magasin )

#### ▲ Contamination

Il y a une quantité élevée de matières particulaires (2 à 100 µm de taille) présente dans l'huile.

#### Fluid Condition

Le résultat pour le BN indique que la réserve d'alcalinité est acceptable pour l'huile. Le AN est acceptable pour ce fluide. L'état de l'huile permet d'en l'utilisation. l'huile peut encore servir si la contamination peut être réduite à un niveau acceptable.

### SAMPLE INFORMATION

|               | method      | limit/base  | current     | history1    | history2 |
|---------------|-------------|-------------|-------------|-------------|----------|
| Sample Number | Client Info |             | WC0921471   | WC0921470   | ---      |
| Sample Date   | Client Info |             | 11 Apr 2024 | 11 Apr 2024 | ---      |
| Machine Age   | mths        | Client Info | 0           | 0           | ---      |
| Oil Age       | mths        | Client Info | 0           | 0           | ---      |
| Oil Changed   | Client Info |             | N/A         | N/A         | ---      |
| Sample Status |             |             | SEVERE      | SEVERE      | ---      |

### CONTAMINATION

|       | method    | limit/base | current | history1 | history2 |
|-------|-----------|------------|---------|----------|----------|
| Water | WC Method |            | NEG     | NEG      | ---      |

### WEAR METALS

|           | method      | limit/base       | current | history1 | history2 |
|-----------|-------------|------------------|---------|----------|----------|
| PQ        | ASTM D8184* |                  | 0       | 0        | ---      |
| Iron      | ppm         | ASTM D5185(m) >5 | 1       | 1        | ---      |
| Chromium  | ppm         | ASTM D5185(m) >5 | 0       | 0        | ---      |
| Nickel    | ppm         | ASTM D5185(m) >5 | 0       | 0        | ---      |
| Titanium  | ppm         | ASTM D5185(m)    | 0       | 0        | ---      |
| Silver    | ppm         | ASTM D5185(m) >5 | 0       | 0        | ---      |
| Aluminum  | ppm         | ASTM D5185(m) >5 | <1      | <1       | ---      |
| Lead      | ppm         | ASTM D5185(m) >5 | 0       | 0        | ---      |
| Copper    | ppm         | ASTM D5185(m) >5 | 0       | 0        | ---      |
| Tin       | ppm         | ASTM D5185(m) >5 | 0       | 0        | ---      |
| Antimony  | ppm         | ASTM D5185(m)    | 0       | 0        | ---      |
| Vanadium  | ppm         | ASTM D5185(m)    | 0       | 0        | ---      |
| Beryllium | ppm         | ASTM D5185(m)    | 0       | 0        | ---      |
| Cadmium   | ppm         | ASTM D5185(m)    | 0       | 0        | ---      |

### ADDITIVES

|            | method | limit/base    | current | history1 | history2 |
|------------|--------|---------------|---------|----------|----------|
| Boron      | ppm    | ASTM D5185(m) | 65      | 66       | ---      |
| Barium     | ppm    | ASTM D5185(m) | 0       | 0        | ---      |
| Molybdenum | ppm    | ASTM D5185(m) | 39      | 39       | ---      |
| Manganese  | ppm    | ASTM D5185(m) | 0       | 0        | ---      |
| Magnesium  | ppm    | ASTM D5185(m) | 500     | 500      | ---      |
| Calcium    | ppm    | ASTM D5185(m) | 1560    | 1570     | ---      |
| Phosphorus | ppm    | ASTM D5185(m) | 750     | 750      | ---      |
| Zinc       | ppm    | ASTM D5185(m) | 850     | 850      | ---      |
| Sulfur     | ppm    | ASTM D5185(m) | 2150    | 2150     | ---      |
| Lithium    | ppm    | ASTM D5185(m) | <1      | <1       | ---      |

### CONTAMINANTS






|           | method | limit/base        | current | history1 | history2 |
|-----------|--------|-------------------|---------|----------|----------|
| Silicon   | ppm    | ASTM D5185(m) >15 | 6       | 6        | ---      |
| Sodium    | ppm    | ASTM D5185(m)     | 2       | 2        | ---      |
| Potassium | ppm    | ASTM D5185(m) >20 | 0       | 0        | ---      |

### INFRA-RED

|           | method   | limit/base  | current | history1 | history2 |
|-----------|----------|-------------|---------|----------|----------|
| Soot %    | %        | ASTM D7844* | 0       | 0        | ---      |
| Nitration | Abs/cm   | ASTM D7624* | 4.6     | 4.6      | ---      |
| Sulfation | Abs./1mm | ASTM D7415* | 22.4    | 22.3     | ---      |



# OIL ANALYSIS REPORT







| FLUID CLEANLINESS | method       | limit/base | current           | history1   | history2 |
|-------------------|--------------|------------|-------------------|------------|----------|
| Particles >4µm    | ASTM D7647   | >5000      | ▲ <b>86384</b>    | ▲ 89727    | ---      |
| Particles >6µm    | ASTM D7647   | >1300      | ▲ <b>32246</b>    | ▲ 38014    | ---      |
| Particles >14µm   | ASTM D7647   | >160       | ▲ <b>1405</b>     | ▲ 2459     | ---      |
| Particles >21µm   | ASTM D7647   | >40        | ▲ <b>159</b>      | ▲ 367      | ---      |
| Particles >38µm   | ASTM D7647   | >10        | <b>3</b>          | 10         | ---      |
| Particles >71µm   | ASTM D7647   | >3         | <b>1</b>          | 4          | ---      |
| Oil Cleanliness   | ISO 4406 (c) | >19/17/14  | ▲ <b>24/22/18</b> | ▲ 24/22/18 | ---      |

| FLUID DEGRADATION | method   | limit/base  | current     | history1 | history2 |
|-------------------|----------|-------------|-------------|----------|----------|
| Oxidation         | Abs/.1mm | ASTM D7414* | <b>18.9</b> | 18.8     | ---      |
| Acid Number (AN)  | mg KOH/g | ASTM D974*  | <b>1.44</b> | 1.46     | ---      |
| Base Number (BN)  | mg KOH/g | ASTM D2896* | <b>9.23</b> | 9.32     | ---      |

| VISUAL           | method | limit/base | current      | history1 | history2 |
|------------------|--------|------------|--------------|----------|----------|
| White Metal      | scalar | Visual*    | <b>NONE</b>  | NONE     | ---      |
| Yellow Metal     | scalar | Visual*    | <b>NONE</b>  | NONE     | ---      |
| Precipitate      | scalar | Visual*    | <b>NONE</b>  | NONE     | ---      |
| Silt             | scalar | Visual*    | <b>NONE</b>  | NONE     | ---      |
| Debris           | scalar | Visual*    | <b>NONE</b>  | NONE     | ---      |
| Sand/Dirt        | scalar | Visual*    | <b>NONE</b>  | NONE     | ---      |
| Appearance       | scalar | Visual*    | <b>NORML</b> | NORML    | ---      |
| Odor             | scalar | Visual*    | <b>NORML</b> | NORML    | ---      |
| Emulsified Water | scalar | Visual*    | <b>NEG</b>   | NEG      | ---      |
| Free Water       | scalar | Visual*    | <b>NEG</b>   | NEG      | ---      |

| FLUID PROPERTIES     | method | limit/base    | current     | history1 | history2 |
|----------------------|--------|---------------|-------------|----------|----------|
| Visc @ 40°C          | cSt    | ASTM D7279(m) | <b>76.2</b> | 76.3     | ---      |
| Visc @ 100°C         | cSt    | ASTM D7279(m) | <b>11.5</b> | 11.5     | ---      |
| Viscosity Index (VI) | Scale  | ASTM D2270*   | <b>143</b>  | 143      | ---      |

| SAMPLE IMAGES | method | limit/base | current                                                                               | history1                                                                              | history2 |
|---------------|--------|------------|---------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------|----------|
| Color         |        |            |  |  | no image |
| Bottom        |        |            |  |  | no image |



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC0921471 **Received** : 15 Apr 2024  
**Lab Number** : **02628808** **Tested** : 19 Apr 2024  
**Unique Number** : 5761940 **Diagnosed** : 19 Apr 2024 - Kevin Marson  
**Test Package** : IND 2 ( Additional Tests: FT-IR, ICP-NewOil, KV100, PQ, PrtCount, TAN Man, TBN, VI)

**RTA - UGB**  
 C.P. 900  
 Ville de la Baie, QC  
 CA G7B 4G9  
 Contact: Alcan Epc  
 mathieu.tremblay2@riotinto.com  
 T: (418)697-9568  
 F: (418)697-9550

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.