







# OIL ANALYSIS REPORT











FLUID DEGRADATION	method	limit/base	current	history1	history2	
Oxidation	Abs./1mm	ASTM D7414*	>25	<b>23.8</b>	---	---

VISUAL	method	limit/base	current	history1	history2	
Emulsified Water	scalar	Visual*	>0.2	<b>NEG</b>	---	---
Free Water	scalar	Visual*		<b>NEG</b>	---	---

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 100°C	cSt	ASTM D7279(m)	14.5	<b>14.9</b>	---	---

## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC0864601      **Received** : 16 Apr 2024  
**Lab Number** : **02629160**      **Tested** : 16 Apr 2024  
**Unique Number** : 5762292      **Diagnosed** : 16 Apr 2024 - Wes Davis  
**Test Package** : MOB 1

**COLACEM CANADA INC**  
 56 RUE LONGUEUIL CP 301  
 L'ORIGINAL, ON  
 CA K0B 1K0  
 Contact: Gabriel Parent  
 gparent@colacem.ca

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

T:  
 F: (613)675-2747