



# PROBLEM SUMMARY

Area

8

Machine Id

## 8-2-301-C FM #2 Trunion - Discharge End


Component

Journal Bearing

Fluid

MOBIL MOBILGEAR SHC 460 (350 LTR)

Sample Rating Trend




WEAR



### COMPONENT CONDITION SUMMARY

#### ▲ Non-ferrous Metals



### RECOMMENDATION

We recommend an early resample to monitor this condition. Re-sampling is suggested to confirm test results prior to significant maintenance activities being performed. Please indicate that this is a resample on your Sample Information Form (SIF). Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.

### PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	SEVERE	SEVERE
Tin	ppm	ASTM D5185(m)	>80	▲ 593	▲ 362	▲ 685
Antimony	ppm	ASTM D5185(m)		▲ 50	▲ 32	▲ 60

Customer Id: STMBOW  
Sample No.: WC0925375  
Lab Number: 02629337  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Resample	---	---	?	We recommend an early resample to monitor this condition. Re-sampling is suggested to confirm test results prior to significant maintenance activities being performed. Please indicate that this is a resample on your Sample Information Form (SIF).
Contact Required	---	---	?	Please contact your representative for information regarding the proper sampling kits for your service.
Alert	---	---	?	NOTE: We recommend using IND 3 test kits,

HISTORICAL DIAGNOSIS

WEAR



21 Feb 2024 Diag: Kevin Marson

We recommend an early resample to monitor this condition. Re-sampling is suggested to confirm test results prior to significant maintenance activities being performed. Please indicate that this is a resample on your Sample Information Form (SIF). Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid. Tin ppm levels are severe. Antimony ppm levels are abnormal. Bearing wear is indicated. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



WEAR



29 Nov 2023 Diag: Kevin Marson

Re-sampling is suggested to confirm test results prior to significant maintenance activities being performed. Please indicate that this is a resample on your Sample Information Form (SIF). We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid. Tin ppm levels are severe. Iron and antimony ppm levels are abnormal. Bearing wear is indicated. The low ferrous density (PQ) index indicates the wear metal levels are due to corrosion. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

view report



NORMAL



14 Sep 2023 Diag: Bill Quesnel

Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



Area

8

Machine Id

## 8-2-301-C FM #2 Trunion - Discharge End

Component

Journal Bearing

Fluid

MOBIL MOBILGEAR SHC 460 (350 LTR)

### DIAGNOSIS

#### ▲ Recommendation

We recommend an early resample to monitor this condition. Re-sampling is suggested to confirm test results prior to significant maintenance activities being performed. Please indicate that this is a resample on your Sample Information Form (SIF). Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.

#### ▲ Wear

Tin ppm levels are severe. Antimony ppm levels are abnormal. Bearing wear is indicated.

#### Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>WC0925375</b>	WC0902103	WC0869918
Sample Date	Client Info			<b>04 Apr 2024</b>	21 Feb 2024	29 Nov 2023
Machine Age	hrs	Client Info		<b>0</b>	0	0
Oil Age	hrs	Client Info		<b>0</b>	0	0
Oil Changed	Client Info			<b>N/A</b>	N/A	N/A
Sample Status				<b>SEVERE</b>	SEVERE	SEVERE

CONTAMINATION		method	limit/base	current	history1	history2
Water	WC Method		>2	<b>NEG</b>	NEG	NEG






WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>60	<b>37</b>	42	▲ 74
Chromium	ppm	ASTM D5185(m)	>20	<b>0</b>	0	<1
Nickel	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	<1	<1
Titanium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)		<b>0</b>	0	<1
Aluminum	ppm	ASTM D5185(m)	>4	<b>2</b>	3	3
Lead	ppm	ASTM D5185(m)	>250	<b>4</b>	4	6
Copper	ppm	ASTM D5185(m)	>125	<b>20</b>	16	28
Tin	ppm	ASTM D5185(m)	>80	<b>▲ 593</b>	▲ 362	▲ 685
Antimony	ppm	ASTM D5185(m)		<b>▲ 50</b>	▲ 32	▲ 60
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	5.7	<b>6</b>	11	7
Barium	ppm	ASTM D5185(m)	0.0	<b>&lt;1</b>	0	0
Molybdenum	ppm	ASTM D5185(m)	0.0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185(m)	0.0	<b>&lt;1</b>	0	<1
Magnesium	ppm	ASTM D5185(m)	0.0	<b>3</b>	3	3
Calcium	ppm	ASTM D5185(m)	0.0	<b>50</b>	46	56
Phosphorus	ppm	ASTM D5185(m)	180	<b>338</b>	367	342
Zinc	ppm	ASTM D5185(m)	0.8	<b>&lt;1</b>	<1	1
Sulfur	ppm	ASTM D5185(m)	4270	<b>3371</b>	4120	4030
Lithium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	<1

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>50	<b>7</b>	8	10
Sodium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	<1
Potassium	ppm	ASTM D5185(m)	>20	<b>3</b>	3	2

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		<b>206897</b>	323430	244459
Particles >6µm		ASTM D7647	>320000	<b>181253</b>	271422	217554
Particles >14µm		ASTM D7647	>160000	<b>55575</b>	61640	79550
Particles >21µm		ASTM D7647	>40000	<b>5568</b>	5599	12421
Particles >38µm		ASTM D7647	>10000	<b>7</b>	1	2
Particles >71µm		ASTM D7647	>2500	<b>6</b>	0	1
Oil Cleanliness		ISO 4406 (c)	>--/25/24	<b>25/25/23</b>	26/25/23	25/25/23

# OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.38	<b>0.59</b>	0.87	0.67






VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	<b>NONE</b>	VLITE	NONE
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	Visual*	NONE	<b>LIGHT</b>	VLITE	NONE
Debris	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	Visual*	>2	<b>NEG</b>	NEG	NEG
Free Water	scalar	Visual*		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	477	<b>444</b>	438	426

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC0925375 **Received** : 16 Apr 2024  
**Lab Number** : **02629337** **Tested** : 17 Apr 2024  
**Unique Number** : 5762469 **Diagnosed** : 17 Apr 2024 - Kevin Marson  
**Test Package** : IND 2 ( Additional Tests: TAN Man )

**ST. MARYS CEMENT CO.**  
 400 BOWMANVILLE AVENUE  
 BOWMANVILLE, ON  
 CA L1C 7B5  
 Contact: Lou Traiforos  
 lou.traiforos@vcimentos.com  
 T: (905)440-5874  
 F: (905)623-4695

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.